

27) Access, Grades, Manoeuvring, Carparks, Signs and Line Marking

Construct and maintain access, parking and manoeuvring for vehicles on site in accordance with the relevant Brisbane Planning Scheme Codes, as indicated on the approved DRAWINGS AND DOCUMENTS, including the following:

....

*v. A minimum of ~~2.3~~ **2.1** metres height clearance to all undercover parking areas, including the entry and access to these areas, and a minimum of 2.5 metres above parking spaces for people with disabilities. The minimum clear height must be measured to the lowest protrusion from the ceiling (e.g. fire sprinklers, services, lighting fixtures, signs, etc).*

BCC DS

RECEIVED

01/09/2026

APPLICATION REF

A007103614