

Planning Ref: F25/2092  
Doc Ref: D25/233078  
Council Ref: A006775804

3 December 2025

Brisbane City Council  
GPO Box 1434,  
Brisbane QLD 4001

**Attention:** Katrina Bogoevski  
Via email: [katrina.bogoevski@brisbane.qld.gov.au](mailto:katrina.bogoevski@brisbane.qld.gov.au)  
[cpeds-ds-planningsupport@brisbane.qld.gov.au](mailto:cpeds-ds-planningsupport@brisbane.qld.gov.au)

Dear Katrina,

**Seqwater Third Party Advice – Final Advice – Material change of Use for Medium Impact Industry, Warehouse, Outdoor Sales and Shop and Reconfiguring a Lot (Access Easement) – 68 King Avenue, Willawong – Lot 16 RP80241**

Seqwater responds to your email on 21 November 2025, requesting Third Party Advice for the proposed Material change of use on the above-mentioned site. Seqwater provides the following response, based on information available on Brisbane City Council's Development.i.

**Seqwater Interest:**

Seqwater's interests involve consideration of the impacts of the development on Seqwater infrastructure, being one (1) bulk water supply pipeline located on the northern side of the King Avenue road reserve, being a 1200mm diameter Mild Steel Cement Lined pipe. Accordingly, the proposed development involves the State Energy and Water Supply Interest, as specified in the *State Planning Policy July 2017* (SPP).


**Subject Site:**

The subject site is a battle-axe allotment with a frontage to King Avenue in the north. The sites currently contains five (5) structures located centrally in the allotment, which appear to comprise a Dwelling House, three (3) sheds including a large, industrial sized shed to the south, and a carport. The remainder of the site comprises sporadic mature vegetation and large areas of managed grass.

The site has a total area of 14,040m<sup>2</sup> and is affected by vegetation, flood and bushfire related overlays. Under the Brisbane City Plan 2014, the majority of the subject site is identified within the Industry Investigation Zone, with the rear southern portion identified within the Environmental Management and Conservation Zone.

**Proposal Overview:**

The proposed development is for combined Material Change of Use for multiple uses over the 68 King Avenue site, in conjunction with a Reconfiguring a Lot for an access easement over the battle-axe entry.



The reconfiguring a lot comprises an access easement over the access handle portion of the site, in favour of 66 King Avenue. The Material change of use component comprises the following features, all proposed within the 68 King Avenue site;

- 4 x buildings, including a demountable office, two (2) sheds for storage and one (1) larger shed for vehicle dismantling;
- Existing dwelling to be demolished;
- 12 car parking spaces;
- One (1) metre wide landscaping along northern boundary; and
- Four outdoor shelving areas located in the centre of the site.

**Seqwater Assessment:**

The following relevant application material available on Council’s Development.i tool has been reviewed:

1. Town Planning Report – Job No. 24-00821, Version V1 – prepared by Clegg Town Planning, dated 21 October 2025;
2. Plans of Development, as follows;

Title	Dwg	Rev	Date	Author
Proposal Plan 1 Over Lots 15 & 16 on RP80241 – 66 & 68 King Avenue	12769_P1	-	9 September 2025	ONF Surveyors
Site Plan	1.01	-	9 September 2025	JLA Drafting Studio
Specification	0.01	-	3 June 2025	JLA Drafting Studio
Building 1	2.01	-	3 June 2025	JLA Drafting Studio
Building 2	2.02	-	3 June 2025	JLA Drafting Studio
Building 3	2.03	-	3 June 2025	JLA Drafting Studio
Building 4	2.04	-	3 June 2025	JLA Drafting Studio

3. Engineering Services Report – Reference 11169, prepared by Inertia, dated 22 September 2025; and
4. Confirmation Notice – Reference A006886304, prepared by Brisbane City Council dated, 19 November 2025.

Seqwater has reviewed the application material and has recommended conditions to be employed as part of Council’s decision. Seqwater’s infrastructure must be always protected and remain accessible.

The proposed development seeks establish new service connections, including a reticulated water and gas connections which will cross Seqwater’s infrastructure, therefore sufficient protections are required.

## Recommended Conditions

Seqwater's Network Consent Guidelines (Version 5 – January 2025) are provided, which include background requirements for development in proximity to relevant infrastructure. This includes the requirement that any buildings or structures within five (5) metres of the easement must not interfere with Seqwater's ability to construct additional infrastructure or repair any infrastructure within the easement or impose any loading on existing or future infrastructure within the easement.

Under section 192 of the *Water Supply (Safety and Reliability) Act 2008*, prior to commencement of construction of the development, Seqwater's written consent is required for any works that may impact Seqwater's assets. A formal Consent Application must be submitted by the developer to Seqwater prior to construction, to allow engineering assessment of the operational works to be conducted in proximity to the easement, in compliance with Seqwater's Network Consent Guidelines.

## Engineering requirements

1. Ensure compliance is achieved with the engineering requirements outlined in the Seqwater Network Consent Guideline for any works in proximity to Seqwater's Pipeline in accordance with s192 of the Water Supply (Safety and Reliability) Act 2008 (QLD).

**Note:** Liaison with Seqwater is required during the design process to ensure Seqwater bulk water infrastructure is not interfered with during construction in accordance with the Water Supply (Safety and Reliability) Act. Further information is available in Seqwater's Network Consent Guideline available at: <https://www.seqwater.com.au/living-and-working-near-water-infrastructure>

Please contact Consents Team at Seqwater at: [consents@seqwater.com.au](mailto:consents@seqwater.com.au)

2. The reticulated water service proposed to cross the Seqwater bulk water pipeline is to comply with Seqwater requirements, achieve a minimum 500mm vertical separation to Seqwater's pipeline and be installed within/as a rigid material capable structurally of spanning over potential excavations of the pipeline.

**Advice Note:** Ensure the Connection Application to Urban Utilities is referred to Seqwater for Third Party Advice.

3. During and post-construction, ensure that access to any existing air-valves and air-valve pits located adjacent to Seqwater's pipeline is maintained at all times.

Should you have any questions about this matter please contact Will Hardy, Senior Planning Officer via email at [planning@seqwater.com.au](mailto:planning@seqwater.com.au).

Yours sincerely,

**Leah Carter**  
Integrated Planning Coordinator