



NOISE IMPACT ASSESSMENT
PROPOSED CHILDCARE CENTRE
141 FURSDEN ROAD
CARINA

Prepared for:
Roycorp Pty Ltd

Prepared by:
MWA Environmental

10 June 2026

DOCUMENT CONTROL SHEET

MWA Environmental		
Level 8 241 Adelaide Street	Job Name:	Carina
GPO Box 3137 Brisbane 4001	Job No:	26062
Telephone: 07 3002 5500		
Email: mail@mwaenviro.com.au	Original Date of Issue:	10 June 2026

DOCUMENT DETAILS

Title:	Noise Impact Assessment – Proposed Childcare Centre – 141 Fursden Road, Carina
Principal Author:	Mr Elton Singh
Client:	Roycorp Pty Ltd
Client Contact:	Royce Blackburne

REVISION/CHECKING HISTORY

Version Number	Date	Issued By		Checked By	
1 DA Report	10.06.2026	ES		PAK	
2					
3					
4					
5					

DISTRIBUTION RECORD

[illegible]

CONTENTS**PAGE**

1.0 INTRODUCTION.....	1
1.1 STUDY BRIEF	1
1.2 SITE DESCRIPTION	1
1.3 PROPOSED DEVELOPMENT	2
2.0 EXISTING NOISE ENVIRONMENT.....	3
3.0 NOISE CRITERIA	5
3.1 CHILDCARE CENTRE CODE	5
3.2 COMMUNITY FACILITIES CODE	6
4.0 NOISE IMPACT ASSESSMENT	8
4.1 NEAREST NOISE SENSITIVE RECEPTORS	8
4.2 NOISE MODELLING	8
4.3 NOISE CONTROL MEASURES	11
4.4 PREDICTED NOISE LEVELS	11
5.0 CONCLUSIONS.....	15

FIGURES**ATTACHMENTS**

1.0 INTRODUCTION

1.1 STUDY BRIEF

MWA Environmental has been engaged to prepare a Noise Impact Assessment for a proposed Childcare Centre development at 141 Fursden Road, Carina. The childcare centre is to be located within a proposed townhouse development on the land.

The assessment has considered the potential impact of noise emissions from the proposed development upon the surrounding noise sensitive receptors. The assessment is based on ambient noise monitoring conducted at the locality, noise measurements previously conducted on typical sources associated with the proposed use and detailed noise propagation modelling.

The report has been prepared in accordance with the requirements of the Brisbane City Council (BCC) *City Plan 2014*.

1.2 SITE DESCRIPTION

The subject site is located 141 Fursden Road, Carina (the '**subject site**'). The subject site is zoned *CF7 Community Facilities* and has real property descriptions of Lot 2 on SP305062.

Surrounding land uses are described as follows:

To the North:	Fursden Road is located to the north with existing residential dwellings on land zoned <i>Low Density Residential</i> beyond the road.
To the East:	Land zoned <i>CR5 Communities Facilities</i> which is used as sporting field by Brisbane State High School and has existing netball and tennis courts and sporting fields.
To the South:	Existing residential dwellings on land zoned <i>Low Density Residential</i> .
To the West:	Existing St Vincent's Aged Care facility located on land zoned <i>CF7 Community Facilities</i> .

The site location and surrounding land uses are shown on the aerial photo included as **Figure 1**.

The surrounding land use zoning shown on **Figure 2**.

1.3 PROPOSED DEVELOPMENT

The proposed development comprises an 88-place childcare centre with associated outdoor play areas. The centre is designed as a two storey building, with the ground level accommodating car parking, office, kitchen, staff facilities and some educational rooms with an outdoor play area (outdoor play area 1). The upper level contains the majority of the educational rooms and two additional outdoor play areas (outdoor play areas 3 and 4).

The following summarises the development:

- Ground level with total of 18 carparking bays, staff and services area;
- Ground floor with 469m² GBA childcare,
- Upper floor with 543m² GBA childcare,
- Three separate outdoor play areas totalling 759m²; and
- Vehicle access via internal roads which links to Fursden Road.

A servicing area for refuse collection is at the site within the carpark.

The proposed operating hours are 6am to 6pm Monday to Friday with the outdoor play areas to be used between 7am and 6pm.

Servicing / deliveries are proposed within the hours 7am to 6pm Monday to Friday.

The development plans are included as **Attachment 1**.

2.0 EXISTING NOISE ENVIRONMENT

To enable assessment of the existing noise exposure of the subject site, noise measurements have been undertaken using a Norsonic NOR139 noise datalogger located at the site over a 7-day period from 21 to 28 April 2026.

The noise datalogger used was programmed to provide statistical analysis results based on 15-minute sampling periods. The sound level meter was pre-calibrated to 94 dB at 1 kHz using a Norsonic Sound Calibrator Nor1256. The meter displayed a deviation of less than ± 0.2 dB from this level at post-calibration.

Weather conditions during the noise monitoring period varied with light to moderate winds and some days with rainfall. It was noted that rainfall events were recorded between the 24 to 28 April. The recorded data was filtered to remove any extraneous near-field noise events which included removal of data on the 25, 26 and 27 April due to heavy rainfall.

The unattended statistical noise levels recorded by the noise datalogger are listed below in **Table 1** with the monitoring location shown on **Figure 3**.

The recorded noise levels are presented as statistical components, which are described as:

- $L_{\max}$: Noise level referred to as the adjusted maximum sound pressure level.
- L_{10} : Noise level exceeded for 10 percent of the measurement period, referred to as the averaged maximum sound pressure level.
- L_{90} : Noise level exceeded for 90 percent of the measurement period. AS1055-2018 ¹ notes that the L_{90} is described as the background sound pressure level.
- L_{eq} : An “average” measurement, and as per AS1055-2018 defined as the value of the sound pressure level of a continuous steady sound state, that within a measurement period, has the same mean square sound pressure as a sound under consideration whose level varies with time.

¹ Australian Standard AS 1055-2018 *Acoustics – Description and measurement of environmental noise, Part 1: General procedures*

**Table 1: Ranges of Site Recorded Noise Levels
21 to 28 April 2026**

PARAMETER	PERIOD	RECORDED NOISE LEVELS – dB(A)		
		MINIMUM	MAXIMUM	AVERAGE
L_{max}	Daytime (7am-6pm)	63	80	70
	Evening (6pm-10pm)	61	80	68
	Nighttime (10pm-7am)	46	85	65
L₁₀	Daytime (7am-6pm)	54	63	58
	Evening (6pm-10pm)	50	59	55
	Nighttime (10pm-7am)	41	63	48
L₉₀	Daytime (7am-6pm)	45	53	48
	Evening (6pm-10pm)	43	51	47
	Nighttime (10pm-7am)	39	51	43
L_{eq}	Daytime (7am-6pm)	50	59	54
	Evening (6pm-10pm)	48	56	52
	Nighttime (10pm-7am)	41	58	47

The datalogger recorded noise levels are included as graphical traces of noise level versus time for the statistical noise level descriptors L₁, L₁₀, L₉₀ and L_{eq} as **Attachment 2**.

Other recorded statistical noise level parameters included:

Rating Background Level – Daytime	=	47 dB(A)
Rating Background Level – Evening	=	45 dB(A)
Rating Background Level – Night	=	40 dB(A)
Average Leq (10pm to 7am)	=	47 dB(A)

3.0 NOISE CRITERIA

3.1 CHILDCARE CENTRE CODE

The BCC CityPlan 2014 *Childcare Centre Code* includes the following Performance Outcome PO10 related to noise emissions from the proposed development:

<i>Performance outcomes</i>	<i>Acceptable outcomes</i>
Section A—If in the Industrial amenity investigation area sub-category	
PO10 <i>Development is of a nature and scale which does not result in noise emissions that exceed the following criteria:</i> <i>$L_{Aeq,adj,T}$ emitted from the development is not greater than the rating background level plus 3 at the sensitive use.</i> <i>Where T is:</i> (a) Day (7am to 6pm): 11 hr; (b) Evening (6pm to 10pm): 4 hr; (c) Night (10pm to 7am): 9hr. <i>Where $L_{Aeq,adj,T}$ is the A-weighted equivalent continuous sound pressure level during measurement time T, adjusted for tonal and impulsive noise characteristics, determined in accordance with the methodology described in the Noise impact assessment planning scheme policy.</i> <i>Note—Rating background level is to be determined in accordance with the methodology described in the Noise impact assessment planning scheme policy.</i> <i>Note—A noise impact assessment report prepared in accordance with the methodology described in the Noise impact assessment planning scheme policy can assist in demonstrating achievement of this performance outcome.</i>	AO10.1 <i>Development provides a 2m high acoustic fence and a minimum 2m wide landscaped buffer along any boundary adjoining land in a zone in the Residential zones category.</i>
	AO10.2 <i>Development ensures mechanical plant or equipment is acoustically screened from adjoining sensitive uses.</i> <i>Note—Mechanical plant includes generators, motors, compressors and pumps, for example air-conditioning, refrigeration or coldroom motors.</i>
	AO10.3 <i>Development does not operate before 7am or after 7pm.</i>

The proposed operating hours commence from 6am and thus the childcare centre use does not satisfy AO10.3. Mechanical plant and equipment will be acoustically and visually screened from adjoining sensitive uses in accordance with AO10.2.

The CityPlan 2014 definition of a ‘sensitive use’ includes a ‘residential care facility’ and thus these noise criteria apply at the following surrounding buildings:

- The residential dwelling to the north and south of the site;
- St Vincent's Aged Care buildings to the west of the site; and
- The proposed townhouse dwellings within the subject site.

Based upon the measured Rating Background Levels from the datalogger the relevant noise criteria at the surrounding aged care buildings and residential dwellings are determined as follows:

Day L_{Aeq} (11 hour):	50 dB(A)
Evening L_{Aeq} (4hr):	48 dB(A)
Night L_{Aeq} (9hr):	43 dB(A)

3.2 COMMUNITY FACILITIES CODE

Assessment against the Community Facilities Code has also been conducted to address the potential impact of noise emissions from the proposed development on nearby sensitive receptors.

The assessed nearest noise sensitive zones comprise the Low Density Residential zone. No noise limits are prescribed for the Community Facilities zone or sensitive uses within the Community Facilities zone under the Code but are prescribed at the Low Density Residential zone.

The relevant PO2 noise (planning) criteria are specified in Table 9.3.5.3.B and the night-time criteria are specified in Table 9.3.5.3.C as presented below:

Table 9.3.5.3.B—Noise (planning) criteria

Criteria location	Intrusive noise criteria	Acoustic amenity criteria		
	Day, evening and night $L_{Aeq,adj,T}$ are not greater than the RBL plus the value in this column for the relevant criteria location, where T equals: - day – 11hr - evening – 4hr - night – 9hr	Day, evening and night $L_{Aeq,adj,T}$ are not greater than the values in the columns below for the relevant criteria location, where T equals: - day – 11hr - evening – 4hr - night – 9hr		
		Day	Evening	Night
Low Density residential zone boundary	3dB(A)	55dB(A)	45dB(A)	40dB(A)

Table 9.3.5.3.C—Night-time Noise Criteria

Criteria location	Where the existing $L_{Aeq,9hr}$ night at the criteria location is:	Average of the highest 15 single L_{Amax} events over a given night (10pm-7am) period is not greater than the following values at the relevant criteria location:	The absolute highest single L_{Amax} event over a given night (10pm-7am) period is not greater than the following values at the relevant criteria location:
At the zone boundary of: Low Density residential zone	45 to 60dB(A)	$L_{Aeq,9hr \text{ night}} + 5\text{dB(A)}$	$L_{Aeq,9hr \text{ night}} + 10\text{dB(A)}$

Based on the applicable noise criteria from the Community Facilities Code the relevant noise limits at surrounding Low Density Residential zone boundaries are summarised in **Table 2**.

Table 2: Zone Boundary Noise Criteria

Criteria	Day	Evening	Night
	L _{Aeq} (11hr)	L _{Aeq} (4hr)	L _{Aeq} (9hr)
Acoustic Amenity Criteria	55 dB(A)	45 dB(A)	40 dB(A)
Intrusive Noise Criteria	50 dB(A)	48 dB(A)	43 dB(A)
Night-time Noise Criteria			L_{Amax}
Night-time Average 15 Highest Noise Criteria	-	-	52 dB(A)
Night-time Absolute Highest Noise Criteria	-	-	57 dB(A)

The lower of the Acoustic Amenity Criteria or the Intrusive Noise Criteria is adopted for the assessment as **bolded** in **Table 2** and applied to the zone boundaries of the Low Density Residential zones.

4.0 NOISE IMPACT ASSESSMENT

4.1 NEAREST NOISE SENSITIVE RECEPTORS

The eight (8) nearest noise sensitive receptors that have been identified and considered for the purposes of this assessment are detailed in **Table 3**. Receptors R7 and T1 to T72 (future townhouses on subject site) are assessed at the sensitive uses with receptors R1 to R6 assessed at the boundaries of the zone as required by the code.

Table 3: Modelled Noise Sensitive Receptors

Receptor	Location	Survey Plan	Receiver Height	Zone/Precinct
R1	68 Fursden Road	202/RP13175	Single Storey	Low Density Residential
R2	68A Fursden Road	201/RP13175	Double Storey	Low Density Residential
R3	70 Fursden Road	200/RP13175	Double Storey	Low Density Residential
R4	72 Fursden Road	1/RP98715	Double Storey	Low Density Residential
R5	74 Fursden Road	2/RP98715	Double Storey	Low Density Residential
R6	Argo Place	SP172837	Double Storey	Low Density Residential
R7	101 Fursden Road	1/SP305062	Mixed Storey	Community Facilities
T1-T72	141 Fursden Road	2/SP305062	Double Storey	Community Facilities

The nominated receptors are shown on an aerial image base on **Figure 4**.

4.2 NOISE MODELLING

Key noise sources associated with the proposed childcare development are as follows:

- Carparking including vehicle movements
- Servicing (refuse collection)
- Outdoor play noise
- Air-conditioning and Kitchen exhaust

MWA Environmental has received advice from PTT Traffic and Transport Engineering, that the peak hour trip generation for the development will be as per **Table 4**.

Table 4: Vehicle Trip Generation (veh/hr)

Land Use	Number of Children	AM Peak	PM Peak
Childcare	88 Children	67	50

For the purpose of the noise modelling, traffic has been distributed across the 6am to 6pm period with the AM peak trip applied to the 7am to 8am period and 3pm to 4pm period as conservative approach and the remaining trips distributed throughout the balance of the trading period.

The noise emissions from vehicles movements entering/exiting the site and carparking noise (car starts and door slams) were modelled as line sources and area sources, respectively.

Servicing of the centre will generally be via vans which do not generate materially different noise to passenger vehicles. However, refuse collection noise and refuse collection vehicle (RCV) movement and potential other heavy vehicle trips have been considered in the noise model as 2 trips during the day period only as a line source (i.e. servicing limited to between 7am to 6pm).

The source noise levels for the childcare outdoor play areas were determined using the *Association of Australian Acoustical Consultants Technical Guideline Child Care Centre Noise Assessment* (September 2020, version 3).

As per the guideline, the noise levels of children playing can vary depending on the age of the children and the type of activity. Sound power levels of children are presented in the guideline as per **Table 5** below.

Table 5: Effective Sound Power Levels ($L_{Aeq, 15min}$) for Groups of 10 Children Playing as per AAC Technical Guideline

Number and Age of Children	Sound Power Levels [dB] at Octave Band Centre Frequencies [Hz]								
	dB(A)	63	125	250	500	1k	2k	4k	8k
10 Children - 0 to 2 years	78	54	60	66	72	74	71	67	64
10 Children - 2 to 3 years	85	61	67	73	79	81	78	74	70
10 Children - 3 to 5 years	87	64	70	75	81	83	80	76	72

The outdoor play areas have been assessed as operating between 7am and 6pm.

Assessment of $L_{Aeq, 11hr}$ 7am to 6pm noise emissions from the outdoor play areas has been based upon each child conservatively spending 75 percent of the day outdoors.

Noise emissions from outdoor play areas have been represented as area sources at the following sound power levels:

Outdoor Play Area 1: 24 children (0-2 years): 81.8 dB(A)
 Outdoor Play Area 3: 20 children (2-3 years): 88.0 dB(A)
 Outdoor Play Area 4: 44 children (3-5 years): 93.4 dB(A)

Vehicle movements entering and leaving the carpark were represented as follows.

Vehicles 7am to 8am and 3pm to 4pm
 (peak 69 trips per hour): L_{Aeq} 70.4 dB(A)/m² SWL

Vehicles 6am to 7am, 8am to 3pm and 4pm to 6pm
 (avg. 7 trips per hour): L_{Aeq} 60.4 dB(A)/m SWL

L_{Amax} 89.0 dB(A) SWL

For carparking noise the parking lot area source was represented in the model on the basis of the following:

Carparking 7am to 8am and 3pm to 4pm
 (peak 2 turnovers/bay/hour): L_{Aeq} 82.6 dB(A) SWL

Carparking 6am to 7am, 8am to 3pm and 4pm to 6pm
 (avg. 0.4 turnover/bay/hour): L_{Aeq} 75.6 dB(A) SWL

L_{Amax} 89.0 dB(A) SWL

Servicing noise, truck movement and refuse collection or deliveries were represented in the model as follows.

Truck movement (2 trips ³): L_{Aeq} 59 dB(A) SWL per trip
 L_{Amax} 99.0 dB(A) SWL

Refuse collection ⁴: L_{Aeq} 99 dB(A) SWL

Delivery ⁵: L_{Aeq} 76 dB(A) SWL

Noise emissions from external mechanical plant have been represented as point sources at the proposed services area with a single kitchen exhaust fan on the roof top.

Air-Conditioning Units (x3): L_{Aeq} 75 dB(A) SWL

Air-Conditioning Unit: L_{Aeq} 73 dB(A) SWL

² Based upon an instantaneous maximum level of 89 dB(A) and an average speed of 5 km/h extrapolated to represent 66 trips per hour (including vans).

³ 1 in and 1 out during day period with SWL specified per truck movement and an average speed of 10 km/h.

⁴ Noise event for 1 minute during day period

⁵ L_{Aeq} noise event for 1 hour during day period with 2 deliveries

Air-Conditioning Unit:	L_{Aeq} 70 dB(A) SWL
Kitchen Exhaust:	L_{Aeq} 75 dB(A) SWL

4.3 NOISE CONTROL MEASURES

The noise modelling has demonstrated compliant outcomes based upon the following:

- **Servicing, refuse collection and deliveries** are to occur between **7am and 6pm only**.
- **Outdoor Play Area to be used** between **7am and 6pm only**.
- A minimum **1.8 metre high acoustic barrier** to the outer perimeter of outdoor play area 1 i.e. north, east and south boundary of outdoor play area on the Ground Level. The 1.8m height is specified as height above the outdoor play area finished surface level.
- A minimum **1.8 and 2.2 metre high solid (gap-free) balustrade/ acoustic barrier** is required to the eastern and northern perimeter of outdoor play area 3 on the Upper Level, respectively. The balustrade/ acoustic barrier heights are specified as height above the outdoor play area FFL.
- A minimum **2.0 and 2.4 metre high solid (gap-free) balustrade/ acoustic barrier** is required to the western and northern perimeter of outdoor play area 4 on the Upper Level, respectively. The balustrade/ acoustic barrier heights are specified as height above the outdoor play area FFL.
- Mechanical plant services area on the upper level should be acoustically screened with an acoustic screen or acoustic louvre at minimum height of 1 metre above the tallest plant.
- Mechanical plant and equipment should be selected and located as necessary to achieve the relevant noise limits at sensitive uses.

The recommended ground level acoustic barrier is presented on **Figure 5**.

The recommended upper level acoustic barriers / balustrades are presented on **Figure 6**.

The construction of the acoustic barrier / balustrades should be gap free and achieve a minimum density of 12.5kg/m².

4.4 PREDICTED NOISE LEVELS

The predicted L_{Aeq} and L_{Amax} noise levels at the most exposed zone boundaries of the Low Density Residential receptors identified in **Figure 4** are presented in **Table 6** below for compliance against the Community Facilities noise limits.

Table 6: Predicted Resultant Noise Levels at the Nearest Zone Boundaries

RECEPTOR	Level	PREDICTED NOISE LEVEL – dB(A)			
		Day L _{Aeq} 11 hr	Night L _{Aeq} 9hr	Average L _{Amax}	Absolute L _{Amax}
R1	Ground	40	21	38	43
	Upper	42	21	37	42
R2	Ground	40	21	37	42
	Upper	42	21	37	42
R3	Ground	40	21	37	42
	Upper	42	21	37	42
R4	Ground	40	21	37	42
	Upper	41	21	37	42
R5	Ground	39	19	36	41
	Upper	41	19	36	41
R6	Ground	28	15	28	33
	Upper	28	15	28	33
CRITERIA LDR Zone		50	40	52	57

The predicted resultant noise levels satisfy the relevant CityPlan 2014 Community Facilities Code noise criteria at the nominated sensitive zone boundaries and in meeting these criteria also would satisfy the Child Care Centre Code noise criteria for the sensitive uses in these zones.

The predicted L_{Aeq} noise levels at the most exposed sensitive uses in Community Facilities zone of the receptors identified in **Figure 4** are presented in **Table 7** below for compliance against the Childcare Centre Code noise limits.

Table 7: Predicted Resultant Noise Levels at the Nearest Sensitive Uses

RECEPTOR	Level	PREDICTED NOISE LEVEL – dB(A)	
		Day L _{Aeq} 11 hr	Night L _{Aeq} 9hr
R7	Ground	38	23
	Upper	39	21
T1	Ground	45	27
	Upper	47	27
T2	Ground	47	30
	Upper	49	30
T3	Ground	48	31
	Upper	50	31
T4	Ground	49	32
	Upper	50	31
T5	Ground	48	32
	Upper	49	30
T8	Ground	47	30
	Upper	49	30
T9	Ground	47	31
	Upper	50	30
T10	Ground	47	31
	Upper	49	30
T11	Ground	46	31
	Upper	48	31
T12	Ground	45	31
	Upper	46	31
T67	Ground	48	35
	Upper	48	36
T68	Ground	49	36
	Upper	48	36
CRITERIA Childcare Code		50	43

Table 7: Continued

RECEPTOR	Level	PREDICTED NOISE LEVEL – dB(A)	
		Day L _{Aeq} 11 hr	Night L _{Aeq} 9hr
T69	Ground	47	34
	Upper	46	33
T70	Ground	45	32
	Upper	45	32
T71	Ground	41	27
	Upper	41	28
T72	Ground	38	23
	Upper	43	24
CRITERIA Childcare Code		50	43

The predicted resultant noise levels satisfy the relevant CityPlan 2014 Child Care Centre Code noise criteria at the surrounding sensitive uses.

All other surrounding zone boundaries are predicted to experience lower noise levels than the nearest receptors summarised in **Table 6**.

The noise propagation calculations are included as **Attachment 3**.

Noise contour plots showing the predicted noise levels are included as **Attachment 4**.

5.0 CONCLUSIONS

MWA Environmental has been engaged to prepare a Noise Impact Assessment for a proposed Childcare Centre development at 141 Fursden Road, Carina.

The assessment has considered the potential impact of noise emissions from the proposed development upon the surrounding noise sensitive receptors. The assessment is based on ambient noise monitoring conducted at the locality, noise measurements previously conducted on typical sources associated with the proposed use and detailed noise propagation modelling.

The proposed childcare centre use has been assessed to comply with Performance Outcome PO2 of the *Community Facilities Code* and Performance Outcome PO10 of the *Childcare Centre Code* with the following noise control measures:

- **Servicing, refuse collection and deliveries** are to occur between **7am and 6pm only**.
- **Outdoor Play Area to be used** between **7am and 6pm only**.
- A minimum **1.8 metre high acoustic barrier** to the outer perimeter of outdoor play area 1, i.e. north, east and south boundary of outdoor play area on the Ground Level. The 1.8m height is specified as height above the outdoor play area finished surface level.
- A minimum **1.8 and 2.2 metre high solid (gap-free) balustrade/ acoustic barrier** is required to the eastern and northern perimeter of outdoor play area 3 on the Upper Level, respectively. The balustrade/ acoustic barrier heights are specified as height above the outdoor play area FFL.
- A minimum **2.0 and 2.4 metre high solid (gap-free) balustrade/ acoustic barrier** is required to the western and northern perimeter of outdoor play area 4 on the Upper Level, respectively. The balustrade/ acoustic barrier heights are specified as height above the outdoor play area FFL.
- Mechanical plant services area on the upper level should be acoustically screened with an acoustic screen or acoustic louvre at minimum height of 1 metre above the tallest plant.
- Mechanical plant and equipment should be selected and located as necessary to achieve the relevant noise limits at sensitive uses.

The recommended ground level acoustic barrier is presented on **Figure 5**.

The recommended upper level acoustic barriers / balustrades are presented on **Figure 6**.

The construction of the acoustic barrier / balustrades should be gap free and achieve a minimum density of 12.5kg/m².

MWA Environmental
10 June 2026

FIGURES



LEGEND

--- SITE LOCATION

PROPERTY BOUNDARY

DRAWING REFERENCE

© THE STATE OF QUEENSLAND 2026
(DEPARTMENT OF NATURAL RESOURCES
AND MINES, MANUFACTURING AND
REGIONAL AND RURAL DEVELOPMENT)
QLDGLOBE.

N

0 20 40 60m

CLIENT

ROYCORP PTY LTD

PROJECT

**NOISE IMPACT
ASSESSMENT
PROPOSED CHILDCARE
CENTRE DEVELOPMENT
141 FURSDEN ROAD
CARINA QLD**


TITLE

**SITE LOCATION
AND SURROUNDING
LAND USES**

JOB	CARINA	FIGURE 1
JOB NO.	26062	
DATE	10/06/26	DWG NUMBER
SCALE	1:2000 (A4)	26062-1
REV.		

mwa
ENVIRONMENTAL

Max Winders & Associates Pty Ltd t/as MWA Environmental
Level 8, 241 Adelaide St, Brisbane, QLD 4001
P 07 3002 5500 E mail@mwaenviro.com.au
W www.mwaenviro.com.au
ABN 94 010 833 084



LEGEND

- SITE LOCATION
- PROPERTY BOUNDARY

BCC CITY PLAN 2014 ZONING

- CF7 COMMUNITY FACILITIES (HEALTH CARE PURPOSES)
- CF5 COMMUNITY FACILITIES (EDUCATION PURPOSES)
- LDR LOW DENSITY RESIDENTIAL
- EC EMERGING COMMUNITY
- OS1 OPEN SPACE (LOCAL)

DRAWING REFERENCE
BCC CITY PLAN 2014, INTERACTIVE MAPPING, ZONING MAP.





CLIENT
ROYCORP PTY LTD

PROJECT
NOISE IMPACT ASSESSMENT
PROPOSED CHILDCARE CENTRE DEVELOPMENT
141 FURSDEN ROAD
CARINA QLD

TITLE
BCC ZONING MAP

JOB	CARINA	FIGURE 2
JOB NO.	26062	
DATE	10/06/26	DWG NUMBER
SCALE	1:2000 (A4)	26062-2
REV.		



mwa
ENVIRONMENTAL

Max Winders & Associates Pty Ltd t/as MWA Environmental
Level 8, 241 Adelaide St, Brisbane, GPO BOX 3137, Brisbane Qld 4001
P 07 3002 5500 E mail@mwaenviro.com.au
W www.mwaenviro.com.au
ABN 94 010 833 084



LEGEND

- SITE LOCATION
- PROPERTY BOUNDARY
- NOISE DATALOGGER LOCATION (UNATTENDED)

DRAWING REFERENCE
© THE STATE OF QUEENSLAND 2026
(DEPARTMENT OF NATURAL RESOURCES
AND MINES, MANUFACTURING AND
REGIONAL AND RURAL DEVELOPMENT)
QLDGLOBE.



0 10 20 30 40 50m

CLIENT
ROYCORP PTY LTD

PROJECT
**NOISE IMPACT
ASSESSMENT
PROPOSED CHILDCARE
CENTRE DEVELOPMENT
141 FURSDEN ROAD
CARINA QLD**

TITLE
**NOISE MONITORING
LOCATION**

JOB	CARINA	FIGURE 3
JOB NO.	26062	
DATE	10/06/26	DWG NUMBER
SCALE	1:1500 (A4)	26062-3
REV.		




Max Winders & Associates Pty Ltd t/as MWA Environmental
Level 8, 241 Adelaide St, Brisbane, QPO BOX 3137, Brisbane Qld 4001
P 07 3002 5500 E mail@mwaenviro.com.au
W www.mwaenviro.com.au
ABN 94 010 833 084



- LEGEND**
- SITE LOCATION
 - PROPERTY BOUNDARY
 - R7 SENSITIVE RECEPTOR LOCATIONS (R1-R7)
 - T72 SITE SENSITIVE TOWNHOUSE RECEPTORS (T1-T12 & T67-T72)

DRAWING REFERENCES

- © THE STATE OF QUEENSLAND 2026 (DEPARTMENT OF NATURAL RESOURCES AND MINES, MANUFACTURING AND REGIONAL AND RURAL DEVELOPMENT) QLDGLOBE.
- ROYCORP SITE PLAN S-0001 REV X



CLIENT

ROYCORP PTY LTD

PROJECT

NOISE IMPACT ASSESSMENT
PROPOSED CHILDCARE CENTRE DEVELOPMENT
141 FURSDEN ROAD
CARINA QLD

TITLE

SENSITIVE RECEPTOR LOCATIONS

JOB	CARINA	FIGURE 4
JOB NO.	26062	
DATE	10/06/26	DWG NUMBER
SCALE	1:1500 (A4)	26062-4
REV.		



LEGEND
1.8m BARRIER HEIGHT
ACOUSTIC BARRIER

CLIENT
ROYCORP PTY LTD

PROJECT
NOISE IMPACT ASSESSMENT
PROPOSED CHILDCARE CENTRE DEVELOPMENT
141 FURSDEN ROAD
CARINA QLD

TITLE
GROUND FLOOR ACOUSTIC BARRIER LOCATION

JOB	CARINA	FIGURE 5
JOB NO.	26062	
DATE	10/06/26	
SCALE	1:300 (A4)	
REV.		26062-5

mwa
 ENVIRONMENTAL

Max Winders & Associates Pty Ltd t/as MWA Environmental
 Level 8, 241 Adelaide St, Brisbane, GPO BOX 3137, Brisbane Qld 4001
 P 07 3002 5500 E mail@mwaenviro.com.au
 W www.mwaenviro.com.au
 ABN 94 010 833 084

1 GROUND FLOOR PLAN
 1:200




Attachment 1

Development Design Drawings






1 GROUND FLOOR PLAN
1:200









1 ROOF PLAN
1:200











ARTIST IMPRESSION ONLY



ARTIST IMPRESSION ONLY



ARTIST IMPRESSION ONLY




ARTIST IMPRESSION ONLY


Attachment 2

Datalogger Trace


26062 Carina - Statistical Noise Levels at - Tuesday, 21/04/2026




26062 Carina - Statistical Noise Levels at - Wednesday, 22/04/2026




26062 Carina - Statistical Noise Levels at - Thursday, 23/04/2026



26062 Carina - Statistical Noise Levels at - Friday, 24/04/2026



26062 Carina - Statistical Noise Levels at - Tuesday, 28/04/2026



Attachment 3

SoundPLAN Noise Propagation Calculations

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	l or A m,m²	Kl dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)
Receiver R1	FI GF	Lmax 43 dB(A)	LAEq - Day 40 dB(A)	LAEq - Nig 21 dB(A)																			
Parking	PLot	LAEq - Day			53.3	79.6	418.8	0.0	0.0	0	70.69	-48.0	0.6	-0.4	-0.6	0.00	0.0	0.1	31.3	0.0	-1.6	0.0	29.7
Parking	PLot	LAEq - Nig			53.3	79.6	418.8	0.0	0.0	0	70.69	-48.0	0.6	-0.4	-0.6	0.00	0.0	0.1	31.3	0.0	-13.5	0.0	17.8
AC1	Point	LAEq - Day			75.0	75.0		0.0	0.0	0	82.49	-49.3	0.1	-21.0	-0.3	0.00	0.0	0.0	4.5	0.0	-0.8	0.0	3.7
AC1	Point	LAEq - Nig			75.0	75.0		0.0	0.0	0	82.49	-49.3	0.1	-21.0	-0.3	0.00	0.0	0.0	4.5	0.0	-10.3	0.0	-5.8
AC2	Point	LAEq - Day			75.0	75.0		0.0	0.0	0	82.36	-49.3	0.1	-21.0	-0.3	0.00	0.0	0.0	4.5	0.0	-0.8	0.0	3.7
AC2	Point	LAEq - Nig			75.0	75.0		0.0	0.0	0	82.36	-49.3	0.1	-21.0	-0.3	0.00	0.0	0.0	4.5	0.0	-10.3	0.0	-5.8
AC3	Point	LAEq - Day			75.0	75.0		0.0	0.0	0	82.55	-49.3	0.1	-20.9	-0.3	0.00	0.0	0.0	4.6	0.0	-0.8	0.0	3.8
AC3	Point	LAEq - Nig			75.0	75.0		0.0	0.0	0	82.55	-49.3	0.1	-20.9	-0.3	0.00	0.0	0.0	4.6	0.0	-10.3	0.0	-5.7
AC4	Point	LAEq - Day			73.0	73.0		0.0	0.0	0	82.58	-49.3	0.1	-21.0	-0.3	0.00	0.0	0.0	2.6	0.0	-0.8	0.0	1.8
AC4	Point	LAEq - Nig			73.0	73.0		0.0	0.0	0	82.58	-49.3	0.1	-21.0	-0.3	0.00	0.0	0.0	2.6	0.0	-10.3	0.0	-7.8
AC5	Point	LAEq - Day			70.0	70.0		0.0	0.0	0	83.07	-49.4	0.1	-20.5	-0.3	0.00	0.0	2.3	2.2	0.0	-0.8	0.0	1.4
AC5	Point	LAEq - Nig			70.0	70.0		0.0	0.0	0	83.07	-49.4	0.1	-20.5	-0.3	0.00	0.0	2.3	2.2	0.0	-10.3	0.0	-8.1
Car Trips	Line	LAEq - Day			52.0	67.1	32.3	0.0	0.0	0	67.08	-47.5	-0.1	-0.1	-0.6	0.00	0.0	0.0	18.7	0.0	12.6	0.0	31.4
Car Trips	Line	LAEq - Nig			52.0	67.1	32.3	0.0	0.0	0	67.08	-47.5	-0.1	-0.1	-0.6	0.00	0.0	0.0	18.7	0.0	-1.1	0.0	17.6
Deliveries	Point	LAEq - Day			76.0	76.0		0.0	5.0	0	65.30	-47.3	0.7	0.0	-1.6	0.00	0.0	0.0	27.8	0.0	-7.4	0.0	25.4
Deliveries	Point	LAEq - Nig			76.0	76.0		0.0	5.0	0	65.30	-47.3	0.7	0.0	-1.6	0.00	0.0	0.0	27.8	0.0			
Kitchen Exhaust	Point	LAEq - Day			75.0	75.0		0.0	0.0	0	78.01	-48.8	0.5	-4.5	-0.6	0.00	0.0	0.0	21.6	0.0	-0.8	0.0	20.8
Kitchen Exhaust	Point	LAEq - Nig			75.0	75.0		0.0	0.0	0	78.01	-48.8	0.5	-4.5	-0.6	0.00	0.0	0.0	21.6	0.0	-10.3	0.0	11.3
Outdoor Play 1	Area	LAEq - Day			60.5	81.8	133.8	0.0	0.0	0	76.27	-48.6	0.0	-9.3	-0.7	0.00	0.0	1.8	25.0	0.0	-1.2	0.0	23.8
Outdoor Play 1	Area	LAEq - Nig			60.5	81.8	133.8	0.0	0.0	0	76.27	-48.6	0.0	-9.3	-0.7	0.00	0.0	1.8	25.0	0.0			
Outdoor Play 3	Area	LAEq - Day			66.5	88.0	140.2	0.0	0.0	0	67.57	-47.6	0.8	-12.3	-0.4	0.00	0.0	3.8	32.3	0.0	-1.2	0.0	31.1
Outdoor Play 3	Area	LAEq - Nig			66.5	88.0	140.2	0.0	0.0	0	67.57	-47.6	0.8	-12.3	-0.4	0.00	0.0	3.8	32.3	0.0			
Outdoor Play 4	Area	LAEq - Day			68.7	93.4	292.3	0.0	0.0	0	63.26	-47.0	0.7	-12.1	-0.4	0.00	0.0	3.3	37.9	0.0	-1.2	0.0	36.7
Outdoor Play 4	Area	LAEq - Nig			68.7	93.4	292.3	0.0	0.0	0	63.26	-47.0	0.7	-12.1	-0.4	0.00	0.0	3.3	37.9	0.0			
RCV	Line	LAEq - Day			59.0	69.7	11.9	0.0	0.0	0	59.78	-46.5	0.4	-0.1	-0.5	0.00	0.0	0.0	23.1	0.0	-7.4	0.0	15.7
RCV	Line	LAEq - Nig			59.0	69.7	11.9	0.0	0.0	0	59.78	-46.5	0.4	-0.1	-0.5	0.00	0.0	0.0	23.1	0.0			
Refuse (Loading)	Point	LAEq - Day			99.0	99.0		5.0	0.0	0	56.37	-46.0	0.4	0.0	-0.5	0.00	0.0	0.0	52.8	0.0	-28.2	0.0	29.7
Refuse (Loading)	Point	LAEq - Nig			99.0	99.0		5.0	0.0	0	56.37	-46.0	0.4	0.0	-0.5	0.00	0.0	0.0	52.8	0.0			
Receiver R1	FI F 1	Lmax 42 dB(A)	LAEq - Day 42 dB(A)	LAEq - Nig 21 dB(A)																			
Parking	PLot	LAEq - Day			53.3	79.6	418.8	0.0	0.0	0	70.81	-48.0	0.6	-0.5	-0.6	0.00	0.0	0.1	31.1	0.0	-1.6	0.0	29.4
Parking	PLot	LAEq - Nig			53.3	79.6	418.8	0.0	0.0	0	70.81	-48.0	0.6	-0.5	-0.6	0.00	0.0	0.1	31.1	0.0	-13.5	0.0	17.5

MWA Environmental

1

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li	Rw	L'w	Lw	l or A	Kl	KT	DO	S	Adiv	Agr	Abar	Aatm	Amisc	ADI	dLrefl	Ls	Cmet	dLw	ZR	Lr
			dB(A)	dB	dB(A)	dB(A)	m,m²	dB	dB	dB	m	dB	dB	dB	dB	dB	dB	dB(A)	dB(A)	dB	dB	dB	dB(A)
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	82.46	-49.3	1.3	-21.6	-0.3	0.00	0.0	0.0	5.1	0.0	-0.8	0.0	4.3
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	82.46	-49.3	1.3	-21.6	-0.3	0.00	0.0	0.0	5.1	0.0	-10.3	0.0	-5.3
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	82.33	-49.3	1.3	-21.6	-0.3	0.00	0.0	0.0	5.1	0.0	-0.8	0.0	4.3
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	82.33	-49.3	1.3	-21.6	-0.3	0.00	0.0	0.0	5.1	0.0	-10.3	0.0	-5.3
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	82.53	-49.3	1.3	-21.5	-0.3	0.00	0.0	0.0	5.2	0.0	-0.8	0.0	4.4
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	82.53	-49.3	1.3	-21.5	-0.3	0.00	0.0	0.0	5.2	0.0	-10.3	0.0	-5.2
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	82.55	-49.3	1.3	-21.6	-0.3	0.00	0.0	0.0	3.1	0.0	-0.8	0.0	2.3
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	82.55	-49.3	1.3	-21.6	-0.3	0.00	0.0	0.0	3.1	0.0	-10.3	0.0	-7.2
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	83.04	-49.4	1.3	-21.2	-0.2	0.00	0.0	2.4	2.9	0.0	-0.8	0.0	2.1
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	83.04	-49.4	1.3	-21.2	-0.2	0.00	0.0	2.4	2.9	0.0	-10.3	0.0	-7.4
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	67.21	-47.5	0.2	-0.1	-0.6	0.00	0.0	0.0	19.0	0.0	12.6	0.0	31.7
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	67.21	-47.5	0.2	-0.1	-0.6	0.00	0.0	0.0	19.0	0.0	-1.1	0.0	17.9
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	65.37	-47.3	1.0	0.0	-1.5	0.00	0.0	0.0	28.1	0.0	-7.4	0.0	25.7
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	65.37	-47.3	1.0	0.0	-1.5	0.00	0.0	0.0	28.1	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	77.85	-48.8	1.3	-4.0	-0.7	0.00	0.0	0.0	22.7	0.0	-0.8	0.0	22.0
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	77.85	-48.8	1.3	-4.0	-0.7	0.00	0.0	0.0	22.7	0.0	-10.3	0.0	12.4
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	76.36	-48.6	0.2	-9.3	-0.7	0.00	0.0	1.9	25.3	0.0	-1.2	0.0	24.0
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	76.36	-48.6	0.2	-9.3	-0.7	0.00	0.0	1.9	25.3	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	67.53	-47.6	1.1	-10.8	-0.4	0.00	0.0	4.6	34.9	0.0	-1.2	0.0	33.7
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	67.53	-47.6	1.1	-10.8	-0.4	0.00	0.0	4.6	34.9	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	63.21	-47.0	1.1	-10.6	-0.4	0.00	0.0	4.1	40.7	0.0	-1.2	0.0	39.4
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	63.21	-47.0	1.1	-10.6	-0.4	0.00	0.0	4.1	40.7	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	59.83	-46.5	0.9	-0.3	-0.5	0.00	0.0	0.0	23.3	0.0	-7.4	0.0	15.9
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	59.83	-46.5	0.9	-0.3	-0.5	0.00	0.0	0.0	23.3	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	56.42	-46.0	0.8	0.0	-0.4	0.00	0.0	0.0	53.3	0.0	-28.2	0.0	30.1
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	56.42	-46.0	0.8	0.0	-0.4	0.00	0.0	0.0	53.3	0.0			
Receiver R2 FI GF Lmax 42 dB(A) LAeq - Day 40 dB(A) LAeq - Nig 21 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	70.26	-47.9	0.7	-0.4	-0.6	0.00	0.0	0.0	31.3	0.0	-1.6	0.0	29.7
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	70.26	-47.9	0.7	-0.4	-0.6	0.00	0.0	0.0	31.3	0.0	-13.5	0.0	17.8
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	82.62	-49.3	0.1	-21.0	-0.3	0.00	0.0	0.0	4.5	0.0	-0.8	0.0	3.7
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	82.62	-49.3	0.1	-21.0	-0.3	0.00	0.0	0.0	4.5	0.0	-10.3	0.0	-5.8
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	82.76	-49.3	0.1	-21.0	-0.3	0.00	0.0	0.0	4.5	0.0	-0.8	0.0	3.7
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	82.76	-49.3	0.1	-21.0	-0.3	0.00	0.0	0.0	4.5	0.0	-10.3	0.0	-5.8

MWA Environmental

2

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	l or A m,m²	Kl dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	82.83	-49.4	0.1	-20.9	-0.3	0.00	0.0	0.0	4.6	0.0	-0.8	0.0	3.8
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	82.83	-49.4	0.1	-20.9	-0.3	0.00	0.0	0.0	4.6	0.0	-10.3	0.0	-5.7
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	82.60	-49.3	0.1	-21.0	-0.3	0.00	0.0	0.0	2.6	0.0	-0.8	0.0	1.8
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	82.60	-49.3	0.1	-21.0	-0.3	0.00	0.0	0.0	2.6	0.0	-10.3	0.0	-7.8
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	83.14	-49.4	0.1	-20.5	-0.3	0.00	0.0	2.3	2.2	0.0	-0.8	0.0	1.4
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	83.14	-49.4	0.1	-20.5	-0.3	0.00	0.0	2.3	2.2	0.0	-10.3	0.0	-8.1
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	66.63	-47.5	-0.1	-0.1	-0.6	0.00	0.0	0.0	18.8	0.0	12.6	0.0	31.4
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	66.63	-47.5	-0.1	-0.1	-0.6	0.00	0.0	0.0	18.8	0.0	-1.1	0.0	17.7
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	63.34	-47.0	0.7	0.0	-1.5	0.00	0.0	0.0	28.2	0.0	-7.4	0.0	25.8
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	63.34	-47.0	0.7	0.0	-1.5	0.00	0.0	0.0	28.2	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	76.40	-48.7	0.5	-4.5	-0.6	0.00	0.0	0.0	21.8	0.0	-0.8	0.0	21.0
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	76.40	-48.7	0.5	-4.5	-0.6	0.00	0.0	0.0	21.8	0.0	-10.3	0.0	11.5
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	71.43	-48.1	-0.1	-7.6	-0.7	0.00	0.0	1.1	26.5	0.0	-1.2	0.0	25.2
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	71.43	-48.1	-0.1	-7.6	-0.7	0.00	0.0	1.1	26.5	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	63.87	-47.1	0.8	-12.1	-0.4	0.00	0.0	3.4	32.6	0.0	-1.2	0.0	31.3
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	63.87	-47.1	0.8	-12.1	-0.4	0.00	0.0	3.4	32.6	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	62.20	-46.9	0.7	-12.1	-0.4	0.00	0.0	3.7	38.4	0.0	-1.2	0.0	37.2
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	62.20	-46.9	0.7	-12.1	-0.4	0.00	0.0	3.7	38.4	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	59.33	-46.5	0.4	-0.1	-0.5	0.00	0.0	0.0	23.1	0.0	-7.4	0.0	15.7
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	59.33	-46.5	0.4	-0.1	-0.5	0.00	0.0	0.0	23.1	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	56.65	-46.1	0.4	0.0	-0.5	0.00	0.0	0.0	52.8	0.0	-28.2	0.0	29.6
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	56.65	-46.1	0.4	0.0	-0.5	0.00	0.0	0.0	52.8	0.0			
Receiver R2 F I F 1 Lmax 42 dB(A) LAeq - Day 42 dB(A) LAeq - Nig 21 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	70.38	-47.9	0.6	-0.6	-0.6	0.00	0.0	0.0	31.1	0.0	-1.6	0.0	29.4
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	70.38	-47.9	0.6	-0.6	-0.6	0.00	0.0	0.0	31.1	0.0	-13.5	0.0	17.5
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	82.60	-49.3	1.3	-21.6	-0.3	0.00	0.0	0.0	5.1	0.0	-0.8	0.0	4.3
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	82.60	-49.3	1.3	-21.6	-0.3	0.00	0.0	0.0	5.1	0.0	-10.3	0.0	-5.3
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	82.74	-49.3	1.3	-21.6	-0.3	0.00	0.0	0.0	5.0	0.0	-0.8	0.0	4.2
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	82.74	-49.3	1.3	-21.6	-0.3	0.00	0.0	0.0	5.0	0.0	-10.3	0.0	-5.3
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	82.81	-49.4	1.3	-21.5	-0.3	0.00	0.0	0.0	5.1	0.0	-0.8	0.0	4.4
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	82.81	-49.4	1.3	-21.5	-0.3	0.00	0.0	0.0	5.1	0.0	-10.3	0.0	-5.2
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	82.57	-49.3	1.3	-21.6	-0.3	0.00	0.0	0.0	3.1	0.0	-0.8	0.0	2.3
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	82.57	-49.3	1.3	-21.6	-0.3	0.00	0.0	0.0	3.1	0.0	-10.3	0.0	-7.2

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	I or A m,m²	KI dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	83.11	-49.4	1.3	-21.2	-0.2	0.00	0.0	2.4	2.9	0.0	-0.8	0.0	2.1
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	83.11	-49.4	1.3	-21.2	-0.2	0.00	0.0	2.4	2.9	0.0	-10.3	0.0	-7.4
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	66.74	-47.5	0.2	-0.1	-0.6	0.00	0.0	0.0	19.1	0.0	12.6	0.0	31.7
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	66.74	-47.5	0.2	-0.1	-0.6	0.00	0.0	0.0	19.1	0.0	-1.1	0.0	18.0
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	63.41	-47.0	1.0	0.0	-1.5	0.00	0.0	0.0	28.5	0.0	-7.4	0.0	26.1
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	63.41	-47.0	1.0	0.0	-1.5	0.00	0.0	0.0	28.5	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	76.24	-48.6	1.3	-4.0	-0.7	0.00	0.0	0.0	23.0	0.0	-0.8	0.0	22.2
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	76.24	-48.6	1.3	-4.0	-0.7	0.00	0.0	0.0	23.0	0.0	-10.3	0.0	12.6
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	71.56	-48.1	0.1	-7.5	-0.7	0.00	0.0	1.2	26.9	0.0	-1.2	0.0	25.6
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	71.56	-48.1	0.1	-7.5	-0.7	0.00	0.0	1.2	26.9	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	63.83	-47.1	1.1	-10.6	-0.4	0.00	0.0	4.1	35.2	0.0	-1.2	0.0	33.9
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	63.83	-47.1	1.1	-10.6	-0.4	0.00	0.0	4.1	35.2	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	62.15	-46.9	1.1	-10.5	-0.4	0.00	0.0	4.5	41.2	0.0	-1.2	0.0	40.0
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	62.15	-46.9	1.1	-10.5	-0.4	0.00	0.0	4.5	41.2	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	59.38	-46.5	0.9	-0.3	-0.5	0.00	0.0	0.0	23.4	0.0	-7.4	0.0	16.0
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	59.38	-46.5	0.9	-0.3	-0.5	0.00	0.0	0.0	23.4	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	56.70	-46.1	0.8	0.0	-0.4	0.00	0.0	0.0	53.3	0.0	-28.2	0.0	30.1
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	56.70	-46.1	0.8	0.0	-0.4	0.00	0.0	0.0	53.3	0.0			
Receiver R3 FI GF Lmax 42 dB(A) LAeq - Day 40 dB(A) LAeq - Nig 21 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	71.17	-48.0	0.7	-0.4	-0.6	0.00	0.0	0.0	31.2	0.0	-1.6	0.0	29.6
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	71.17	-48.0	0.7	-0.4	-0.6	0.00	0.0	0.0	31.2	0.0	-13.5	0.0	17.7
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	83.83	-49.5	0.1	-21.0	-0.3	0.00	0.0	0.0	4.4	0.0	-0.8	0.0	3.6
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	83.83	-49.5	0.1	-21.0	-0.3	0.00	0.0	0.0	4.4	0.0	-10.3	0.0	-6.0
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	84.20	-49.5	0.1	-21.0	-0.3	0.00	0.0	0.0	4.3	0.0	-0.8	0.0	3.5
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	84.20	-49.5	0.1	-21.0	-0.3	0.00	0.0	0.0	4.3	0.0	-10.3	0.0	-6.0
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	84.16	-49.5	0.1	-20.9	-0.3	0.00	0.0	0.0	4.5	0.0	-0.8	0.0	3.7
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	84.16	-49.5	0.1	-20.9	-0.3	0.00	0.0	0.0	4.5	0.0	-10.3	0.0	-5.9
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	83.71	-49.4	0.1	-21.0	-0.3	0.00	0.0	0.0	2.4	0.0	-0.8	0.0	1.6
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	83.71	-49.4	0.1	-21.0	-0.3	0.00	0.0	0.0	2.4	0.0	-10.3	0.0	-7.9
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	84.29	-49.5	0.1	-20.6	-0.3	0.00	0.0	2.3	2.1	0.0	-0.8	0.0	1.3
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	84.29	-49.5	0.1	-20.6	-0.3	0.00	0.0	2.3	2.1	0.0	-10.3	0.0	-8.2
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	67.65	-47.6	-0.1	-0.1	-0.7	0.00	0.0	0.0	18.7	0.0	12.6	0.0	31.3
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	67.65	-47.6	-0.1	-0.1	-0.7	0.00	0.0	0.0	18.7	0.0	-1.1	0.0	17.6

MWA Environmental

4

26062 Carina
Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	I or A m,m²	KI dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)	
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	63.08	-47.0	0.7	0.0	-1.5	0.00	0.0	0.0	28.2	0.0	-7.4	0.0	25.8	
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	63.08	-47.0	0.7	0.0	-1.5	0.00	0.0	0.0	28.2	0.0				
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	76.23	-48.6	0.5	-4.5	-0.6	0.00	0.0	0.0	21.8	0.0	-0.8	0.0	21.0	
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	76.23	-48.6	0.5	-4.5	-0.6	0.00	0.0	0.0	21.8	0.0	-10.3	0.0	11.5	
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	68.46	-47.7	-0.2	-5.5	-0.7	0.00	0.0	0.5	28.2	0.0	-1.2	0.0	27.0	
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	68.46	-47.7	-0.2	-5.5	-0.7	0.00	0.0	0.5	28.2	0.0				
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	62.02	-46.8	0.7	-12.2	-0.4	0.00	0.0	3.7	33.1	0.0	-1.2	0.0	31.8	
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	62.02	-46.8	0.7	-12.2	-0.4	0.00	0.0	3.7	33.1	0.0				
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	62.73	-46.9	0.7	-12.3	-0.4	0.00	0.0	3.5	38.0	0.0	-1.2	0.0	36.7	
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	62.73	-46.9	0.7	-12.3	-0.4	0.00	0.0	3.5	38.0	0.0				
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	60.49	-46.6	0.4	-0.1	-0.5	0.00	0.0	0.0	23.0	0.0	-7.4	0.0	15.5	
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	60.49	-46.6	0.4	-0.1	-0.5	0.00	0.0	0.0	23.0	0.0				
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	58.46	-46.3	0.4	0.0	-0.5	0.00	0.0	0.0	52.5	0.0	-28.2	0.0	29.3	
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	58.46	-46.3	0.4	0.0	-0.5	0.00	0.0	0.0	52.5	0.0				
Receiver R3 FI F 1 Lmax 42 dB(A) LAeq - Day 42 dB(A) LAeq - Nig 21 dB(A)																								
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	71.29	-48.1	0.7	-0.5	-0.6	0.00	0.0	0.0	31.0	0.0	-1.6	0.0	29.4	
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	71.29	-48.1	0.7	-0.5	-0.6	0.00	0.0	0.0	31.0	0.0	-13.5	0.0	17.5	
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	83.80	-49.5	1.3	-21.6	-0.3	0.00	0.0	0.0	4.9	0.0	-0.8	0.0	4.1	
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	83.80	-49.5	1.3	-21.6	-0.3	0.00	0.0	0.0	4.9	0.0	-10.3	0.0	-5.4	
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	84.16	-49.5	1.3	-21.7	-0.3	0.00	0.0	0.0	4.8	0.0	-0.8	0.0	4.0	
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	84.16	-49.5	1.3	-21.7	-0.3	0.00	0.0	0.0	4.8	0.0	-10.3	0.0	-5.5	
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	84.13	-49.5	1.3	-21.5	-0.3	0.00	0.0	0.0	5.0	0.0	-0.8	0.0	4.2	
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	84.13	-49.5	1.3	-21.5	-0.3	0.00	0.0	0.0	5.0	0.0	-10.3	0.0	-5.3	
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	83.68	-49.4	1.3	-21.6	-0.3	0.00	0.0	0.0	3.0	0.0	-0.8	0.0	2.2	
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	83.68	-49.4	1.3	-21.6	-0.3	0.00	0.0	0.0	3.0	0.0	-10.3	0.0	-7.4	
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	84.26	-49.5	1.3	-21.2	-0.3	0.00	0.0	2.4	2.8	0.0	-0.8	0.0	2.0	
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	84.26	-49.5	1.3	-21.2	-0.3	0.00	0.0	2.4	2.8	0.0	-10.3	0.0	-7.6	
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	67.77	-47.6	0.2	-0.1	-0.6	0.00	0.0	0.0	19.0	0.0	12.6	0.0	31.6	
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	67.77	-47.6	0.2	-0.1	-0.6	0.00	0.0	0.0	19.0	0.0	-1.1	0.0	17.9	
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	63.13	-47.0	1.0	0.0	-1.5	0.00	0.0	0.0	28.5	0.0	-7.4	0.0	26.1	
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	63.13	-47.0	1.0	0.0	-1.5	0.00	0.0	0.0	28.5	0.0				
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	76.07	-48.6	1.3	-4.2	-0.7	0.00	0.0	0.0	22.9	0.0	-0.8	0.0	22.1	
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	76.07	-48.6	1.3	-4.2	-0.7	0.00	0.0	0.0	22.9	0.0	-10.3	0.0	12.5	

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	l or A m,m²	Kl dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	68.56	-47.7	0.0	-5.4	-0.7	0.00	0.0	0.6	28.6	0.0	-1.2	0.0	27.4
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	68.56	-47.7	0.0	-5.4	-0.7	0.00	0.0	0.6	28.6	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	61.98	-46.8	1.1	-10.6	-0.4	0.00	0.0	4.4	35.7	0.0	-1.2	0.0	34.5
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	61.98	-46.8	1.1	-10.6	-0.4	0.00	0.0	4.4	35.7	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	62.67	-46.9	1.1	-10.7	-0.4	0.00	0.0	4.2	40.7	0.0	-1.2	0.0	39.5
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	62.67	-46.9	1.1	-10.7	-0.4	0.00	0.0	4.2	40.7	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	60.53	-46.6	0.9	-0.3	-0.5	0.00	0.0	0.0	23.2	0.0	-7.4	0.0	15.8
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	60.53	-46.6	0.9	-0.3	-0.5	0.00	0.0	0.0	23.2	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	58.50	-46.3	0.8	0.0	-0.4	0.00	0.0	0.0	53.0	0.0	-28.2	0.0	29.8
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	58.50	-46.3	0.8	0.0	-0.4	0.00	0.0	0.0	53.0	0.0			
Receiver R4 FI GF Lmax 42 dB(A) LAeq - Day 40 dB(A) LAeq - Nig 21 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	74.06	-48.4	0.8	-0.8	-0.6	0.00	0.0	0.0	30.6	0.0	-1.6	0.0	29.0
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	74.06	-48.4	0.8	-0.8	-0.6	0.00	0.0	0.0	30.6	0.0	-13.5	0.0	17.0
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	86.78	-49.8	0.1	-21.1	-0.3	0.00	0.0	0.0	4.0	0.0	-0.8	0.0	3.3
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	86.78	-49.8	0.1	-21.1	-0.3	0.00	0.0	0.0	4.0	0.0	-10.3	0.0	-6.3
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	87.41	-49.8	0.2	-21.1	-0.3	0.00	0.0	0.0	4.0	0.0	-0.8	0.0	3.2
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	87.41	-49.8	0.2	-21.1	-0.3	0.00	0.0	0.0	4.0	0.0	-10.3	0.0	-6.4
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	87.24	-49.8	0.2	-21.0	-0.3	0.00	0.0	0.0	4.1	0.0	-0.8	0.0	3.3
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	87.24	-49.8	0.2	-21.0	-0.3	0.00	0.0	0.0	4.1	0.0	-10.3	0.0	-6.2
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	86.54	-49.7	0.1	-21.0	-0.3	0.00	0.0	0.0	2.1	0.0	-0.8	0.0	1.3
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	86.54	-49.7	0.1	-21.0	-0.3	0.00	0.0	0.0	2.1	0.0	-10.3	0.0	-8.2
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	87.16	-49.8	0.1	-20.6	-0.3	0.00	0.0	2.3	1.8	0.0	-0.8	0.0	1.0
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	87.16	-49.8	0.1	-20.6	-0.3	0.00	0.0	2.3	1.8	0.0	-10.3	0.0	-8.5
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	70.83	-48.0	0.0	-0.2	-0.7	0.00	0.0	0.0	18.2	0.0	12.6	0.0	30.9
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	70.83	-48.0	0.0	-0.2	-0.7	0.00	0.0	0.0	18.2	0.0	-1.1	0.0	17.2
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	64.65	-47.2	0.7	-8.5	-1.0	0.00	0.0	0.0	20.1	0.0	-7.4	0.0	17.7
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	64.65	-47.2	0.7	-8.5	-1.0	0.00	0.0	0.0	20.1	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	77.62	-48.8	0.5	-4.1	-0.5	0.00	0.0	0.0	22.0	0.0	-0.8	0.0	21.2
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	77.62	-48.8	0.5	-4.1	-0.5	0.00	0.0	0.0	22.0	0.0	-10.3	0.0	11.7
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	66.38	-47.4	-0.4	-2.4	-0.7	0.00	0.0	0.5	31.2	0.0	-1.2	0.0	30.0
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	66.38	-47.4	-0.4	-2.4	-0.7	0.00	0.0	0.5	31.2	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	61.66	-46.8	0.7	-12.4	-0.4	0.00	0.0	3.2	32.3	0.0	-1.2	0.0	31.1
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	61.66	-46.8	0.7	-12.4	-0.4	0.00	0.0	3.2	32.3	0.0			

MWA Environmental

6

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	l or A m,m²	Kl dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	65.28	-47.3	0.8	-12.7	-0.4	0.00	0.0	3.5	37.4	0.0	-1.2	0.0	36.1
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	65.28	-47.3	0.8	-12.7	-0.4	0.00	0.0	3.5	37.4	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	63.91	-47.1	0.4	-0.1	-0.5	0.00	0.0	0.0	22.5	0.0	-7.4	0.0	15.1
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	63.91	-47.1	0.4	-0.1	-0.5	0.00	0.0	0.0	22.5	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	62.68	-46.9	0.4	0.0	-0.5	0.00	0.0	0.0	51.9	0.0	-28.2	0.0	28.7
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	62.68	-46.9	0.4	0.0	-0.5	0.00	0.0	0.0	51.9	0.0			
Receiver R4 FI F 1 Lmax 42 dB(A) LAeq - Day 41 dB(A) LAeq - Nig 21 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	74.14	-48.4	0.7	-0.9	-0.6	0.00	0.0	0.0	30.3	0.0	-1.6	0.0	28.7
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	74.14	-48.4	0.7	-0.9	-0.6	0.00	0.0	0.0	30.3	0.0	-13.5	0.0	16.8
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	86.74	-49.8	1.3	-21.7	-0.3	0.00	0.0	0.0	4.6	0.0	-0.8	0.0	3.8
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	86.74	-49.8	1.3	-21.7	-0.3	0.00	0.0	0.0	4.6	0.0	-10.3	0.0	-5.8
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	87.37	-49.8	1.3	-21.7	-0.3	0.00	0.0	0.0	4.5	0.0	-0.8	0.0	3.7
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	87.37	-49.8	1.3	-21.7	-0.3	0.00	0.0	0.0	4.5	0.0	-10.3	0.0	-5.9
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	87.20	-49.8	1.3	-21.6	-0.3	0.00	0.0	0.0	4.6	0.0	-0.8	0.0	3.8
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	87.20	-49.8	1.3	-21.6	-0.3	0.00	0.0	0.0	4.6	0.0	-10.3	0.0	-5.7
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	86.49	-49.7	1.3	-21.6	-0.3	0.00	0.0	0.0	2.6	0.0	-0.8	0.0	1.8
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	86.49	-49.7	1.3	-21.6	-0.3	0.00	0.0	0.0	2.6	0.0	-10.3	0.0	-7.7
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	87.11	-49.8	1.3	-21.2	-0.3	0.00	0.0	2.4	2.5	0.0	-0.8	0.0	1.7
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	87.11	-49.8	1.3	-21.2	-0.3	0.00	0.0	2.4	2.5	0.0	-10.3	0.0	-7.9
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	70.92	-48.0	0.2	-0.2	-0.6	0.00	0.0	0.0	18.5	0.0	12.6	0.0	31.1
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	70.92	-48.0	0.2	-0.2	-0.6	0.00	0.0	0.0	18.5	0.0	-1.1	0.0	17.4
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	64.70	-47.2	1.0	-8.3	-0.9	0.00	0.0	0.0	20.6	0.0	-7.4	0.0	18.2
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	64.70	-47.2	1.0	-8.3	-0.9	0.00	0.0	0.0	20.6	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	77.44	-48.8	1.3	-4.7	-0.5	0.00	0.0	0.0	22.3	0.0	-0.8	0.0	21.5
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	77.44	-48.8	1.3	-4.7	-0.5	0.00	0.0	0.0	22.3	0.0	-10.3	0.0	11.9
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	66.46	-47.4	-0.3	-2.3	-0.7	0.00	0.0	0.5	31.5	0.0	-1.2	0.0	30.3
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	66.46	-47.4	-0.3	-2.3	-0.7	0.00	0.0	0.5	31.5	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	61.58	-46.8	1.1	-10.9	-0.4	0.00	0.0	3.9	34.9	0.0	-1.2	0.0	33.7
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	61.58	-46.8	1.1	-10.9	-0.4	0.00	0.0	3.9	34.9	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	65.22	-47.3	1.1	-11.2	-0.4	0.00	0.0	4.3	40.0	0.0	-1.2	0.0	38.7
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	65.22	-47.3	1.1	-11.2	-0.4	0.00	0.0	4.3	40.0	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	63.93	-47.1	0.9	-0.2	-0.5	0.00	0.0	0.0	22.8	0.0	-7.4	0.0	15.4
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	63.93	-47.1	0.9	-0.2	-0.5	0.00	0.0	0.0	22.8	0.0			

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li	Rw	L'w	Lw	I or A	KI	KT	DO	S	Adiv	Agr	Abar	Aatm	Amisc	ADI	dLrefl	Ls	Cmet	dLw	ZR	Lr	
			dB(A)	dB	dB(A)	dB(A)	m,m²	dB	dB	dB	m	dB	dB	dB	dB	dB	dB	dB(A)	dB(A)	dB	dB	dB	dB(A)	
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	62.70	-46.9	0.8	0.0	-0.5	0.00	0.0	0.0	52.4	0.0	-28.2	0.0	29.2	
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	62.70	-46.9	0.8	0.0	-0.5	0.00	0.0	0.0	52.4	0.0				
Receiver R5 FI GF Lmax 41 dB(A) LAeq - Day 39 dB(A) LAeq - Nig 19 dB(A)																								
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	80.24	-49.1	0.9	-2.0	-0.6	0.00	0.0	0.0	28.8	0.0	-1.6	0.0	27.2	
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	80.24	-49.1	0.9	-2.0	-0.6	0.00	0.0	0.0	28.8	0.0	-13.5	0.0	15.3	
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	92.65	-50.3	0.2	-21.9	-0.4	0.00	0.0	0.0	2.6	0.0	-0.8	0.0	1.8	
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	92.65	-50.3	0.2	-21.9	-0.4	0.00	0.0	0.0	2.6	0.0	-10.3	0.0	-7.7	
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	93.57	-50.4	0.2	-21.2	-0.3	0.00	0.0	0.0	3.3	0.0	-0.8	0.0	2.5	
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	93.57	-50.4	0.2	-21.2	-0.3	0.00	0.0	0.0	3.3	0.0	-10.3	0.0	-7.0	
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	93.25	-50.4	0.2	-21.0	-0.3	0.00	0.0	0.0	3.5	0.0	-0.8	0.0	2.7	
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	93.25	-50.4	0.2	-21.0	-0.3	0.00	0.0	0.0	3.5	0.0	-10.3	0.0	-6.8	
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	92.27	-50.3	0.2	-21.9	-0.4	0.00	0.0	0.0	0.7	0.0	-0.8	0.0	-0.1	
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	92.27	-50.3	0.2	-21.9	-0.4	0.00	0.0	0.0	0.7	0.0	-10.3	0.0	-9.7	
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	92.92	-50.4	0.2	-21.5	-0.3	0.00	0.0	2.0	0.0	0.0	-0.8	0.0	-0.8	
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	92.92	-50.4	0.2	-21.5	-0.3	0.00	0.0	2.0	0.0	0.0	-10.3	0.0	-10.3	
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	77.47	-48.8	0.1	-1.3	-0.7	0.00	0.0	0.0	16.5	0.0	12.6	0.0	29.1	
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	77.47	-48.8	0.1	-1.3	-0.7	0.00	0.0	0.0	16.5	0.0	-1.1	0.0	15.4	
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	69.60	-47.8	0.7	-15.9	-0.8	0.00	0.0	0.3	12.5	0.0	-7.4	0.0	10.1	
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	69.60	-47.8	0.7	-15.9	-0.8	0.00	0.0	0.3	12.5	0.0				
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	81.86	-49.3	0.5	-3.8	-0.5	0.00	0.0	0.0	21.9	0.0	-0.8	0.0	21.1	
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	81.86	-49.3	0.5	-3.8	-0.5	0.00	0.0	0.0	21.9	0.0	-10.3	0.0	11.6	
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	66.81	-47.5	-0.7	-5.3	-0.6	0.00	0.0	3.1	30.8	0.0	-1.2	0.0	29.6	
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	66.81	-47.5	-0.7	-5.3	-0.6	0.00	0.0	3.1	30.8	0.0				
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	64.47	-47.2	0.7	-13.0	-0.4	0.00	0.0	3.3	31.5	0.0	-1.2	0.0	30.3	
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	64.47	-47.2	0.7	-13.0	-0.4	0.00	0.0	3.3	31.5	0.0				
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	71.36	-48.1	0.8	-12.8	-0.4	0.00	0.0	3.9	36.9	0.0	-1.2	0.0	35.7	
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	71.36	-48.1	0.8	-12.8	-0.4	0.00	0.0	3.9	36.9	0.0				
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	70.98	-48.0	0.5	-0.1	-0.6	0.00	0.0	0.0	21.6	0.0	-7.4	0.0	14.2	
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	70.98	-48.0	0.5	-0.1	-0.6	0.00	0.0	0.0	21.6	0.0				
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	70.64	-48.0	0.5	0.0	-0.6	0.00	0.0	0.0	50.9	0.0	-28.2	0.0	27.7	
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	70.64	-48.0	0.5	0.0	-0.6	0.00	0.0	0.0	50.9	0.0				
Receiver R5 FI F 1 Lmax 41 dB(A) LAeq - Day 41 dB(A) LAeq - Nig 19 dB(A)																								

MWA Environmental

8

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li	Rw	L'w	Lw	l or A	Kl	KT	DO	S	Adiv	Agr	Abar	Aatm	Amisc	ADI	dLrefl	Ls	Cmet	dLw	ZR	Lr	
			dB(A)	dB	dB(A)	dB(A)	m,m ²	dB	dB	dB	m	dB	dB	dB	dB	dB	dB	dB(A)	dB(A)	dB	dB	dB	dB(A)	
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	80.28	-49.1	0.7	-2.1	-0.7	0.00	0.0	0.0	28.5	0.0	-1.6	0.0	26.9	
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	80.28	-49.1	0.7	-2.1	-0.7	0.00	0.0	0.0	28.5	0.0	-13.5	0.0	15.0	
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	92.59	-50.3	1.3	-21.7	-0.3	0.00	0.0	0.0	3.9	0.0	-0.8	0.0	3.2	
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	92.59	-50.3	1.3	-21.7	-0.3	0.00	0.0	0.0	3.9	0.0	-10.3	0.0	-6.4	
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	93.51	-50.4	1.3	-21.7	-0.3	0.00	0.0	0.0	3.8	0.0	-0.8	0.0	3.0	
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	93.51	-50.4	1.3	-21.7	-0.3	0.00	0.0	0.0	3.8	0.0	-10.3	0.0	-6.5	
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	93.20	-50.4	1.3	-21.6	-0.3	0.00	0.0	0.0	4.0	0.0	-0.8	0.0	3.2	
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	93.20	-50.4	1.3	-21.6	-0.3	0.00	0.0	0.0	4.0	0.0	-10.3	0.0	-6.3	
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	92.21	-50.3	1.3	-21.7	-0.3	0.00	0.0	0.0	2.0	0.0	-0.8	0.0	1.2	
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	92.21	-50.3	1.3	-21.7	-0.3	0.00	0.0	0.0	2.0	0.0	-10.3	0.0	-8.3	
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	92.86	-50.3	1.3	-21.2	-0.3	0.00	0.0	2.0	1.4	0.0	-0.8	0.0	0.7	
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	92.86	-50.3	1.3	-21.2	-0.3	0.00	0.0	2.0	1.4	0.0	-10.3	0.0	-8.9	
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	77.54	-48.8	0.3	-1.3	-0.7	0.00	0.0	0.0	16.7	0.0	12.6	0.0	29.3	
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	77.54	-48.8	0.3	-1.3	-0.7	0.00	0.0	0.0	16.7	0.0	-1.1	0.0	15.6	
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	69.62	-47.8	0.9	-15.6	-0.7	0.00	0.0	0.3	13.0	0.0	-7.4	0.0	10.6	
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	69.62	-47.8	0.9	-15.6	-0.7	0.00	0.0	0.3	13.0	0.0				
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	81.68	-49.2	1.3	-4.8	-0.6	0.00	0.0	0.0	21.8	0.0	-0.8	0.0	21.0	
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	81.68	-49.2	1.3	-4.8	-0.6	0.00	0.0	0.0	21.8	0.0	-10.3	0.0	11.4	
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	66.88	-47.5	-0.7	-4.1	-0.6	0.00	0.0	2.8	31.7	0.0	-1.2	0.0	30.4	
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	66.88	-47.5	-0.7	-4.1	-0.6	0.00	0.0	2.8	31.7	0.0				
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	64.35	-47.2	1.1	-11.6	-0.4	0.00	0.0	3.9	33.8	0.0	-1.2	0.0	32.6	
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	64.35	-47.2	1.1	-11.6	-0.4	0.00	0.0	3.9	33.8	0.0				
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	71.29	-48.1	1.1	-11.3	-0.4	0.00	0.0	4.7	39.4	0.0	-1.2	0.0	38.2	
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	71.29	-48.1	1.1	-11.3	-0.4	0.00	0.0	4.7	39.4	0.0				
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	70.98	-48.0	0.9	-0.2	-0.5	0.00	0.0	0.0	21.9	0.0	-7.4	0.0	14.4	
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	70.98	-48.0	0.9	-0.2	-0.5	0.00	0.0	0.0	21.9	0.0				
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	70.65	-48.0	0.8	0.0	-0.5	0.00	0.0	0.0	51.3	0.0	-28.2	0.0	28.1	
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	70.65	-48.0	0.8	0.0	-0.5	0.00	0.0	0.0	51.3	0.0				
Receiver R6 FI GF Lmax 33 dB(A) LAeq - Day 28 dB(A) LAeq - Nig 15 dB(A)																								
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	153.20	-54.7	-0.7	-0.3	-1.1	0.00	0.0	0.0	22.7	0.0	-1.6	0.0	21.1	
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	153.20	-54.7	-0.7	-0.3	-1.1	0.00	0.0	0.0	22.7	0.0	-13.5	0.0	9.2	
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	142.59	-54.1	-1.9	-9.6	-0.3	0.00	0.0	5.9	15.0	0.0	-0.8	0.0	14.2	
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	142.59	-54.1	-1.9	-9.6	-0.3	0.00	0.0	5.9	15.0	0.0	-10.3	0.0	4.7	

MWA Environmental

9

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	l or A m,m²	Kl dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	142.80	-54.1	-1.9	-9.7	-0.3	0.00	0.0	5.9	15.0	0.0	-0.8	0.0	14.2
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	142.80	-54.1	-1.9	-9.7	-0.3	0.00	0.0	5.9	15.0	0.0	-10.3	0.0	4.6
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	142.56	-54.1	-1.9	-9.9	-0.3	0.00	0.0	6.2	15.0	0.0	-0.8	0.0	14.2
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	142.56	-54.1	-1.9	-9.9	-0.3	0.00	0.0	6.2	15.0	0.0	-10.3	0.0	4.6
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	142.49	-54.1	-1.9	-9.7	-0.3	0.00	0.0	6.0	13.1	0.0	-0.8	0.0	12.3
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	142.49	-54.1	-1.9	-9.7	-0.3	0.00	0.0	6.0	13.1	0.0	-10.3	0.0	2.7
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	142.01	-54.0	-1.9	-10.8	-0.3	0.00	0.0	6.5	9.4	0.0	-0.8	0.0	8.6
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	142.01	-54.0	-1.9	-10.8	-0.3	0.00	0.0	6.5	9.4	0.0	-10.3	0.0	-0.9
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	155.11	-54.8	-1.1	-0.1	-1.4	0.00	0.0	0.0	9.8	0.0	12.6	0.0	22.4
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	155.11	-54.8	-1.1	-0.1	-1.4	0.00	0.0	0.0	9.8	0.0	-1.1	0.0	8.7
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	161.55	-55.2	-0.2	0.0	-3.1	0.00	0.0	0.0	17.6	0.0	-7.4	0.0	15.2
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	161.55	-55.2	-0.2	0.0	-3.1	0.00	0.0	0.0	17.6	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	148.78	-54.4	-1.2	-3.3	-1.0	0.00	0.0	0.0	15.0	0.0	-0.8	0.0	14.2
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	148.78	-54.4	-1.2	-3.3	-1.0	0.00	0.0	0.0	15.0	0.0	-10.3	0.0	4.7
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	157.66	-54.9	-1.2	-8.0	-1.3	0.00	0.0	0.0	16.5	0.0	-1.2	0.0	15.2
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	157.66	-54.9	-1.2	-8.0	-1.3	0.00	0.0	0.0	16.5	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	163.32	-55.3	-0.5	-20.4	-0.8	0.00	0.0	3.0	14.0	0.0	-1.2	0.0	12.7
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	163.32	-55.3	-0.5	-20.4	-0.8	0.00	0.0	3.0	14.0	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	162.07	-55.2	-0.6	-19.4	-0.8	0.00	0.0	2.2	19.7	0.0	-1.2	0.0	18.4
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	162.07	-55.2	-0.6	-19.4	-0.8	0.00	0.0	2.2	19.7	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	164.85	-55.3	-0.9	-0.3	-1.3	0.00	0.0	0.0	11.9	0.0	-7.4	0.0	4.5
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	164.85	-55.3	-0.9	-0.3	-1.3	0.00	0.0	0.0	11.9	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	168.66	-55.5	-0.8	-0.5	-1.3	0.00	0.0	0.0	40.9	0.0	-28.2	0.0	17.7
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	168.66	-55.5	-0.8	-0.5	-1.3	0.00	0.0	0.0	40.9	0.0			
Receiver R6 FI F 1 Lmax 33 dB(A) LAeq - Day 28 dB(A) LAeq - Nig 15 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	153.25	-54.7	-0.8	-0.2	-1.2	0.00	0.0	0.0	22.7	0.0	-1.6	0.0	21.1
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	153.25	-54.7	-0.8	-0.2	-1.2	0.00	0.0	0.0	22.7	0.0	-13.5	0.0	9.1
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	142.58	-54.1	-0.3	-11.0	-0.3	0.00	0.0	6.2	15.4	0.0	-0.8	0.0	14.7
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	142.58	-54.1	-0.3	-11.0	-0.3	0.00	0.0	6.2	15.4	0.0	-10.3	0.0	5.1
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	142.78	-54.1	-0.3	-11.1	-0.3	0.00	0.0	6.2	15.4	0.0	-0.8	0.0	14.6
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	142.78	-54.1	-0.3	-11.1	-0.3	0.00	0.0	6.2	15.4	0.0	-10.3	0.0	5.0
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	142.54	-54.1	-0.3	-11.4	-0.3	0.00	0.0	6.4	15.4	0.0	-0.8	0.0	14.6
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	142.54	-54.1	-0.3	-11.4	-0.3	0.00	0.0	6.4	15.4	0.0	-10.3	0.0	5.0

MWA Environmental

10

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	l or A m,m²	Kl dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	142.47	-54.1	-0.3	-11.1	-0.3	0.00	0.0	6.2	13.5	0.0	-0.8	0.0	12.7
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	142.47	-54.1	-0.3	-11.1	-0.3	0.00	0.0	6.2	13.5	0.0	-10.3	0.0	3.1
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	141.99	-54.0	-0.3	-12.3	-0.3	0.00	0.0	6.8	9.9	0.0	-0.8	0.0	9.1
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	141.99	-54.0	-0.3	-12.3	-0.3	0.00	0.0	6.8	9.9	0.0	-10.3	0.0	-0.5
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	155.16	-54.8	-0.6	-0.1	-1.2	0.00	0.0	0.0	10.4	0.0	12.6	0.0	23.0
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	155.16	-54.8	-0.6	-0.1	-1.2	0.00	0.0	0.0	10.4	0.0	-1.1	0.0	9.3
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	161.58	-55.2	0.2	-0.1	-2.8	0.00	0.0	0.0	18.1	0.0	-7.4	0.0	15.7
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	161.58	-55.2	0.2	-0.1	-2.8	0.00	0.0	0.0	18.1	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	148.70	-54.4	0.0	-3.7	-1.2	0.00	0.0	0.0	15.6	0.0	-0.8	0.0	14.8
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	148.70	-54.4	0.0	-3.7	-1.2	0.00	0.0	0.0	15.6	0.0	-10.3	0.0	5.3
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	157.69	-54.9	-0.8	-7.7	-1.2	0.00	0.0	0.0	17.2	0.0	-1.2	0.0	15.9
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	157.69	-54.9	-0.8	-7.7	-1.2	0.00	0.0	0.0	17.2	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	163.30	-55.3	0.2	-20.6	-0.8	0.00	0.0	3.3	14.8	0.0	-1.2	0.0	13.6
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	163.30	-55.3	0.2	-20.6	-0.8	0.00	0.0	3.3	14.8	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	162.06	-55.2	0.2	-19.3	-0.8	0.00	0.0	2.3	20.6	0.0	-1.2	0.0	19.3
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	162.06	-55.2	0.2	-19.3	-0.8	0.00	0.0	2.3	20.6	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	164.87	-55.3	0.1	-2.4	-1.4	0.00	0.0	0.0	10.7	0.0	-7.4	0.0	3.3
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	164.87	-55.3	0.1	-2.4	-1.4	0.00	0.0	0.0	10.7	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	168.67	-55.5	0.2	-2.9	-1.4	0.00	0.0	0.0	39.4	0.0	-28.2	0.0	16.2
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	168.67	-55.5	0.2	-2.9	-1.4	0.00	0.0	0.0	39.4	0.0			
Receiver R7-1 FI GF Lmax 41 dB(A) LAeq - Day 38 dB(A) LAeq - Nig 20 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	78.68	-48.9	-0.5	-0.3	-0.6	0.00	0.0	1.2	30.4	0.0	-1.6	0.0	28.7
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	78.68	-48.9	-0.5	-0.3	-0.6	0.00	0.0	1.2	30.4	0.0	-13.5	0.0	16.8
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	79.30	-49.0	-0.9	-17.9	-0.2	0.00	0.0	5.8	12.9	0.0	-0.8	0.0	12.1
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	79.30	-49.0	-0.9	-17.9	-0.2	0.00	0.0	5.8	12.9	0.0	-10.3	0.0	2.6
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	77.42	-48.8	-0.9	-17.3	-0.2	0.00	0.0	2.0	9.9	0.0	-0.8	0.0	9.1
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	77.42	-48.8	-0.9	-17.3	-0.2	0.00	0.0	2.0	9.9	0.0	-10.3	0.0	-0.5
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	78.37	-48.9	-0.9	-17.1	-0.2	0.00	0.0	1.8	9.7	0.0	-0.8	0.0	8.9
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	78.37	-48.9	-0.9	-17.1	-0.2	0.00	0.0	1.8	9.7	0.0	-10.3	0.0	-0.6
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	80.15	-49.1	-0.9	-18.1	-0.2	0.00	0.0	7.8	12.6	0.0	-0.8	0.0	11.8
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	80.15	-49.1	-0.9	-18.1	-0.2	0.00	0.0	7.8	12.6	0.0	-10.3	0.0	2.2
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	79.99	-49.1	-0.9	-16.5	-0.2	0.00	0.0	7.0	10.4	0.0	-0.8	0.0	9.6
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	79.99	-49.1	-0.9	-16.5	-0.2	0.00	0.0	7.0	10.4	0.0	-10.3	0.0	0.0

MWA Environmental

11

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li	Rw	L'w	Lw	I or A	KI	KT	DO	S	Adiv	Agr	Abar	Aatm	Amisc	ADI	dLrefl	Ls	Cmet	dLw	ZR	Lr	
			dB(A)	dB	dB(A)	dB(A)	m,m²	dB	dB	dB	m	dB	dB	dB	dB	dB	dB	dB(A)	dB(A)	dB	dB	dB	dB(A)	
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	78.68	-48.9	-1.1	-0.1	-0.8	0.00	0.0	1.5	17.7	0.0	12.6	0.0	30.3	
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	78.68	-48.9	-1.1	-0.1	-0.8	0.00	0.0	1.5	17.7	0.0	-1.1	0.0	16.6	
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	85.88	-49.7	0.2	0.0	-2.0	0.00	0.0	2.4	27.0	0.0	-7.4	0.0	24.6	
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	85.88	-49.7	0.2	0.0	-2.0	0.00	0.0	2.4	27.0	0.0				
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	88.83	-50.0	-0.3	-4.0	-0.6	0.00	0.0	0.0	20.1	0.0	-0.8	0.0	19.3	
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	88.83	-50.0	-0.3	-4.0	-0.6	0.00	0.0	0.0	20.1	0.0	-10.3	0.0	9.8	
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	106.62	-51.5	0.7	-18.5	-0.9	0.00	0.0	1.1	12.7	0.0	-1.2	0.0	11.4	
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	106.62	-51.5	0.7	-18.5	-0.9	0.00	0.0	1.1	12.7	0.0				
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	96.23	-50.7	0.2	-9.0	-0.6	0.00	0.0	3.5	31.4	0.0	-1.2	0.0	30.1	
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	96.23	-50.7	0.2	-9.0	-0.6	0.00	0.0	3.5	31.4	0.0				
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	79.79	-49.0	0.0	-9.6	-0.5	0.00	0.0	1.2	35.6	0.0	-1.2	0.0	34.3	
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	79.79	-49.0	0.0	-9.6	-0.5	0.00	0.0	1.2	35.6	0.0				
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	76.20	-48.6	-0.4	-0.1	-0.6	0.00	0.0	0.6	20.6	0.0	-7.4	0.0	13.2	
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	76.20	-48.6	-0.4	-0.1	-0.6	0.00	0.0	0.6	20.6	0.0				
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	71.87	-48.1	-0.5	-0.1	-0.6	0.00	0.0	0.2	50.0	0.0	-28.2	0.0	26.8	
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	71.87	-48.1	-0.5	-0.1	-0.6	0.00	0.0	0.2	50.0	0.0				
Receiver R7-1 FI F 1 Lmax 41 dB(A) LAeq - Day 39 dB(A) LAeq - Nig 21 dB(A)																								
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	78.81	-48.9	-0.6	-0.4	-0.7	0.00	0.0	1.3	30.2	0.0	-1.6	0.0	28.6	
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	78.81	-48.9	-0.6	-0.4	-0.7	0.00	0.0	1.3	30.2	0.0	-13.5	0.0	16.7	
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	79.31	-49.0	0.2	-18.7	-0.2	0.00	0.0	6.7	14.1	0.0	-0.8	0.0	13.3	
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	79.31	-49.0	0.2	-18.7	-0.2	0.00	0.0	6.7	14.1	0.0	-10.3	0.0	3.8	
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	77.42	-48.8	0.2	-18.0	-0.2	0.00	0.0	2.6	10.7	0.0	-0.8	0.0	9.9	
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	77.42	-48.8	0.2	-18.0	-0.2	0.00	0.0	2.6	10.7	0.0	-10.3	0.0	0.4	
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	78.37	-48.9	0.2	-17.9	-0.2	0.00	0.0	2.2	10.5	0.0	-0.8	0.0	9.7	
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	78.37	-48.9	0.2	-17.9	-0.2	0.00	0.0	2.2	10.5	0.0	-10.3	0.0	0.2	
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	80.16	-49.1	0.3	-18.9	-0.2	0.00	0.0	8.5	13.7	0.0	-0.8	0.0	12.9	
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	80.16	-49.1	0.3	-18.9	-0.2	0.00	0.0	8.5	13.7	0.0	-10.3	0.0	3.3	
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	80.00	-49.1	0.2	-17.2	-0.2	0.00	0.0	7.5	11.3	0.0	-0.8	0.0	10.5	
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	80.00	-49.1	0.2	-17.2	-0.2	0.00	0.0	7.5	11.3	0.0	-10.3	0.0	1.0	
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	78.82	-48.9	-0.8	0.0	-0.7	0.00	0.0	1.4	18.0	0.0	12.6	0.0	30.7	
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	78.82	-48.9	-0.8	0.0	-0.7	0.00	0.0	1.4	18.0	0.0	-1.1	0.0	16.9	
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	85.96	-49.7	0.6	-0.6	-2.1	0.00	0.0	2.3	26.5	0.0	-7.4	0.0	24.1	
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	85.96	-49.7	0.6	-0.6	-2.1	0.00	0.0	2.3	26.5	0.0				

MWA Environmental

12

26062 Carina
Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	l or A m,m²	Kl dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)	
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	88.72	-50.0	0.7	-4.7	-0.6	0.00	0.0	0.0	20.4	0.0	-0.8	0.0	19.6	
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	88.72	-50.0	0.7	-4.7	-0.6	0.00	0.0	0.0	20.4	0.0	-10.3	0.0	10.1	
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	106.71	-51.6	1.2	-18.5	-0.8	0.00	0.0	1.1	13.2	0.0	-1.2	0.0	12.0	
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	106.71	-51.6	1.2	-18.5	-0.8	0.00	0.0	1.1	13.2	0.0				
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	96.22	-50.7	0.9	-7.4	-0.7	0.00	0.0	3.4	33.5	0.0	-1.2	0.0	32.3	
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	96.22	-50.7	0.9	-7.4	-0.7	0.00	0.0	3.4	33.5	0.0				
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	79.76	-49.0	0.6	-8.4	-0.6	0.00	0.0	1.3	37.4	0.0	-1.2	0.0	36.1	
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	79.76	-49.0	0.6	-8.4	-0.6	0.00	0.0	1.3	37.4	0.0				
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	76.27	-48.6	0.3	-0.5	-0.6	0.00	0.0	0.4	20.7	0.0	-7.4	0.0	13.3	
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	76.27	-48.6	0.3	-0.5	-0.6	0.00	0.0	0.4	20.7	0.0				
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	71.95	-48.1	0.2	0.0	-0.5	0.00	0.0	0.1	50.6	0.0	-28.2	0.0	27.4	
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	71.95	-48.1	0.2	0.0	-0.5	0.00	0.0	0.1	50.6	0.0				
Receiver R7-2 FI GF Lmax 42 dB(A) LAeq - Day 38 dB(A) LAeq - Nig 23 dB(A)																								
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	67.55	-47.6	-0.5	-0.5	-0.6	0.00	0.0	1.0	31.3	0.0	-1.6	0.0	29.7	
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	67.55	-47.6	-0.5	-0.5	-0.6	0.00	0.0	1.0	31.3	0.0	-13.5	0.0	17.8	
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	59.85	-46.5	-1.0	-8.8	-0.2	0.00	0.0	4.3	22.7	0.0	-0.8	0.0	22.0	
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	59.85	-46.5	-1.0	-8.8	-0.2	0.00	0.0	4.3	22.7	0.0	-10.3	0.0	12.4	
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	57.94	-46.3	-1.0	-10.8	-0.2	0.00	0.0	3.0	19.8	0.0	-0.8	0.0	19.0	
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	57.94	-46.3	-1.0	-10.8	-0.2	0.00	0.0	3.0	19.8	0.0	-10.3	0.0	9.4	
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	58.79	-46.4	-1.0	-9.7	-0.2	0.00	0.0	3.5	21.3	0.0	-0.8	0.0	20.5	
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	58.79	-46.4	-1.0	-9.7	-0.2	0.00	0.0	3.5	21.3	0.0	-10.3	0.0	10.9	
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	60.70	-46.7	-1.0	-8.5	-0.2	0.00	0.0	4.4	21.1	0.0	-0.8	0.0	20.3	
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	60.70	-46.7	-1.0	-8.5	-0.2	0.00	0.0	4.4	21.1	0.0	-10.3	0.0	10.8	
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	60.13	-46.6	-1.0	-9.7	-0.2	0.00	0.0	3.2	15.8	0.0	-0.8	0.0	15.0	
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	60.13	-46.6	-1.0	-9.7	-0.2	0.00	0.0	3.2	15.8	0.0	-10.3	0.0	5.4	
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	69.32	-47.8	-1.1	-0.1	-0.7	0.00	0.0	1.5	18.9	0.0	12.6	0.0	31.5	
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	69.32	-47.8	-1.1	-0.1	-0.7	0.00	0.0	1.5	18.9	0.0	-1.1	0.0	17.8	
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	79.76	-49.0	0.1	0.0	-1.9	0.00	0.0	2.4	27.6	0.0	-7.4	0.0	25.2	
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	79.76	-49.0	0.1	0.0	-1.9	0.00	0.0	2.4	27.6	0.0				
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	74.05	-48.4	-0.4	-4.5	-0.5	0.00	0.0	0.0	21.2	0.0	-0.8	0.0	20.4	
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	74.05	-48.4	-0.4	-4.5	-0.5	0.00	0.0	0.0	21.2	0.0	-10.3	0.0	10.9	
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	95.77	-50.6	0.4	-22.2	-0.8	0.00	0.0	4.2	12.8	0.0	-1.2	0.0	11.6	
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	95.77	-50.6	0.4	-22.2	-0.8	0.00	0.0	4.2	12.8	0.0				

MWA Environmental

13

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li	Rw	L'w	Lw	l or A	Kl	KT	DO	S	Adiv	Agr	Abar	Aatm	Amisc	ADI	dLrefl	Ls	Cmet	dLw	ZR	Lr	
			dB(A)	dB	dB(A)	dB(A)	m,m²	dB	dB	dB	m	dB	dB	dB	dB	dB	dB	dB(A)	dB(A)	dB	dB	dB	dB(A)	
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	89.78	-50.1	0.1	-18.7	-0.5	0.00	0.0	5.6	24.5	0.0	-1.2	0.0	23.3	
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	89.78	-50.1	0.1	-18.7	-0.5	0.00	0.0	5.6	24.5	0.0				
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	74.78	-48.5	0.0	-10.6	-0.5	0.00	0.0	1.2	35.1	0.0	-1.2	0.0	33.8	
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	74.78	-48.5	0.0	-10.6	-0.5	0.00	0.0	1.2	35.1	0.0				
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	73.75	-48.3	-0.5	-0.1	-0.6	0.00	0.0	0.9	21.1	0.0	-7.4	0.0	13.7	
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	73.75	-48.3	-0.5	-0.1	-0.6	0.00	0.0	0.9	21.1	0.0				
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	72.85	-48.2	-0.6	-0.1	-0.6	0.00	0.0	0.8	50.3	0.0	-28.2	0.0	27.1	
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	72.85	-48.2	-0.6	-0.1	-0.6	0.00	0.0	0.8	50.3	0.0				
Receiver T1 FIGF Lmax 54 dB(A) LAeq - Day 45 dB(A) LAeq - Nig 27 dB(A)																								
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	30.56	-40.7	1.2	-2.8	-0.2	0.00	0.0	0.0	37.0	0.0	-1.6	0.0	35.4	
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	30.56	-40.7	1.2	-2.8	-0.2	0.00	0.0	0.0	37.0	0.0	-13.5	0.0	23.5	
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	43.99	-43.9	1.2	-23.1	-0.2	0.00	0.0	0.0	9.0	0.0	-0.8	0.0	8.2	
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	43.99	-43.9	1.2	-23.1	-0.2	0.00	0.0	0.0	9.0	0.0	-10.3	0.0	-1.3	
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	45.01	-44.1	1.2	-23.2	-0.2	0.00	0.0	0.0	8.8	0.0	-0.8	0.0	8.0	
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	45.01	-44.1	1.2	-23.2	-0.2	0.00	0.0	0.0	8.8	0.0	-10.3	0.0	-1.6	
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	44.64	-44.0	1.2	-23.1	-0.2	0.00	0.0	0.0	8.9	0.0	-0.8	0.0	8.1	
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	44.64	-44.0	1.2	-23.1	-0.2	0.00	0.0	0.0	8.9	0.0	-10.3	0.0	-1.4	
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	43.57	-43.8	1.2	-23.1	-0.2	0.00	0.0	0.0	7.1	0.0	-0.8	0.0	6.3	
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	43.57	-43.8	1.2	-23.1	-0.2	0.00	0.0	0.0	7.1	0.0	-10.3	0.0	-3.2	
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	44.22	-43.9	1.2	-22.9	-0.2	0.00	0.0	0.0	4.3	0.0	-0.8	0.0	3.5	
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	44.22	-43.9	1.2	-22.9	-0.2	0.00	0.0	0.0	4.3	0.0	-10.3	0.0	-6.1	
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	28.32	-40.0	0.5	-1.7	-0.2	0.00	0.0	0.0	25.6	0.0	12.6	0.0	38.2	
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	28.32	-40.0	0.5	-1.7	-0.2	0.00	0.0	0.0	25.6	0.0	-1.1	0.0	24.5	
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	20.81	-37.4	1.0	-17.8	-0.2	0.00	0.0	0.3	22.0	0.0	-7.4	0.0	19.6	
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	20.81	-37.4	1.0	-17.8	-0.2	0.00	0.0	0.3	22.0	0.0				
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	33.66	-41.5	1.3	-17.7	-0.1	0.00	0.0	0.0	17.0	0.0	-0.8	0.0	16.2	
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	33.66	-41.5	1.3	-17.7	-0.1	0.00	0.0	0.0	17.0	0.0	-10.3	0.0	6.6	
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	22.87	-38.2	0.2	-8.3	-0.2	0.00	0.0	1.5	36.8	0.0	-1.2	0.0	35.6	
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	22.87	-38.2	0.2	-8.3	-0.2	0.00	0.0	1.5	36.8	0.0				
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	16.83	-35.5	0.8	-17.1	-0.1	0.00	0.0	1.7	37.8	0.0	-1.2	0.0	36.5	
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	16.83	-35.5	0.8	-17.1	-0.1	0.00	0.0	1.7	37.8	0.0				
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	22.39	-38.0	0.8	-17.9	-0.1	0.00	0.0	2.4	40.6	0.0	-1.2	0.0	39.3	
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	22.39	-38.0	0.8	-17.9	-0.1	0.00	0.0	2.4	40.6	0.0				

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	I or A m,m²	KI dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)	
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	23.80	-38.5	0.4	0.0	-0.2	0.00	0.0	0.0	31.3	0.0	-7.4	0.0	23.9	
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	23.80	-38.5	0.4	0.0	-0.2	0.00	0.0	0.0	31.3	0.0				
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	25.31	-39.1	0.0	-0.1	-0.2	0.00	0.0	0.0	59.6	0.0	-28.2	0.0	36.5	
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	25.31	-39.1	0.0	-0.1	-0.2	0.00	0.0	0.0	59.6	0.0				
Receiver T1 FIF 1 Lmax 53 dB(A) LAeq - Day 47 dB(A) LAeq - Nig 27 dB(A)																								
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	30.80	-40.8	1.2	-3.6	-0.3	0.00	0.0	0.0	36.2	0.0	-1.6	0.0	34.6	
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	30.80	-40.8	1.2	-3.6	-0.3	0.00	0.0	0.0	36.2	0.0	-13.5	0.0	22.7	
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	43.89	-43.8	1.7	-22.8	-0.2	0.00	0.0	0.0	9.9	0.0	-0.8	0.0	9.1	
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	43.89	-43.8	1.7	-22.8	-0.2	0.00	0.0	0.0	9.9	0.0	-10.3	0.0	-0.4	
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	44.92	-44.0	1.7	-22.8	-0.2	0.00	0.0	0.0	9.7	0.0	-0.8	0.0	8.9	
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	44.92	-44.0	1.7	-22.8	-0.2	0.00	0.0	0.0	9.7	0.0	-10.3	0.0	-0.7	
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	44.54	-44.0	1.7	-22.7	-0.2	0.00	0.0	0.0	9.9	0.0	-0.8	0.0	9.1	
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	44.54	-44.0	1.7	-22.7	-0.2	0.00	0.0	0.0	9.9	0.0	-10.3	0.0	-0.5	
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	43.48	-43.8	1.7	-22.7	-0.2	0.00	0.0	0.0	8.0	0.0	-0.8	0.0	7.2	
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	43.48	-43.8	1.7	-22.7	-0.2	0.00	0.0	0.0	8.0	0.0	-10.3	0.0	-2.3	
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	44.13	-43.9	1.7	-22.3	-0.2	0.00	0.0	0.0	5.3	0.0	-0.8	0.0	4.5	
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	44.13	-43.9	1.7	-22.3	-0.2	0.00	0.0	0.0	5.3	0.0	-10.3	0.0	-5.0	
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	28.57	-40.1	0.7	-1.8	-0.2	0.00	0.0	0.0	25.7	0.0	12.6	0.0	38.3	
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	28.57	-40.1	0.7	-1.8	-0.2	0.00	0.0	0.0	25.7	0.0	-1.1	0.0	24.6	
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	20.91	-37.4	1.1	-17.5	-0.2	0.00	0.0	0.3	22.3	0.0	-7.4	0.0	19.9	
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	20.91	-37.4	1.1	-17.5	-0.2	0.00	0.0	0.3	22.3	0.0				
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	33.24	-41.4	1.7	-11.4	-0.1	0.00	0.0	0.0	23.7	0.0	-0.8	0.0	22.9	
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	33.24	-41.4	1.7	-11.4	-0.1	0.00	0.0	0.0	23.7	0.0	-10.3	0.0	13.4	
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	23.15	-38.3	0.4	-8.1	-0.2	0.00	0.0	1.9	37.6	0.0	-1.2	0.0	36.3	
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	23.15	-38.3	0.4	-8.1	-0.2	0.00	0.0	1.9	37.6	0.0				
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	16.47	-35.3	0.9	-13.3	-0.1	0.00	0.0	2.3	42.5	0.0	-1.2	0.0	41.3	
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	16.47	-35.3	0.9	-13.3	-0.1	0.00	0.0	2.3	42.5	0.0				
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	22.12	-37.9	1.0	-14.6	-0.1	0.00	0.0	3.0	44.8	0.0	-1.2	0.0	43.5	
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	22.12	-37.9	1.0	-14.6	-0.1	0.00	0.0	3.0	44.8	0.0				
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	23.84	-38.5	0.7	-1.6	-0.2	0.00	0.0	0.0	30.1	0.0	-7.4	0.0	22.7	
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	23.84	-38.5	0.7	-1.6	-0.2	0.00	0.0	0.0	30.1	0.0				
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	25.34	-39.1	0.4	-0.2	-0.2	0.00	0.0	0.0	59.9	0.0	-28.2	0.0	36.7	
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	25.34	-39.1	0.4	-0.2	-0.2	0.00	0.0	0.0	59.9	0.0				

MWA Environmental

15

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li	Rw	L'w	Lw	I or A	KI	KT	DO	S	Adiv	Agr	Abar	Aatm	Amisc	ADI	dLrefl	Ls	Cmet	dLw	ZR	Lr	
			dB(A)	dB	dB(A)	dB(A)	m,m²	dB	dB	dB	m	dB	dB	dB	dB	dB	dB	dB(A)	dB(A)	dB	dB	dB	dB(A)	
Receiver T2 FI GF Lmax 55 dB(A) LAeq - Day 47 dB(A) LAeq - Nig 30 dB(A)																								
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	27.02	-39.6	1.1	-0.2	-0.2	0.00	0.0	0.0	40.6	0.0	-1.6	0.0	39.0	
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	27.02	-39.6	1.1	-0.2	-0.2	0.00	0.0	0.0	40.6	0.0	-13.5	0.0	27.1	
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	41.20	-43.3	1.3	-23.0	-0.2	0.00	0.0	0.3	10.0	0.0	-0.8	0.0	9.2	
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	41.20	-43.3	1.3	-23.0	-0.2	0.00	0.0	0.3	10.0	0.0	-10.3	0.0	-0.3	
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	41.99	-43.5	1.2	-23.1	-0.2	0.00	0.0	0.3	9.8	0.0	-0.8	0.0	9.0	
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	41.99	-43.5	1.2	-23.1	-0.2	0.00	0.0	0.3	9.8	0.0	-10.3	0.0	-0.5	
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	41.73	-43.4	1.3	-23.0	-0.2	0.00	0.0	0.3	10.0	0.0	-0.8	0.0	9.2	
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	41.73	-43.4	1.3	-23.0	-0.2	0.00	0.0	0.3	10.0	0.0	-10.3	0.0	-0.4	
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	40.90	-43.2	1.3	-23.0	-0.2	0.00	0.0	0.3	8.1	0.0	-0.8	0.0	7.3	
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	40.90	-43.2	1.3	-23.0	-0.2	0.00	0.0	0.3	8.1	0.0	-10.3	0.0	-2.2	
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	41.53	-43.4	1.3	-22.7	-0.2	0.00	0.0	2.4	7.4	0.0	-0.8	0.0	6.6	
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	41.53	-43.4	1.3	-22.7	-0.2	0.00	0.0	2.4	7.4	0.0	-10.3	0.0	-2.9	
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	23.63	-38.5	0.3	0.0	-0.2	0.00	0.0	0.0	28.7	0.0	12.6	0.0	41.4	
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	23.63	-38.5	0.3	0.0	-0.2	0.00	0.0	0.0	28.7	0.0	-1.1	0.0	27.6	
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	18.91	-36.5	1.0	-4.8	-0.5	0.00	0.0	0.0	35.2	0.0	-7.4	0.0	32.8	
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	18.91	-36.5	1.0	-4.8	-0.5	0.00	0.0	0.0	35.2	0.0				
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	32.44	-41.2	1.4	-17.8	-0.1	0.00	0.0	0.0	17.2	0.0	-0.8	0.0	16.4	
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	32.44	-41.2	1.4	-17.8	-0.1	0.00	0.0	0.0	17.2	0.0	-10.3	0.0	6.9	
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	27.29	-39.7	0.4	-11.4	-0.2	0.00	0.0	2.1	32.9	0.0	-1.2	0.0	31.6	
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	27.29	-39.7	0.4	-11.4	-0.2	0.00	0.0	2.1	32.9	0.0				
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	18.48	-36.3	0.8	-17.1	-0.1	0.00	0.0	2.1	37.3	0.0	-1.2	0.0	36.1	
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	18.48	-36.3	0.8	-17.1	-0.1	0.00	0.0	2.1	37.3	0.0				
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	19.21	-36.7	0.8	-17.3	-0.1	0.00	0.0	2.2	42.2	0.0	-1.2	0.0	41.0	
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	19.21	-36.7	0.8	-17.3	-0.1	0.00	0.0	2.2	42.2	0.0				
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	19.10	-36.6	0.4	0.0	-0.2	0.00	0.0	0.0	33.3	0.0	-7.4	0.0	25.9	
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	19.10	-36.6	0.4	0.0	-0.2	0.00	0.0	0.0	33.3	0.0				
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	19.99	-37.0	0.1	0.0	-0.2	0.00	0.0	0.0	61.8	0.0	-28.2	0.0	38.6	
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	19.99	-37.0	0.1	0.0	-0.2	0.00	0.0	0.0	61.8	0.0				
Receiver T2 FI F 1 Lmax 55 dB(A) LAeq - Day 49 dB(A) LAeq - Nig 30 dB(A)																								
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	27.34	-39.7	1.2	-1.6	-0.3	0.00	0.0	0.0	39.1	0.0	-1.6	0.0	37.5	
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	27.34	-39.7	1.2	-1.6	-0.3	0.00	0.0	0.0	39.1	0.0	-13.5	0.0	25.6	

MWA Environmental

16

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li	Rw	L'w	Lw	l or A	Kl	KT	DO	S	Adiv	Agr	Abar	Aatm	Amisc	ADI	dLrefl	Ls	Cmet	dLw	ZR	Lr
			dB(A)	dB	dB(A)	dB(A)	m,m²	dB	dB	dB	m	dB	dB	dB	dB	dB	dB	dB(A)	dB(A)	dB	dB	dB	dB(A)
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	41.11	-43.3	1.7	-22.7	-0.2	0.00	0.0	0.2	10.8	0.0	-0.8	0.0	10.0
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	41.11	-43.3	1.7	-22.7	-0.2	0.00	0.0	0.2	10.8	0.0	-10.3	0.0	0.5
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	41.89	-43.4	1.7	-22.7	-0.2	0.00	0.0	0.2	10.6	0.0	-0.8	0.0	9.8
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	41.89	-43.4	1.7	-22.7	-0.2	0.00	0.0	0.2	10.6	0.0	-10.3	0.0	0.3
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	41.64	-43.4	1.7	-22.6	-0.2	0.00	0.0	0.2	10.8	0.0	-0.8	0.0	10.0
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	41.64	-43.4	1.7	-22.6	-0.2	0.00	0.0	0.2	10.8	0.0	-10.3	0.0	0.5
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	40.81	-43.2	1.7	-22.7	-0.2	0.00	0.0	0.2	8.9	0.0	-0.8	0.0	8.1
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	40.81	-43.2	1.7	-22.7	-0.2	0.00	0.0	0.2	8.9	0.0	-10.3	0.0	-1.4
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	41.44	-43.3	1.7	-22.3	-0.2	0.00	0.0	2.5	8.5	0.0	-0.8	0.0	7.7
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	41.44	-43.3	1.7	-22.3	-0.2	0.00	0.0	2.5	8.5	0.0	-10.3	0.0	-1.8
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	24.00	-38.6	0.6	-0.7	-0.2	0.00	0.0	0.0	28.1	0.0	12.6	0.0	40.7
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	24.00	-38.6	0.6	-0.7	-0.2	0.00	0.0	0.0	28.1	0.0	-1.1	0.0	27.0
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	19.04	-36.6	1.1	-4.8	-0.5	0.00	0.0	0.0	35.3	0.0	-7.4	0.0	32.8
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	19.04	-36.6	1.1	-4.8	-0.5	0.00	0.0	0.0	35.3	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	32.02	-41.1	1.7	-11.0	-0.1	0.00	0.0	0.0	24.4	0.0	-0.8	0.0	23.6
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	32.02	-41.1	1.7	-11.0	-0.1	0.00	0.0	0.0	24.4	0.0	-10.3	0.0	14.1
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	27.51	-39.8	0.6	-11.2	-0.2	0.00	0.0	2.7	33.9	0.0	-1.2	0.0	32.6
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	27.51	-39.8	0.6	-11.2	-0.2	0.00	0.0	2.7	33.9	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	18.19	-36.2	0.9	-13.3	-0.1	0.00	0.0	2.6	41.9	0.0	-1.2	0.0	40.6
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	18.19	-36.2	0.9	-13.3	-0.1	0.00	0.0	2.6	41.9	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	18.92	-36.5	1.0	-13.7	-0.1	0.00	0.0	2.7	46.8	0.0	-1.2	0.0	45.5
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	18.92	-36.5	1.0	-13.7	-0.1	0.00	0.0	2.7	46.8	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	19.18	-36.7	0.7	-1.5	-0.2	0.00	0.0	0.0	32.1	0.0	-7.4	0.0	24.7
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	19.18	-36.7	0.7	-1.5	-0.2	0.00	0.0	0.0	32.1	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	20.06	-37.0	0.4	-0.2	-0.2	0.00	0.0	0.0	62.1	0.0	-28.2	0.0	38.9
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	20.06	-37.0	0.4	-0.2	-0.2	0.00	0.0	0.0	62.1	0.0			
Receiver T3 FI GF Lmax 56 dB(A) LAeq - Day 48 dB(A) LAeq - Nig 31 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	25.69	-39.2	1.0	-0.1	-0.2	0.00	0.0	0.1	41.2	0.0	-1.6	0.0	39.6
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	25.69	-39.2	1.0	-0.1	-0.2	0.00	0.0	0.1	41.2	0.0	-13.5	0.0	27.7
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	39.93	-43.0	1.2	-22.9	-0.2	0.00	0.0	0.0	10.0	0.0	-0.8	0.0	9.3
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	39.93	-43.0	1.2	-22.9	-0.2	0.00	0.0	0.0	10.0	0.0	-10.3	0.0	-0.3
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	40.39	-43.1	1.2	-23.0	-0.2	0.00	0.0	0.0	9.9	0.0	-0.8	0.0	9.1
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	40.39	-43.1	1.2	-23.0	-0.2	0.00	0.0	0.0	9.9	0.0	-10.3	0.0	-0.4

MWA Environmental

17

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	l or A m,m²	Kl dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	40.30	-43.1	1.2	-22.9	-0.2	0.00	0.0	0.0	10.0	0.0	-0.8	0.0	9.3
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	40.30	-43.1	1.2	-22.9	-0.2	0.00	0.0	0.0	10.0	0.0	-10.3	0.0	-0.3
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	39.78	-43.0	1.2	-22.9	-0.2	0.00	0.0	0.0	8.1	0.0	-0.8	0.0	7.3
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	39.78	-43.0	1.2	-22.9	-0.2	0.00	0.0	0.0	8.1	0.0	-10.3	0.0	-2.2
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	40.36	-43.1	1.2	-22.6	-0.2	0.00	0.0	2.2	7.5	0.0	-0.8	0.0	6.7
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	40.36	-43.1	1.2	-22.6	-0.2	0.00	0.0	2.2	7.5	0.0	-10.3	0.0	-2.8
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	20.43	-37.2	0.1	-0.2	-0.2	0.00	0.0	0.0	29.6	0.0	12.6	0.0	42.2
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	20.43	-37.2	0.1	-0.2	-0.2	0.00	0.0	0.0	29.6	0.0	-1.1	0.0	28.5
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	19.93	-37.0	1.0	0.0	-0.6	0.00	0.0	0.0	39.4	0.0	-7.4	0.0	37.0
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	19.93	-37.0	1.0	0.0	-0.6	0.00	0.0	0.0	39.4	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	33.28	-41.4	1.3	-14.9	-0.1	0.00	0.0	1.1	20.9	0.0	-0.8	0.0	20.1
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	33.28	-41.4	1.3	-14.9	-0.1	0.00	0.0	1.1	20.9	0.0	-10.3	0.0	10.6
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	33.17	-41.4	0.4	-13.2	-0.3	0.00	0.0	2.4	29.7	0.0	-1.2	0.0	28.4
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	33.17	-41.4	0.4	-13.2	-0.3	0.00	0.0	2.4	29.7	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	23.01	-38.2	0.7	-17.5	-0.1	0.00	0.0	3.1	36.0	0.0	-1.2	0.0	34.7
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	23.01	-38.2	0.7	-17.5	-0.1	0.00	0.0	3.1	36.0	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	18.48	-36.3	0.7	-16.6	-0.1	0.00	0.0	2.2	43.3	0.0	-1.2	0.0	42.0
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	18.48	-36.3	0.7	-16.6	-0.1	0.00	0.0	2.2	43.3	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	16.07	-35.1	0.3	0.0	-0.1	0.00	0.0	0.0	34.8	0.0	-7.4	0.0	27.4
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	16.07	-35.1	0.3	0.0	-0.1	0.00	0.0	0.0	34.8	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	15.75	-34.9	0.1	0.0	-0.1	0.00	0.0	0.0	64.0	0.0	-28.2	0.0	40.8
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	15.75	-34.9	0.1	0.0	-0.1	0.00	0.0	0.0	64.0	0.0			
Receiver T3 FIF 1 Lmax 56 dB(A) LAeq - Day 50 dB(A) LAeq - Nig 31 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	26.06	-39.3	1.1	-1.7	-0.3	0.00	0.0	0.1	39.5	0.0	-1.6	0.0	37.9
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	26.06	-39.3	1.1	-1.7	-0.3	0.00	0.0	0.1	39.5	0.0	-13.5	0.0	26.0
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	39.85	-43.0	1.7	-22.6	-0.2	0.00	0.0	0.0	10.9	0.0	-0.8	0.0	10.1
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	39.85	-43.0	1.7	-22.6	-0.2	0.00	0.0	0.0	10.9	0.0	-10.3	0.0	0.5
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	40.31	-43.1	1.7	-22.7	-0.2	0.00	0.0	0.0	10.7	0.0	-0.8	0.0	9.9
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	40.31	-43.1	1.7	-22.7	-0.2	0.00	0.0	0.0	10.7	0.0	-10.3	0.0	0.4
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	40.22	-43.1	1.7	-22.5	-0.2	0.00	0.0	0.0	10.9	0.0	-0.8	0.0	10.1
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	40.22	-43.1	1.7	-22.5	-0.2	0.00	0.0	0.0	10.9	0.0	-10.3	0.0	0.5
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	39.70	-43.0	1.7	-22.6	-0.2	0.00	0.0	0.0	8.9	0.0	-0.8	0.0	8.1
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	39.70	-43.0	1.7	-22.6	-0.2	0.00	0.0	0.0	8.9	0.0	-10.3	0.0	-1.4

MWA Environmental

18

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li	Rw	L'w	Lw	I or A	KI	KT	DO	S	Adiv	Agr	Abar	Aatm	Amisc	ADI	dLrefl	Ls	Cmet	dLw	ZR	Lr		
			dB(A)	dB	dB(A)	dB(A)	m,m²	dB	dB	dB	m	dB	dB	dB	dB	dB	dB	dB(A)	dB(A)	dB	dB	dB	dB(A)		
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	40.28	-43.1	1.7	-22.2	-0.2	0.00	0.0	2.4	8.6	0.0	-0.8	0.0	7.8		
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	40.28	-43.1	1.7	-22.2	-0.2	0.00	0.0	2.4	8.6	0.0	-10.3	0.0	-1.8		
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	21.01	-37.4	0.4	-0.7	-0.2	0.00	0.0	0.0	29.2	0.0	12.6	0.0	41.8		
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	21.01	-37.4	0.4	-0.7	-0.2	0.00	0.0	0.0	29.2	0.0	-1.1	0.0	28.1		
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	20.10	-37.1	1.1	-1.4	-0.7	0.00	0.0	0.0	37.9	0.0	-7.4	0.0	35.5		
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	20.10	-37.1	1.1	-1.4	-0.7	0.00	0.0	0.0	37.9	0.0					
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	32.89	-41.3	1.6	-5.8	-0.2	0.00	0.0	1.4	30.7	0.0	-0.8	0.0	29.9		
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	32.89	-41.3	1.6	-5.8	-0.2	0.00	0.0	1.4	30.7	0.0	-10.3	0.0	20.4		
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	33.37	-41.5	0.6	-13.1	-0.3	0.00	0.0	2.9	30.5	0.0	-1.2	0.0	29.2		
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	33.37	-41.5	0.6	-13.1	-0.3	0.00	0.0	2.9	30.5	0.0					
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	22.83	-38.2	0.9	-14.2	-0.1	0.00	0.0	4.3	40.7	0.0	-1.2	0.0	39.5		
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	22.83	-38.2	0.9	-14.2	-0.1	0.00	0.0	4.3	40.7	0.0					
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	18.23	-36.2	0.9	-12.7	-0.1	0.00	0.0	2.9	48.2	0.0	-1.2	0.0	46.9		
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	18.23	-36.2	0.9	-12.7	-0.1	0.00	0.0	2.9	48.2	0.0					
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	16.22	-35.2	0.6	-1.5	-0.1	0.00	0.0	0.0	33.5	0.0	-7.4	0.0	26.1		
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	16.22	-35.2	0.6	-1.5	-0.1	0.00	0.0	0.0	33.5	0.0					
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	15.87	-35.0	0.4	-0.1	-0.1	0.00	0.0	0.0	64.2	0.0	-28.2	0.0	41.0		
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	15.87	-35.0	0.4	-0.1	-0.1	0.00	0.0	0.0	64.2	0.0					
Receiver T4 FI GF Lmax 58 dB(A) LAeq - Day 49 dB(A) LAeq - Nig 32 dB(A)																									
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	24.63	-38.8	1.1	-0.1	-0.2	0.00	0.0	0.4	41.8	0.0	-1.6	0.0	40.2		
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	24.63	-38.8	1.1	-0.1	-0.2	0.00	0.0	0.4	41.8	0.0	-13.5	0.0	28.3		
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	38.22	-42.6	1.3	-22.9	-0.2	0.00	0.0	0.7	11.2	0.0	-0.8	0.0	10.4		
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	38.22	-42.6	1.3	-22.9	-0.2	0.00	0.0	0.7	11.2	0.0	-10.3	0.0	0.9		
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	38.34	-42.7	1.3	-23.0	-0.2	0.00	0.0	0.7	11.1	0.0	-0.8	0.0	10.3		
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	38.34	-42.7	1.3	-23.0	-0.2	0.00	0.0	0.7	11.1	0.0	-10.3	0.0	0.8		
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	38.41	-42.7	1.3	-22.9	-0.2	0.00	0.0	0.7	11.2	0.0	-0.8	0.0	10.4		
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	38.41	-42.7	1.3	-22.9	-0.2	0.00	0.0	0.7	11.2	0.0	-10.3	0.0	0.9		
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	38.22	-42.6	1.3	-22.9	-0.2	0.00	0.0	0.7	9.2	0.0	-0.8	0.0	8.4		
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	38.22	-42.6	1.3	-22.9	-0.2	0.00	0.0	0.7	9.2	0.0	-10.3	0.0	-1.1		
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	38.75	-42.8	1.3	-22.6	-0.2	0.00	0.0	2.6	8.4	0.0	-0.8	0.0	7.6		
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	38.75	-42.8	1.3	-22.6	-0.2	0.00	0.0	2.6	8.4	0.0	-10.3	0.0	-2.0		
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	18.44	-36.3	0.1	-0.3	-0.2	0.00	0.0	0.3	30.7	0.0	12.6	0.0	43.4		
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	18.44	-36.3	0.1	-0.3	-0.2	0.00	0.0	0.3	30.7	0.0	-1.1	0.0	29.7		

26062 Carina
Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	I or A m,m²	KI dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	21.60	-37.7	1.0	0.0	-0.6	0.00	0.0	2.3	41.0	0.0	-7.4	0.0	38.6
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	21.60	-37.7	1.0	0.0	-0.6	0.00	0.0	2.3	41.0	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	33.92	-41.6	1.3	-14.7	-0.1	0.00	0.0	0.1	19.9	0.0	-0.8	0.0	19.2
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	33.92	-41.6	1.3	-14.7	-0.1	0.00	0.0	0.1	19.9	0.0	-10.3	0.0	9.6
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	38.25	-42.6	0.6	-14.9	-0.4	0.00	0.0	2.5	27.1	0.0	-1.2	0.0	25.8
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	38.25	-42.6	0.6	-14.9	-0.4	0.00	0.0	2.5	27.1	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	27.37	-39.7	0.8	-17.0	-0.2	0.00	0.0	3.8	35.6	0.0	-1.2	0.0	34.4
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	27.37	-39.7	0.8	-17.0	-0.2	0.00	0.0	3.8	35.6	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	18.28	-36.2	0.8	-16.4	-0.1	0.00	0.0	1.6	43.0	0.0	-1.2	0.0	41.8
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	18.28	-36.2	0.8	-16.4	-0.1	0.00	0.0	1.6	43.0	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	14.26	-34.1	0.4	0.0	-0.1	0.00	0.0	0.0	35.9	0.0	-7.4	0.0	28.5
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	14.26	-34.1	0.4	0.0	-0.1	0.00	0.0	0.0	35.9	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	12.24	-32.7	0.2	0.0	-0.1	0.00	0.0	0.0	66.3	0.0	-28.2	0.0	43.1
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	12.24	-32.7	0.2	0.0	-0.1	0.00	0.0	0.0	66.3	0.0			
Receiver T4 FIF 1 Lmax 58 dB(A) LAeq - Day 50 dB(A) LAeq - Nig 31 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	25.04	-39.0	1.1	-2.1	-0.2	0.00	0.0	0.3	39.6	0.0	-1.6	0.0	38.0
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	25.04	-39.0	1.1	-2.1	-0.2	0.00	0.0	0.3	39.6	0.0	-13.5	0.0	26.1
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	38.15	-42.6	1.7	-21.8	-0.2	0.00	0.0	0.5	12.6	0.0	-0.8	0.0	11.8
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	38.15	-42.6	1.7	-21.8	-0.2	0.00	0.0	0.5	12.6	0.0	-10.3	0.0	2.3
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	38.27	-42.7	1.7	-21.9	-0.2	0.00	0.0	0.5	12.5	0.0	-0.8	0.0	11.8
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	38.27	-42.7	1.7	-21.9	-0.2	0.00	0.0	0.5	12.5	0.0	-10.3	0.0	2.2
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	38.34	-42.7	1.7	-21.7	-0.1	0.00	0.0	0.5	12.7	0.0	-0.8	0.0	11.9
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	38.34	-42.7	1.7	-21.7	-0.1	0.00	0.0	0.5	12.7	0.0	-10.3	0.0	2.3
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	38.15	-42.6	1.7	-21.8	-0.1	0.00	0.0	0.5	10.7	0.0	-0.8	0.0	9.9
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	38.15	-42.6	1.7	-21.8	-0.1	0.00	0.0	0.5	10.7	0.0	-10.3	0.0	0.3
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	38.68	-42.7	1.7	-21.4	-0.1	0.00	0.0	2.6	10.1	0.0	-0.8	0.0	9.3
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	38.68	-42.7	1.7	-21.4	-0.1	0.00	0.0	2.6	10.1	0.0	-10.3	0.0	-0.2
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	19.21	-36.7	0.4	-0.9	-0.2	0.00	0.0	0.1	29.9	0.0	12.6	0.0	42.5
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	19.21	-36.7	0.4	-0.9	-0.2	0.00	0.0	0.1	29.9	0.0	-1.1	0.0	28.8
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	21.77	-37.8	1.1	-4.4	-0.5	0.00	0.0	2.1	36.5	0.0	-7.4	0.0	34.1
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	21.77	-37.8	1.1	-4.4	-0.5	0.00	0.0	2.1	36.5	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	33.55	-41.5	1.7	-4.9	-0.2	0.00	0.0	0.0	30.0	0.0	-0.8	0.0	29.2
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	33.55	-41.5	1.7	-4.9	-0.2	0.00	0.0	0.0	30.0	0.0	-10.3	0.0	19.7

MWA Environmental

20

26062 Carina
Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	l or A m,m²	Kl dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)	
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	38.43	-42.7	0.8	-14.7	-0.3	0.00	0.0	2.7	27.7	0.0	-1.2	0.0	26.4	
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	38.43	-42.7	0.8	-14.7	-0.3	0.00	0.0	2.7	27.7	0.0				
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	27.25	-39.7	1.0	-13.1	-0.2	0.00	0.0	4.9	41.0	0.0	-1.2	0.0	39.7	
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	27.25	-39.7	1.0	-13.1	-0.2	0.00	0.0	4.9	41.0	0.0				
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	18.06	-36.1	0.9	-12.3	-0.1	0.00	0.0	2.4	48.2	0.0	-1.2	0.0	46.9	
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	18.06	-36.1	0.9	-12.3	-0.1	0.00	0.0	2.4	48.2	0.0				
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	14.48	-34.2	0.6	-1.9	-0.1	0.00	0.0	0.0	34.1	0.0	-7.4	0.0	26.7	
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	14.48	-34.2	0.6	-1.9	-0.1	0.00	0.0	0.0	34.1	0.0				
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	12.46	-32.9	0.5	-0.1	-0.1	0.00	0.0	0.0	66.3	0.0	-28.2	0.0	43.1	
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	12.46	-32.9	0.5	-0.1	-0.1	0.00	0.0	0.0	66.3	0.0				
Receiver T5 FI GF Lmax 56 dB(A) LAeq - Day 48 dB(A) LAeq - Nig 32 dB(A)																								
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	25.82	-39.2	1.0	-0.2	-0.2	0.00	0.0	0.5	41.4	0.0	-1.6	0.0	39.8	
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	25.82	-39.2	1.0	-0.2	-0.2	0.00	0.0	0.5	41.4	0.0	-13.5	0.0	27.9	
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	38.07	-42.6	1.3	-23.0	-0.2	0.00	0.0	0.6	11.1	0.0	-0.8	0.0	10.3	
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	38.07	-42.6	1.3	-23.0	-0.2	0.00	0.0	0.6	11.1	0.0	-10.3	0.0	0.7	
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	37.83	-42.5	1.3	-23.0	-0.2	0.00	0.0	0.6	11.1	0.0	-0.8	0.0	10.3	
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	37.83	-42.5	1.3	-23.0	-0.2	0.00	0.0	0.6	11.1	0.0	-10.3	0.0	0.7	
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	38.07	-42.6	1.3	-23.0	-0.2	0.00	0.0	0.6	11.1	0.0	-0.8	0.0	10.3	
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	38.07	-42.6	1.3	-23.0	-0.2	0.00	0.0	0.6	11.1	0.0	-10.3	0.0	0.8	
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	38.23	-42.6	1.3	-23.0	-0.2	0.00	0.0	0.6	9.1	0.0	-0.8	0.0	8.3	
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	38.23	-42.6	1.3	-23.0	-0.2	0.00	0.0	0.6	9.1	0.0	-10.3	0.0	-1.3	
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	38.68	-42.7	1.3	-22.7	-0.2	0.00	0.0	2.6	8.2	0.0	-0.8	0.0	7.4	
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	38.68	-42.7	1.3	-22.7	-0.2	0.00	0.0	2.6	8.2	0.0	-10.3	0.0	-2.1	
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	21.06	-37.5	0.3	0.0	-0.2	0.00	0.0	0.4	30.1	0.0	12.6	0.0	42.7	
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	21.06	-37.5	0.3	0.0	-0.2	0.00	0.0	0.4	30.1	0.0	-1.1	0.0	29.0	
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	25.32	-39.1	1.0	0.0	-0.7	0.00	0.0	2.3	39.5	0.0	-7.4	0.0	37.1	
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	25.32	-39.1	1.0	0.0	-0.7	0.00	0.0	2.3	39.5	0.0				
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	36.20	-42.2	1.3	-14.2	-0.1	0.00	0.0	0.2	20.1	0.0	-0.8	0.0	19.3	
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	36.20	-42.2	1.3	-14.2	-0.1	0.00	0.0	0.2	20.1	0.0	-10.3	0.0	9.8	
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	43.90	-43.8	0.7	-15.9	-0.4	0.00	0.0	2.6	25.1	0.0	-1.2	0.0	23.8	
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	43.90	-43.8	0.7	-15.9	-0.4	0.00	0.0	2.6	25.1	0.0				
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	32.76	-41.3	0.8	-15.7	-0.2	0.00	0.0	3.8	35.4	0.0	-1.2	0.0	34.1	
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	32.76	-41.3	0.8	-15.7	-0.2	0.00	0.0	3.8	35.4	0.0				

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	l or A m,m²	Kl dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	20.64	-37.3	0.8	-16.6	-0.1	0.00	0.0	1.3	41.5	0.0	-1.2	0.0	40.3
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	20.64	-37.3	0.8	-16.6	-0.1	0.00	0.0	1.3	41.5	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	16.34	-35.3	0.4	0.0	-0.1	0.00	0.0	0.0	34.7	0.0	-7.4	0.0	27.3
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	16.34	-35.3	0.4	0.0	-0.1	0.00	0.0	0.0	34.7	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	12.35	-32.8	0.2	0.0	-0.1	0.00	0.0	0.0	66.3	0.0	-28.2	0.0	43.1
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	12.35	-32.8	0.2	0.0	-0.1	0.00	0.0	0.0	66.3	0.0			
Receiver T5 FIF 1 Lmax 55 dB(A) LAeq - Day 49 dB(A) LAeq - Nig 30 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	26.22	-39.4	1.0	-2.1	-0.2	0.00	0.0	0.4	39.2	0.0	-1.6	0.0	37.6
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	26.22	-39.4	1.0	-2.1	-0.2	0.00	0.0	0.4	39.2	0.0	-13.5	0.0	25.7
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	38.01	-42.6	1.7	-22.6	-0.2	0.00	0.0	0.5	11.9	0.0	-0.8	0.0	11.1
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	38.01	-42.6	1.7	-22.6	-0.2	0.00	0.0	0.5	11.9	0.0	-10.3	0.0	1.5
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	37.77	-42.5	1.7	-22.6	-0.2	0.00	0.0	0.5	11.9	0.0	-0.8	0.0	11.1
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	37.77	-42.5	1.7	-22.6	-0.2	0.00	0.0	0.5	11.9	0.0	-10.3	0.0	1.5
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	38.01	-42.6	1.7	-22.5	-0.2	0.00	0.0	0.5	11.9	0.0	-0.8	0.0	11.1
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	38.01	-42.6	1.7	-22.5	-0.2	0.00	0.0	0.5	11.9	0.0	-10.3	0.0	1.6
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	38.17	-42.6	1.7	-22.6	-0.2	0.00	0.0	0.5	9.9	0.0	-0.8	0.0	9.1
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	38.17	-42.6	1.7	-22.6	-0.2	0.00	0.0	0.5	9.9	0.0	-10.3	0.0	-0.5
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	38.62	-42.7	1.7	-22.2	-0.2	0.00	0.0	2.7	9.3	0.0	-0.8	0.0	8.5
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	38.62	-42.7	1.7	-22.2	-0.2	0.00	0.0	2.7	9.3	0.0	-10.3	0.0	-1.0
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	21.66	-37.7	0.5	-1.3	-0.2	0.00	0.0	0.2	28.7	0.0	12.6	0.0	41.3
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	21.66	-37.7	0.5	-1.3	-0.2	0.00	0.0	0.2	28.7	0.0	-1.1	0.0	27.6
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	25.49	-39.1	1.1	-5.0	-0.6	0.00	0.0	2.1	34.5	0.0	-7.4	0.0	32.1
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	25.49	-39.1	1.1	-5.0	-0.6	0.00	0.0	2.1	34.5	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	35.87	-42.1	1.7	-4.6	-0.2	0.00	0.0	0.0	29.8	0.0	-0.8	0.0	29.0
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	35.87	-42.1	1.7	-4.6	-0.2	0.00	0.0	0.0	29.8	0.0	-10.3	0.0	19.5
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	44.06	-43.9	1.0	-15.7	-0.4	0.00	0.0	2.8	25.6	0.0	-1.2	0.0	24.3
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	44.06	-43.9	1.0	-15.7	-0.4	0.00	0.0	2.8	25.6	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	32.67	-41.3	1.0	-11.2	-0.2	0.00	0.0	4.8	41.2	0.0	-1.2	0.0	39.9
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	32.67	-41.3	1.0	-11.2	-0.2	0.00	0.0	4.8	41.2	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	20.48	-37.2	1.0	-12.4	-0.1	0.00	0.0	1.9	46.5	0.0	-1.2	0.0	45.2
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	20.48	-37.2	1.0	-12.4	-0.1	0.00	0.0	1.9	46.5	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	16.55	-35.4	0.7	-2.3	-0.1	0.00	0.0	0.0	32.6	0.0	-7.4	0.0	25.2
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	16.55	-35.4	0.7	-2.3	-0.1	0.00	0.0	0.0	32.6	0.0			

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	I or A m,m²	KI dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	12.60	-33.0	0.5	-0.3	-0.1	0.00	0.0	0.0	66.1	0.0	-28.2	0.0	42.9
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	12.60	-33.0	0.5	-0.3	-0.1	0.00	0.0	0.0	66.1	0.0			
Receiver T8 FI GF Lmax 53 dB(A) LAeq - Day 47 dB(A) LAeq - Nig 30 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	25.54	-39.1	0.1	-0.5	-0.2	0.00	0.0	0.7	40.4	0.0	-1.6	0.0	38.8
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	25.54	-39.1	0.1	-0.5	-0.2	0.00	0.0	0.7	40.4	0.0	-13.5	0.0	26.9
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	30.98	-40.8	-0.4	-20.0	-0.1	0.00	0.0	0.3	13.9	0.0	-0.8	0.0	13.1
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	30.98	-40.8	-0.4	-20.0	-0.1	0.00	0.0	0.3	13.9	0.0	-10.3	0.0	3.6
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	29.71	-40.5	-0.7	-19.1	-0.1	0.00	0.0	0.2	14.9	0.0	-0.8	0.0	14.1
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	29.71	-40.5	-0.7	-19.1	-0.1	0.00	0.0	0.2	14.9	0.0	-10.3	0.0	4.5
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	30.41	-40.7	-0.5	-19.4	-0.1	0.00	0.0	0.2	14.5	0.0	-0.8	0.0	13.7
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	30.41	-40.7	-0.5	-19.4	-0.1	0.00	0.0	0.2	14.5	0.0	-10.3	0.0	4.2
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	31.59	-41.0	-0.3	-20.3	-0.1	0.00	0.0	0.3	11.6	0.0	-0.8	0.0	10.8
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	31.59	-41.0	-0.3	-20.3	-0.1	0.00	0.0	0.3	11.6	0.0	-10.3	0.0	1.3
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	31.72	-41.0	-0.4	-19.5	-0.1	0.00	0.0	2.5	11.5	0.0	-0.8	0.0	10.7
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	31.72	-41.0	-0.4	-19.5	-0.1	0.00	0.0	2.5	11.5	0.0	-10.3	0.0	1.2
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	26.07	-39.3	-0.1	0.0	-0.3	0.00	0.0	0.8	28.2	0.0	12.6	0.0	40.8
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	26.07	-39.3	-0.1	0.0	-0.3	0.00	0.0	0.8	28.2	0.0	-1.1	0.0	27.1
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	32.35	-41.2	1.0	0.0	-0.9	0.00	0.0	2.3	37.2	0.0	-7.4	0.0	34.8
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	32.35	-41.2	1.0	0.0	-0.9	0.00	0.0	2.3	37.2	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	36.84	-42.3	0.8	-9.1	-0.2	0.00	0.0	0.1	24.3	0.0	-0.8	0.0	23.5
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	36.84	-42.3	0.8	-9.1	-0.2	0.00	0.0	0.1	24.3	0.0	-10.3	0.0	13.9
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	53.38	-45.5	1.4	-22.8	-0.5	0.00	0.0	1.6	16.0	0.0	-1.2	0.0	14.7
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	53.38	-45.5	1.4	-22.8	-0.5	0.00	0.0	1.6	16.0	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	42.80	-43.6	1.3	-13.9	-0.2	0.00	0.0	4.4	35.8	0.0	-1.2	0.0	34.6
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	42.80	-43.6	1.3	-13.9	-0.2	0.00	0.0	4.4	35.8	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	25.44	-39.1	0.6	-13.5	-0.1	0.00	0.0	1.7	42.9	0.0	-1.2	0.0	41.6
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	25.44	-39.1	0.6	-13.5	-0.1	0.00	0.0	1.7	42.9	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	22.93	-38.2	0.3	-0.1	-0.2	0.00	0.0	0.6	32.1	0.0	-7.4	0.0	24.7
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	22.93	-38.2	0.3	-0.1	-0.2	0.00	0.0	0.6	32.1	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	18.85	-36.5	0.0	-0.1	-0.2	0.00	0.0	0.0	62.3	0.0	-28.2	0.0	39.1
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	18.85	-36.5	0.0	-0.1	-0.2	0.00	0.0	0.0	62.3	0.0			
Receiver T8 FI F 1 Lmax 53 dB(A) LAeq - Day 49 dB(A) LAeq - Nig 30 dB(A)																							

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li	Rw	L'w	Lw	l or A	Kl	KT	DO	S	Adiv	Agr	Abar	Aatm	Amisc	ADI	dLrefl	Ls	Cmet	dLw	ZR	Lr
			dB(A)	dB	dB(A)	dB(A)	m,m ²	dB	dB	dB	m	dB	dB	dB	dB	dB	dB	dB(A)	dB(A)	dB	dB	dB	dB(A)
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	25.96	-39.3	0.1	-0.7	-0.3	0.00	0.0	0.2	39.6	0.0	-1.6	0.0	38.0
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	25.96	-39.3	0.1	-0.7	-0.3	0.00	0.0	0.2	39.6	0.0	-13.5	0.0	26.1
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	30.94	-40.8	0.4	-20.3	-0.1	0.00	0.0	0.2	14.4	0.0	-0.8	0.0	13.6
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	30.94	-40.8	0.4	-20.3	-0.1	0.00	0.0	0.2	14.4	0.0	-10.3	0.0	4.1
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	29.67	-40.4	0.1	-19.4	-0.1	0.00	0.0	0.2	15.4	0.0	-0.8	0.0	14.6
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	29.67	-40.4	0.1	-19.4	-0.1	0.00	0.0	0.2	15.4	0.0	-10.3	0.0	5.0
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	30.38	-40.6	0.2	-19.7	-0.1	0.00	0.0	0.2	15.0	0.0	-0.8	0.0	14.2
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	30.38	-40.6	0.2	-19.7	-0.1	0.00	0.0	0.2	15.0	0.0	-10.3	0.0	4.7
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	31.55	-41.0	0.5	-20.5	-0.1	0.00	0.0	0.3	12.1	0.0	-0.8	0.0	11.3
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	31.55	-41.0	0.5	-20.5	-0.1	0.00	0.0	0.3	12.1	0.0	-10.3	0.0	1.8
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	31.69	-41.0	0.4	-19.7	-0.1	0.00	0.0	2.7	12.3	0.0	-0.8	0.0	11.5
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	31.69	-41.0	0.4	-19.7	-0.1	0.00	0.0	2.7	12.3	0.0	-10.3	0.0	1.9
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	26.44	-39.4	0.2	-0.1	-0.3	0.00	0.0	0.2	27.7	0.0	12.6	0.0	40.4
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	26.44	-39.4	0.2	-0.1	-0.3	0.00	0.0	0.2	27.7	0.0	-1.1	0.0	26.7
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	32.52	-41.2	1.2	-6.6	-0.6	0.00	0.0	2.1	30.8	0.0	-7.4	0.0	28.4
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	32.52	-41.2	1.2	-6.6	-0.6	0.00	0.0	2.1	30.8	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	36.55	-42.2	1.2	-5.5	-0.2	0.00	0.0	0.0	28.3	0.0	-0.8	0.0	27.5
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	36.55	-42.2	1.2	-5.5	-0.2	0.00	0.0	0.0	28.3	0.0	-10.3	0.0	18.0
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	53.53	-45.6	1.7	-23.4	-0.5	0.00	0.0	1.3	15.3	0.0	-1.2	0.0	14.1
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	53.53	-45.6	1.7	-23.4	-0.5	0.00	0.0	1.3	15.3	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	42.76	-43.6	1.5	-7.4	-0.3	0.00	0.0	4.6	42.7	0.0	-1.2	0.0	41.5
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	42.76	-43.6	1.5	-7.4	-0.3	0.00	0.0	4.6	42.7	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	25.36	-39.1	0.8	-9.0	-0.2	0.00	0.0	2.0	47.9	0.0	-1.2	0.0	46.7
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	25.36	-39.1	0.8	-9.0	-0.2	0.00	0.0	2.0	47.9	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	23.11	-38.3	0.7	-4.8	-0.2	0.00	0.0	0.3	27.5	0.0	-7.4	0.0	20.1
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	23.11	-38.3	0.7	-4.8	-0.2	0.00	0.0	0.3	27.5	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	19.06	-36.6	0.4	-0.5	-0.2	0.00	0.0	0.0	62.1	0.0	-28.2	0.0	38.9
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	19.06	-36.6	0.4	-0.5	-0.2	0.00	0.0	0.0	62.1	0.0			
Receiver T9 FI GF Lmax 53 dB(A) LAeq - Day 47 dB(A) LAeq - Nig 31 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	23.43	-38.4	0.0	-0.5	-0.2	0.00	0.0	0.7	41.1	0.0	-1.6	0.0	39.5
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	23.43	-38.4	0.0	-0.5	-0.2	0.00	0.0	0.7	41.1	0.0	-13.5	0.0	27.6
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	26.44	-39.4	-0.3	-19.9	-0.1	0.00	0.0	4.1	19.3	0.0	-0.8	0.0	18.5
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	26.44	-39.4	-0.3	-19.9	-0.1	0.00	0.0	4.1	19.3	0.0	-10.3	0.0	9.0

MWA Environmental

24

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	l or A m,m²	Kl dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	24.95	-38.9	-0.6	-19.0	-0.1	0.00	0.0	0.1	16.5	0.0	-0.8	0.0	15.7
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	24.95	-38.9	-0.6	-19.0	-0.1	0.00	0.0	0.1	16.5	0.0	-10.3	0.0	6.2
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	25.74	-39.2	-0.4	-19.3	-0.1	0.00	0.0	7.6	23.6	0.0	-0.8	0.0	22.8
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	25.74	-39.2	-0.4	-19.3	-0.1	0.00	0.0	7.6	23.6	0.0	-10.3	0.0	13.2
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	27.14	-39.7	-0.2	-20.1	-0.1	0.00	0.0	1.2	14.1	0.0	-0.8	0.0	13.3
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	27.14	-39.7	-0.2	-20.1	-0.1	0.00	0.0	1.2	14.1	0.0	-10.3	0.0	3.8
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	27.18	-39.7	-0.3	-19.3	-0.1	0.00	0.0	5.4	16.0	0.0	-0.8	0.0	15.2
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	27.18	-39.7	-0.3	-19.3	-0.1	0.00	0.0	5.4	16.0	0.0	-10.3	0.0	5.7
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	25.00	-39.0	-0.1	0.0	-0.2	0.00	0.0	0.8	28.6	0.0	12.6	0.0	41.2
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	25.00	-39.0	-0.1	0.0	-0.2	0.00	0.0	0.8	28.6	0.0	-1.1	0.0	27.5
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	32.04	-41.1	1.0	0.0	-0.9	0.00	0.0	2.3	37.3	0.0	-7.4	0.0	34.9
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	32.04	-41.1	1.0	0.0	-0.9	0.00	0.0	2.3	37.3	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	34.32	-41.7	0.8	-12.1	-0.1	0.00	0.0	0.2	21.9	0.0	-0.8	0.0	21.2
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	34.32	-41.7	0.8	-12.1	-0.1	0.00	0.0	0.2	21.9	0.0	-10.3	0.0	11.6
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	52.71	-45.4	1.4	-23.7	-0.5	0.00	0.0	0.9	14.4	0.0	-1.2	0.0	13.2
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	52.71	-45.4	1.4	-23.7	-0.5	0.00	0.0	0.9	14.4	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	42.72	-43.6	1.3	-12.5	-0.3	0.00	0.0	2.8	35.8	0.0	-1.2	0.0	34.5
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	42.72	-43.6	1.3	-12.5	-0.3	0.00	0.0	2.8	35.8	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	25.00	-39.0	0.6	-12.9	-0.1	0.00	0.0	1.0	43.0	0.0	-1.2	0.0	41.7
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	25.00	-39.0	0.6	-12.9	-0.1	0.00	0.0	1.0	43.0	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	23.35	-38.4	0.3	-0.1	-0.2	0.00	0.0	0.6	32.1	0.0	-7.4	0.0	24.7
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	23.35	-38.4	0.3	-0.1	-0.2	0.00	0.0	0.6	32.1	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	20.44	-37.2	0.0	-0.1	-0.2	0.00	0.0	0.2	61.7	0.0	-28.2	0.0	38.5
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	20.44	-37.2	0.0	-0.1	-0.2	0.00	0.0	0.2	61.7	0.0			
Receiver T9 FIF 1 Lmax 53 dB(A) LAeq - Day 50 dB(A) LAeq - Nig 30 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	23.89	-38.6	0.1	-0.7	-0.2	0.00	0.0	0.2	40.4	0.0	-1.6	0.0	38.8
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	23.89	-38.6	0.1	-0.7	-0.2	0.00	0.0	0.2	40.4	0.0	-13.5	0.0	26.9
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	26.40	-39.4	0.4	-20.0	-0.1	0.00	0.0	5.4	21.3	0.0	-0.8	0.0	20.5
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	26.40	-39.4	0.4	-20.0	-0.1	0.00	0.0	5.4	21.3	0.0	-10.3	0.0	11.0
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	24.91	-38.9	0.2	-19.2	-0.1	0.00	0.0	0.1	17.1	0.0	-0.8	0.0	16.3
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	24.91	-38.9	0.2	-19.2	-0.1	0.00	0.0	0.1	17.1	0.0	-10.3	0.0	6.8
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	25.70	-39.2	0.3	-19.4	-0.1	0.00	0.0	8.7	25.3	0.0	-0.8	0.0	24.5
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	25.70	-39.2	0.3	-19.4	-0.1	0.00	0.0	8.7	25.3	0.0	-10.3	0.0	14.9

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	l or A m,m²	Kl dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	27.10	-39.7	0.5	-20.2	-0.1	0.00	0.0	1.2	14.7	0.0	-0.8	0.0	13.9
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	27.10	-39.7	0.5	-20.2	-0.1	0.00	0.0	1.2	14.7	0.0	-10.3	0.0	4.4
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	27.14	-39.7	0.4	-19.3	-0.1	0.00	0.0	6.5	17.9	0.0	-0.8	0.0	17.1
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	27.14	-39.7	0.4	-19.3	-0.1	0.00	0.0	6.5	17.9	0.0	-10.3	0.0	7.5
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	25.37	-39.1	0.2	-0.1	-0.2	0.00	0.0	0.3	28.1	0.0	12.6	0.0	40.7
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	25.37	-39.1	0.2	-0.1	-0.2	0.00	0.0	0.3	28.1	0.0	-1.1	0.0	27.0
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	32.21	-41.2	1.1	-6.6	-0.6	0.00	0.0	2.1	30.9	0.0	-7.4	0.0	28.5
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	32.21	-41.2	1.1	-6.6	-0.6	0.00	0.0	2.1	30.9	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	34.00	-41.6	1.2	-7.5	-0.2	0.00	0.0	0.1	27.0	0.0	-0.8	0.0	26.2
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	34.00	-41.6	1.2	-7.5	-0.2	0.00	0.0	0.1	27.0	0.0	-10.3	0.0	16.6
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	52.86	-45.5	1.7	-24.0	-0.5	0.00	0.0	0.9	14.4	0.0	-1.2	0.0	13.2
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	52.86	-45.5	1.7	-24.0	-0.5	0.00	0.0	0.9	14.4	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	42.68	-43.6	1.5	-5.9	-0.4	0.00	0.0	3.1	42.8	0.0	-1.2	0.0	41.6
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	42.68	-43.6	1.5	-5.9	-0.4	0.00	0.0	3.1	42.8	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	24.92	-38.9	0.8	-8.1	-0.2	0.00	0.0	1.2	48.1	0.0	-1.2	0.0	46.9
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	24.92	-38.9	0.8	-8.1	-0.2	0.00	0.0	1.2	48.1	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	23.53	-38.4	0.7	-4.8	-0.2	0.00	0.0	0.3	27.3	0.0	-7.4	0.0	19.9
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	23.53	-38.4	0.7	-4.8	-0.2	0.00	0.0	0.3	27.3	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	20.64	-37.3	0.3	-0.5	-0.2	0.00	0.0	0.0	61.4	0.0	-28.2	0.0	38.2
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	20.64	-37.3	0.3	-0.5	-0.2	0.00	0.0	0.0	61.4	0.0			
Receiver T10 FI GF Lmax 52 dB(A) LAeq - Day 47 dB(A) LAeq - Nig 31 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	23.50	-38.4	0.0	-0.6	-0.2	0.00	0.0	0.7	41.0	0.0	-1.6	0.0	39.4
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	23.50	-38.4	0.0	-0.6	-0.2	0.00	0.0	0.7	41.0	0.0	-13.5	0.0	27.5
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	23.27	-38.3	-0.3	-19.5	-0.1	0.00	0.0	7.7	24.5	0.0	-0.8	0.0	23.7
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	23.27	-38.3	-0.3	-19.5	-0.1	0.00	0.0	7.7	24.5	0.0	-10.3	0.0	14.2
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	21.49	-37.6	-0.5	-18.8	-0.1	0.00	0.0	0.1	18.1	0.0	-0.8	0.0	17.3
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	21.49	-37.6	-0.5	-18.8	-0.1	0.00	0.0	0.1	18.1	0.0	-10.3	0.0	7.8
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	22.40	-38.0	-0.4	-18.8	-0.1	0.00	0.0	0.1	17.8	0.0	-0.8	0.0	17.0
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	22.40	-38.0	-0.4	-18.8	-0.1	0.00	0.0	0.1	17.8	0.0	-10.3	0.0	7.5
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	24.09	-38.6	-0.2	-19.7	-0.1	0.00	0.0	8.4	22.8	0.0	-0.8	0.0	22.0
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	24.09	-38.6	-0.2	-19.7	-0.1	0.00	0.0	8.4	22.8	0.0	-10.3	0.0	12.4
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	23.98	-38.6	-0.2	-18.6	-0.1	0.00	0.0	5.1	17.6	0.0	-0.8	0.0	16.8
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	23.98	-38.6	-0.2	-18.6	-0.1	0.00	0.0	5.1	17.6	0.0	-10.3	0.0	7.2

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li	Rw	L'w	Lw	I or A	KI	KT	DO	S	Adiv	Agr	Abar	Aatm	Amisc	ADI	dLrefl	Ls	Cmet	dLw	ZR	Lr	
			dB(A)	dB	dB(A)	dB(A)	m,m²	dB	dB	dB	m	dB	dB	dB	dB	dB	dB	dB(A)	dB(A)	dB	dB	dB	dB(A)	
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	25.70	-39.2	-0.1	0.0	-0.3	0.00	0.0	0.9	28.4	0.0	12.6	0.0	41.0	
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	25.70	-39.2	-0.1	0.0	-0.3	0.00	0.0	0.9	28.4	0.0	-1.1	0.0	27.3	
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	33.81	-41.6	0.9	0.0	-0.9	0.00	0.0	2.3	36.7	0.0	-7.4	0.0	34.3	
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	33.81	-41.6	0.9	0.0	-0.9	0.00	0.0	2.3	36.7	0.0				
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	33.55	-41.5	0.7	-12.2	-0.1	0.00	0.0	0.2	22.1	0.0	-0.8	0.0	21.3	
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	33.55	-41.5	0.7	-12.2	-0.1	0.00	0.0	0.2	22.1	0.0	-10.3	0.0	11.7	
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	53.55	-45.6	1.4	-24.1	-0.5	0.00	0.0	0.2	13.2	0.0	-1.2	0.0	11.9	
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	53.55	-45.6	1.4	-24.1	-0.5	0.00	0.0	0.2	13.2	0.0				
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	44.46	-44.0	1.2	-12.2	-0.3	0.00	0.0	1.5	34.4	0.0	-1.2	0.0	33.1	
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	44.46	-44.0	1.2	-12.2	-0.3	0.00	0.0	1.5	34.4	0.0				
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	27.11	-39.7	0.5	-12.2	-0.2	0.00	0.0	0.5	42.4	0.0	-1.2	0.0	41.1	
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	27.11	-39.7	0.5	-12.2	-0.2	0.00	0.0	0.5	42.4	0.0				
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	26.12	-39.3	0.2	-0.1	-0.2	0.00	0.0	0.8	31.1	0.0	-7.4	0.0	23.7	
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	26.12	-39.3	0.2	-0.1	-0.2	0.00	0.0	0.8	31.1	0.0				
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	24.47	-38.8	-0.1	-0.1	-0.2	0.00	0.0	0.7	60.5	0.0	-28.2	0.0	37.3	
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	24.47	-38.8	-0.1	-0.1	-0.2	0.00	0.0	0.7	60.5	0.0				
Receiver T10 FI F 1 Lmax 53 dB(A) LAeq - Day 49 dB(A) LAeq - Nig 30 dB(A)																								
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	23.95	-38.6	0.0	-0.6	-0.2	0.00	0.0	0.3	40.4	0.0	-1.6	0.0	38.8	
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	23.95	-38.6	0.0	-0.6	-0.2	0.00	0.0	0.3	40.4	0.0	-13.5	0.0	26.9	
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	23.22	-38.3	0.4	-19.5	-0.1	0.00	0.0	9.6	27.2	0.0	-0.8	0.0	26.4	
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	23.22	-38.3	0.4	-19.5	-0.1	0.00	0.0	9.6	27.2	0.0	-10.3	0.0	16.8	
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	21.44	-37.6	0.2	-18.8	-0.1	0.00	0.0	0.1	18.8	0.0	-0.8	0.0	18.0	
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	21.44	-37.6	0.2	-18.8	-0.1	0.00	0.0	0.1	18.8	0.0	-10.3	0.0	8.5	
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	22.35	-38.0	0.3	-18.8	-0.1	0.00	0.0	0.1	18.6	0.0	-0.8	0.0	17.8	
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	22.35	-38.0	0.3	-18.8	-0.1	0.00	0.0	0.1	18.6	0.0	-10.3	0.0	8.2	
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	24.04	-38.6	0.5	-19.7	-0.1	0.00	0.0	10.5	25.6	0.0	-0.8	0.0	24.8	
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	24.04	-38.6	0.5	-19.7	-0.1	0.00	0.0	10.5	25.6	0.0	-10.3	0.0	15.2	
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	23.93	-38.6	0.4	-18.4	-0.1	0.00	0.0	6.3	19.7	0.0	-0.8	0.0	18.9	
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	23.93	-38.6	0.4	-18.4	-0.1	0.00	0.0	6.3	19.7	0.0	-10.3	0.0	9.4	
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	26.06	-39.3	0.2	-0.1	-0.3	0.00	0.0	0.3	27.9	0.0	12.6	0.0	40.5	
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	26.06	-39.3	0.2	-0.1	-0.3	0.00	0.0	0.3	27.9	0.0	-1.1	0.0	26.8	
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	33.97	-41.6	1.1	-6.3	-0.7	0.00	0.0	2.1	30.7	0.0	-7.4	0.0	28.3	
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	33.97	-41.6	1.1	-6.3	-0.7	0.00	0.0	2.1	30.7	0.0				

26062 Carina
Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	l or A m,m²	Kl dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)	
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	33.23	-41.4	1.2	-7.8	-0.1	0.00	0.0	0.1	26.9	0.0	-0.8	0.0	26.1	
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	33.23	-41.4	1.2	-7.8	-0.1	0.00	0.0	0.1	26.9	0.0	-10.3	0.0	16.5	
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	53.70	-45.6	1.7	-24.2	-0.5	0.00	0.0	0.1	13.2	0.0	-1.2	0.0	12.0	
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	53.70	-45.6	1.7	-24.2	-0.5	0.00	0.0	0.1	13.2	0.0				
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	44.42	-43.9	1.5	-5.8	-0.4	0.00	0.0	1.9	41.2	0.0	-1.2	0.0	40.0	
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	44.42	-43.9	1.5	-5.8	-0.4	0.00	0.0	1.9	41.2	0.0				
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	27.04	-39.6	0.8	-7.7	-0.2	0.00	0.0	0.6	47.3	0.0	-1.2	0.0	46.1	
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	27.04	-39.6	0.8	-7.7	-0.2	0.00	0.0	0.6	47.3	0.0				
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	26.28	-39.4	0.6	-4.4	-0.2	0.00	0.0	0.4	26.8	0.0	-7.4	0.0	19.4	
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	26.28	-39.4	0.6	-4.4	-0.2	0.00	0.0	0.4	26.8	0.0				
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	24.64	-38.8	0.3	-0.6	-0.2	0.00	0.0	0.1	59.8	0.0	-28.2	0.0	36.6	
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	24.64	-38.8	0.3	-0.6	-0.2	0.00	0.0	0.1	59.8	0.0				
Receiver T11 FI GF Lmax 53 dB(A) LAeq - Day 46 dB(A) LAeq - Nig 31 dB(A)																								
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	23.19	-38.3	0.0	-0.5	-0.2	0.00	0.0	0.7	41.2	0.0	-1.6	0.0	39.6	
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	23.19	-38.3	0.0	-0.5	-0.2	0.00	0.0	0.7	41.2	0.0	-13.5	0.0	27.7	
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	19.83	-36.9	-0.2	-18.3	-0.1	0.00	0.0	1.6	21.2	0.0	-0.8	0.0	20.4	
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	19.83	-36.9	-0.2	-18.3	-0.1	0.00	0.0	1.6	21.2	0.0	-10.3	0.0	10.8	
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	17.84	-36.0	-0.4	-12.1	-0.1	0.00	0.0	0.2	26.6	0.0	-0.8	0.0	25.8	
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	17.84	-36.0	-0.4	-12.1	-0.1	0.00	0.0	0.2	26.6	0.0	-10.3	0.0	16.3	
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	18.81	-36.5	-0.3	-11.2	-0.1	0.00	0.0	0.2	27.1	0.0	-0.8	0.0	26.3	
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	18.81	-36.5	-0.3	-11.2	-0.1	0.00	0.0	0.2	27.1	0.0	-10.3	0.0	16.8	
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	20.73	-37.3	-0.1	-18.5	-0.1	0.00	0.0	2.3	19.4	0.0	-0.8	0.0	18.6	
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	20.73	-37.3	-0.1	-18.5	-0.1	0.00	0.0	2.3	19.4	0.0	-10.3	0.0	9.0	
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	20.46	-37.2	-0.1	-10.6	-0.1	0.00	0.0	1.2	23.2	0.0	-0.8	0.0	22.4	
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	20.46	-37.2	-0.1	-10.6	-0.1	0.00	0.0	1.2	23.2	0.0	-10.3	0.0	12.9	
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	25.76	-39.2	-0.1	0.0	-0.3	0.00	0.0	0.9	28.5	0.0	12.6	0.0	41.1	
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	25.76	-39.2	-0.1	0.0	-0.3	0.00	0.0	0.9	28.5	0.0	-1.1	0.0	27.4	
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	35.11	-41.9	1.0	0.0	-0.9	0.00	0.0	2.3	36.4	0.0	-7.4	0.0	34.0	
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	35.11	-41.9	1.0	0.0	-0.9	0.00	0.0	2.3	36.4	0.0				
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	32.26	-41.2	0.8	-12.4	-0.1	0.00	0.0	1.4	23.5	0.0	-0.8	0.0	22.7	
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	32.26	-41.2	0.8	-12.4	-0.1	0.00	0.0	1.4	23.5	0.0	-10.3	0.0	13.2	
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	53.35	-45.5	1.4	-24.3	-0.5	0.00	0.0	0.2	13.1	0.0	-1.2	0.0	11.9	
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	53.35	-45.5	1.4	-24.3	-0.5	0.00	0.0	0.2	13.1	0.0				

MWA Environmental

28

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	l or A m,m²	Kl dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	45.43	-44.1	1.3	-18.2	-0.3	0.00	0.0	3.8	30.4	0.0	-1.2	0.0	29.1
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	45.43	-44.1	1.3	-18.2	-0.3	0.00	0.0	3.8	30.4	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	29.10	-40.3	0.6	-13.3	-0.2	0.00	0.0	1.2	41.4	0.0	-1.2	0.0	40.2
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	29.10	-40.3	0.6	-13.3	-0.2	0.00	0.0	1.2	41.4	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	28.73	-40.2	0.2	-0.1	-0.3	0.00	0.0	1.0	30.5	0.0	-7.4	0.0	23.1
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	28.73	-40.2	0.2	-0.1	-0.3	0.00	0.0	1.0	30.5	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	28.37	-40.0	-0.2	-0.1	-0.3	0.00	0.0	0.9	59.3	0.0	-28.2	0.0	36.1
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	28.37	-40.0	-0.2	-0.1	-0.3	0.00	0.0	0.9	59.3	0.0			
Receiver T11 FI F 1 Lmax 53 dB(A) LAeq - Day 48 dB(A) LAeq - Nig 31 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	23.66	-38.5	0.0	-0.7	-0.2	0.00	0.0	0.2	40.5	0.0	-1.6	0.0	38.9
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	23.66	-38.5	0.0	-0.7	-0.2	0.00	0.0	0.2	40.5	0.0	-13.5	0.0	26.9
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	19.78	-36.9	0.4	-17.8	-0.1	0.00	0.0	2.5	23.1	0.0	-0.8	0.0	22.3
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	19.78	-36.9	0.4	-17.8	-0.1	0.00	0.0	2.5	23.1	0.0	-10.3	0.0	12.8
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	17.78	-36.0	0.2	-11.4	-0.1	0.00	0.0	0.6	28.3	0.0	-0.8	0.0	27.5
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	17.78	-36.0	0.2	-11.4	-0.1	0.00	0.0	0.6	28.3	0.0	-10.3	0.0	18.0
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	18.76	-36.5	0.3	-9.9	-0.1	0.00	0.0	0.2	29.1	0.0	-0.8	0.0	28.3
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	18.76	-36.5	0.3	-9.9	-0.1	0.00	0.0	0.2	29.1	0.0	-10.3	0.0	18.7
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	20.68	-37.3	0.5	-17.9	-0.1	0.00	0.0	3.0	21.2	0.0	-0.8	0.0	20.4
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	20.68	-37.3	0.5	-17.9	-0.1	0.00	0.0	3.0	21.2	0.0	-10.3	0.0	10.9
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	20.40	-37.2	0.5	-8.6	-0.1	0.00	0.0	1.3	25.9	0.0	-0.8	0.0	25.1
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	20.40	-37.2	0.5	-8.6	-0.1	0.00	0.0	1.3	25.9	0.0	-10.3	0.0	15.6
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	26.13	-39.3	0.2	-0.1	-0.3	0.00	0.0	0.3	27.9	0.0	12.6	0.0	40.5
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	26.13	-39.3	0.2	-0.1	-0.3	0.00	0.0	0.3	27.9	0.0	-1.1	0.0	26.8
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	35.26	-41.9	1.1	-6.5	-0.6	0.00	0.0	2.1	30.1	0.0	-7.4	0.0	27.7
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	35.26	-41.9	1.1	-6.5	-0.6	0.00	0.0	2.1	30.1	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	31.93	-41.1	1.2	-8.0	-0.1	0.00	0.0	0.1	27.0	0.0	-0.8	0.0	26.2
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	31.93	-41.1	1.2	-8.0	-0.1	0.00	0.0	0.1	27.0	0.0	-10.3	0.0	16.7
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	53.50	-45.6	1.7	-24.4	-0.5	0.00	0.0	0.3	13.2	0.0	-1.2	0.0	12.0
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	53.50	-45.6	1.7	-24.4	-0.5	0.00	0.0	0.3	13.2	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	45.40	-44.1	1.5	-12.9	-0.4	0.00	0.0	5.1	37.2	0.0	-1.2	0.0	36.0
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	45.40	-44.1	1.5	-12.9	-0.4	0.00	0.0	5.1	37.2	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	29.05	-40.3	0.8	-9.0	-0.2	0.00	0.0	1.3	46.0	0.0	-1.2	0.0	44.8
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	29.05	-40.3	0.8	-9.0	-0.2	0.00	0.0	1.3	46.0	0.0			

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	I or A m,m²	KI dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)	
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	28.88	-40.2	0.7	-4.4	-0.2	0.00	0.0	0.5	26.2	0.0	-7.4	0.0	18.8	
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	28.88	-40.2	0.7	-4.4	-0.2	0.00	0.0	0.5	26.2	0.0				
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	28.52	-40.1	0.3	-0.9	-0.3	0.00	0.0	0.2	58.2	0.0	-28.2	0.0	35.0	
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	28.52	-40.1	0.3	-0.9	-0.3	0.00	0.0	0.2	58.2	0.0				
Receiver T12 FI GF Lmax 53 dB(A) LAeq - Day 45 dB(A) LAeq - Nig 31 dB(A)																								
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	25.29	-39.1	0.1	-0.5	-0.2	0.00	0.0	0.7	40.5	0.0	-1.6	0.0	38.9	
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	25.29	-39.1	0.1	-0.5	-0.2	0.00	0.0	0.7	40.5	0.0	-13.5	0.0	27.0	
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	19.30	-36.7	-0.1	-10.9	-0.1	0.00	0.0	1.6	28.9	0.0	-0.8	0.0	28.1	
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	19.30	-36.7	-0.1	-10.9	-0.1	0.00	0.0	1.6	28.9	0.0	-10.3	0.0	18.5	
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	17.26	-35.7	-0.4	-12.3	-0.1	0.00	0.0	1.3	27.9	0.0	-0.8	0.0	27.1	
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	17.26	-35.7	-0.4	-12.3	-0.1	0.00	0.0	1.3	27.9	0.0	-10.3	0.0	17.5	
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	18.21	-36.2	-0.2	-11.4	-0.1	0.00	0.0	1.6	28.8	0.0	-0.8	0.0	28.0	
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	18.21	-36.2	-0.2	-11.4	-0.1	0.00	0.0	1.6	28.8	0.0	-10.3	0.0	18.4	
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	20.21	-37.1	-0.1	-10.6	-0.1	0.00	0.0	2.1	27.2	0.0	-0.8	0.0	26.5	
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	20.21	-37.1	-0.1	-10.6	-0.1	0.00	0.0	2.1	27.2	0.0	-10.3	0.0	16.9	
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	19.76	-36.9	-0.1	-10.7	-0.1	0.00	0.0	2.0	24.2	0.0	-0.8	0.0	23.4	
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	19.76	-36.9	-0.1	-10.7	-0.1	0.00	0.0	2.0	24.2	0.0	-10.3	0.0	13.9	
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	27.81	-39.9	-0.1	0.0	-0.3	0.00	0.0	1.0	27.9	0.0	12.6	0.0	40.5	
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	27.81	-39.9	-0.1	0.0	-0.3	0.00	0.0	1.0	27.9	0.0	-1.1	0.0	26.8	
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	38.25	-42.6	1.0	0.0	-1.0	0.00	0.0	2.3	35.6	0.0	-7.4	0.0	33.2	
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	38.25	-42.6	1.0	0.0	-1.0	0.00	0.0	2.3	35.6	0.0				
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	33.22	-41.4	0.8	-12.1	-0.1	0.00	0.0	1.4	23.5	0.0	-0.8	0.0	22.7	
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	33.22	-41.4	0.8	-12.1	-0.1	0.00	0.0	1.4	23.5	0.0	-10.3	0.0	13.2	
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	54.77	-45.8	1.4	-23.3	-0.5	0.00	0.0	1.8	15.3	0.0	-1.2	0.0	14.1	
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	54.77	-45.8	1.4	-23.3	-0.5	0.00	0.0	1.8	15.3	0.0				
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	48.10	-44.6	1.2	-22.6	-0.3	0.00	0.0	5.2	26.8	0.0	-1.2	0.0	25.6	
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	48.10	-44.6	1.2	-22.6	-0.3	0.00	0.0	5.2	26.8	0.0				
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	33.07	-41.4	0.6	-14.5	-0.2	0.00	0.0	1.9	39.8	0.0	-1.2	0.0	38.6	
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	33.07	-41.4	0.6	-14.5	-0.2	0.00	0.0	1.9	39.8	0.0				
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	33.06	-41.4	0.2	-0.1	-0.3	0.00	0.0	1.0	29.2	0.0	-7.4	0.0	21.8	
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	33.06	-41.4	0.2	-0.1	-0.3	0.00	0.0	1.0	29.2	0.0				
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	33.53	-41.5	-0.2	-0.1	-0.3	0.00	0.0	1.0	57.9	0.0	-28.2	0.0	34.7	
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	33.53	-41.5	-0.2	-0.1	-0.3	0.00	0.0	1.0	57.9	0.0				

MWA Environmental

30

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	I or A m,m²	KI dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)
Receiver T12 FI F 1 Lmax 53 dB(A) LAeq - Day 46 dB(A) LAeq - Nig 31 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	25.73	-39.2	0.1	-0.7	-0.3	0.00	0.0	0.3	39.8	0.0	-1.6	0.0	38.1
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	25.73	-39.2	0.1	-0.7	-0.3	0.00	0.0	0.3	39.8	0.0	-13.5	0.0	26.2
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	19.25	-36.7	0.4	-9.1	-0.1	0.00	0.0	2.3	31.9	0.0	-0.8	0.0	31.1
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	19.25	-36.7	0.4	-9.1	-0.1	0.00	0.0	2.3	31.9	0.0	-10.3	0.0	21.5
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	17.21	-35.7	0.2	-11.6	0.0	0.00	0.0	2.7	30.6	0.0	-0.8	0.0	29.8
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	17.21	-35.7	0.2	-11.6	0.0	0.00	0.0	2.7	30.6	0.0	-10.3	0.0	20.2
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	18.16	-36.2	0.3	-10.1	-0.1	0.00	0.0	2.7	31.7	0.0	-0.8	0.0	30.9
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	18.16	-36.2	0.3	-10.1	-0.1	0.00	0.0	2.7	31.7	0.0	-10.3	0.0	21.3
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	20.16	-37.1	0.5	-8.5	-0.1	0.00	0.0	2.4	30.3	0.0	-0.8	0.0	29.5
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	20.16	-37.1	0.5	-8.5	-0.1	0.00	0.0	2.4	30.3	0.0	-10.3	0.0	20.0
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	19.71	-36.9	0.4	-8.9	-0.1	0.00	0.0	2.5	27.1	0.0	-0.8	0.0	26.3
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	19.71	-36.9	0.4	-8.9	-0.1	0.00	0.0	2.5	27.1	0.0	-10.3	0.0	16.7
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	28.17	-40.0	0.2	-0.1	-0.3	0.00	0.0	0.3	27.3	0.0	12.6	0.0	39.9
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	28.17	-40.0	0.2	-0.1	-0.3	0.00	0.0	0.3	27.3	0.0	-1.1	0.0	26.2
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	38.40	-42.7	1.1	-6.4	-0.7	0.00	0.0	2.1	29.5	0.0	-7.4	0.0	27.1
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	38.40	-42.7	1.1	-6.4	-0.7	0.00	0.0	2.1	29.5	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	32.89	-41.3	1.2	-7.8	-0.1	0.00	0.0	0.1	27.0	0.0	-0.8	0.0	26.2
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	32.89	-41.3	1.2	-7.8	-0.1	0.00	0.0	0.1	27.0	0.0	-10.3	0.0	16.6
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	54.91	-45.8	1.6	-23.2	-0.5	0.00	0.0	2.0	16.0	0.0	-1.2	0.0	14.7
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	54.91	-45.8	1.6	-23.2	-0.5	0.00	0.0	2.0	16.0	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	48.07	-44.6	1.5	-19.7	-0.3	0.00	0.0	8.0	32.9	0.0	-1.2	0.0	31.7
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	48.07	-44.6	1.5	-19.7	-0.3	0.00	0.0	8.0	32.9	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	33.01	-41.4	0.9	-11.1	-0.2	0.00	0.0	2.4	43.9	0.0	-1.2	0.0	42.7
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	33.01	-41.4	0.9	-11.1	-0.2	0.00	0.0	2.4	43.9	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	33.20	-41.4	0.6	-4.2	-0.2	0.00	0.0	0.5	25.1	0.0	-7.4	0.0	17.7
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	33.20	-41.4	0.6	-4.2	-0.2	0.00	0.0	0.5	25.1	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	33.66	-41.5	0.3	-1.3	-0.3	0.00	0.0	0.3	56.4	0.0	-28.2	0.0	33.2
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	33.66	-41.5	0.3	-1.3	-0.3	0.00	0.0	0.3	56.4	0.0			
Receiver T67 FI GF Lmax 60 dB(A) LAeq - Day 48 dB(A) LAeq - Nig 35 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	17.59	-35.9	0.7	0.0	-0.2	0.00	0.0	0.4	44.6	0.0	-1.6	0.0	43.0
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	17.59	-35.9	0.7	0.0	-0.2	0.00	0.0	0.4	44.6	0.0	-13.5	0.0	31.0

MWA Environmental

31

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li	Rw	L'w	Lw	l or A	Kl	KT	DO	S	Adiv	Agr	Abar	Aatm	Amisc	ADI	dLrefl	Ls	Cmet	dLw	ZR	Lr
			dB(A)	dB	dB(A)	dB(A)	m,m ²	dB	dB	dB	m	dB	dB	dB	dB	dB	dB	dB(A)	dB(A)	dB	dB	dB	dB(A)
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	9.14	-30.2	0.1	-14.1	0.0	0.00	0.0	3.4	34.2	0.0	-0.8	0.0	33.4
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	9.14	-30.2	0.1	-14.1	0.0	0.00	0.0	3.4	34.2	0.0	-10.3	0.0	23.9
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	8.80	-29.9	0.1	-14.2	0.0	0.00	0.0	3.4	34.4	0.0	-0.8	0.0	33.6
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	8.80	-29.9	0.1	-14.2	0.0	0.00	0.0	3.4	34.4	0.0	-10.3	0.0	24.1
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	8.77	-29.9	0.1	-14.3	0.0	0.00	0.0	3.4	34.3	0.0	-0.8	0.0	33.5
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	8.77	-29.9	0.1	-14.3	0.0	0.00	0.0	3.4	34.3	0.0	-10.3	0.0	24.0
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	9.41	-30.5	0.1	-14.0	0.0	0.00	0.0	3.8	32.4	0.0	-0.8	0.0	31.6
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	9.41	-30.5	0.1	-14.0	0.0	0.00	0.0	3.8	32.4	0.0	-10.3	0.0	22.1
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	8.80	-29.9	0.0	-14.5	0.0	0.00	0.0	3.6	29.2	0.0	-0.8	0.0	28.4
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	8.80	-29.9	0.0	-14.5	0.0	0.00	0.0	3.6	29.2	0.0	-10.3	0.0	18.8
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	18.11	-36.2	0.4	0.0	-0.2	0.00	0.0	0.5	31.7	0.0	12.6	0.0	44.3
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	18.11	-36.2	0.4	0.0	-0.2	0.00	0.0	0.5	31.7	0.0	-1.1	0.0	30.6
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	31.74	-41.0	1.6	0.0	-0.9	0.00	0.0	2.4	38.1	0.0	-7.4	0.0	35.7
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	31.74	-41.0	1.6	0.0	-0.9	0.00	0.0	2.4	38.1	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	22.19	-37.9	0.9	-15.0	-0.1	0.00	0.0	0.3	23.2	0.0	-0.8	0.0	22.4
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	22.19	-37.9	0.9	-15.0	-0.1	0.00	0.0	0.3	23.2	0.0	-10.3	0.0	12.9
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	42.00	-43.5	1.0	-22.3	-0.4	0.00	0.0	3.9	20.6	0.0	-1.2	0.0	19.3
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	42.00	-43.5	1.0	-22.3	-0.4	0.00	0.0	3.9	20.6	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	38.95	-42.8	1.6	-24.5	-0.4	0.00	0.0	1.5	23.4	0.0	-1.2	0.0	22.2
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	38.95	-42.8	1.6	-24.5	-0.4	0.00	0.0	1.5	23.4	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	29.59	-40.4	1.6	-21.9	-0.2	0.00	0.0	1.0	33.5	0.0	-1.2	0.0	32.3
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	29.59	-40.4	1.6	-21.9	-0.2	0.00	0.0	1.0	33.5	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	31.14	-40.9	1.5	-0.1	-0.3	0.00	0.0	0.4	30.5	0.0	-7.4	0.0	23.1
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	31.14	-40.9	1.5	-0.1	-0.3	0.00	0.0	0.4	30.5	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	34.58	-41.8	1.6	-0.1	-0.3	0.00	0.0	0.0	58.5	0.0	-28.2	0.0	35.3
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	34.58	-41.8	1.6	-0.1	-0.3	0.00	0.0	0.0	58.5	0.0			
Receiver T67 FI F 1 Lmax 59 dB(A) LAeq - Day 48 dB(A) LAeq - Nig 36 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	18.27	-36.2	0.7	-1.3	-0.2	0.00	0.0	0.4	43.0	0.0	-1.6	0.0	41.4
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	18.27	-36.2	0.7	-1.3	-0.2	0.00	0.0	0.4	43.0	0.0	-13.5	0.0	29.5
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	8.80	-29.9	0.4	-12.2	0.0	0.00	0.0	4.5	37.8	0.0	-0.8	0.0	37.0
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	8.80	-29.9	0.4	-12.2	0.0	0.00	0.0	4.5	37.8	0.0	-10.3	0.0	27.4
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	8.46	-29.5	0.4	-12.3	0.0	0.00	0.0	4.4	37.9	0.0	-0.8	0.0	37.2
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	8.46	-29.5	0.4	-12.3	0.0	0.00	0.0	4.4	37.9	0.0	-10.3	0.0	27.6

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	l or A m,m²	Kl dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	8.42	-29.5	0.4	-12.5	0.0	0.00	0.0	4.5	37.9	0.0	-0.8	0.0	37.1
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	8.42	-29.5	0.4	-12.5	0.0	0.00	0.0	4.5	37.9	0.0	-10.3	0.0	27.5
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	9.09	-30.2	0.4	-12.1	0.0	0.00	0.0	4.8	35.9	0.0	-0.8	0.0	35.2
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	9.09	-30.2	0.4	-12.1	0.0	0.00	0.0	4.8	35.9	0.0	-10.3	0.0	25.6
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	8.45	-29.5	0.3	-13.2	0.0	0.00	0.0	5.1	32.6	0.0	-0.8	0.0	31.8
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	8.45	-29.5	0.3	-13.2	0.0	0.00	0.0	5.1	32.6	0.0	-10.3	0.0	22.3
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	18.81	-36.5	0.6	-1.2	-0.1	0.00	0.0	0.5	30.3	0.0	12.6	0.0	43.0
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	18.81	-36.5	0.6	-1.2	-0.1	0.00	0.0	0.5	30.3	0.0	-1.1	0.0	29.3
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	31.85	-41.1	1.7	-8.6	-0.5	0.00	0.0	2.4	30.0	0.0	-7.4	0.0	27.6
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	31.85	-41.1	1.7	-8.6	-0.5	0.00	0.0	2.4	30.0	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	21.61	-37.7	1.3	-11.1	-0.1	0.00	0.0	0.1	27.5	0.0	-0.8	0.0	26.7
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	21.61	-37.7	1.3	-11.1	-0.1	0.00	0.0	0.1	27.5	0.0	-10.3	0.0	17.1
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	42.15	-43.5	1.2	-21.1	-0.3	0.00	0.0	4.4	22.4	0.0	-1.2	0.0	21.2
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	42.15	-43.5	1.2	-21.1	-0.3	0.00	0.0	4.4	22.4	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	38.86	-42.8	1.8	-22.8	-0.3	0.00	0.0	1.7	25.7	0.0	-1.2	0.0	24.4
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	38.86	-42.8	1.8	-22.8	-0.3	0.00	0.0	1.7	25.7	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	29.46	-40.4	1.8	-20.4	-0.2	0.00	0.0	1.0	35.2	0.0	-1.2	0.0	34.0
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	29.46	-40.4	1.8	-20.4	-0.2	0.00	0.0	1.0	35.2	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	31.22	-40.9	1.8	-8.1	-0.1	0.00	0.0	0.4	22.7	0.0	-7.4	0.0	15.3
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	31.22	-40.9	1.8	-8.1	-0.1	0.00	0.0	0.4	22.7	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	34.64	-41.8	1.8	-8.1	-0.2	0.00	0.0	0.0	50.8	0.0	-28.2	0.0	27.6
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	34.64	-41.8	1.8	-8.1	-0.2	0.00	0.0	0.0	50.8	0.0			
Receiver T68 FI GF Lmax 60 dB(A) LAeq - Day 49 dB(A) LAeq - Nig 36 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	16.50	-35.3	0.7	0.0	-0.1	0.00	0.0	0.4	45.2	0.0	-1.6	0.0	43.6
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	16.50	-35.3	0.7	0.0	-0.1	0.00	0.0	0.4	45.2	0.0	-13.5	0.0	31.7
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	9.45	-30.5	0.1	-14.1	0.0	0.00	0.0	3.4	33.8	0.0	-0.8	0.0	33.0
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	9.45	-30.5	0.1	-14.1	0.0	0.00	0.0	3.4	33.8	0.0	-10.3	0.0	23.5
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	10.42	-31.3	0.1	-13.8	0.0	0.00	0.0	3.6	33.5	0.0	-0.8	0.0	32.7
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	10.42	-31.3	0.1	-13.8	0.0	0.00	0.0	3.6	33.5	0.0	-10.3	0.0	23.1
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	9.80	-30.8	0.0	-14.0	0.0	0.00	0.0	3.4	33.6	0.0	-0.8	0.0	32.8
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	9.80	-30.8	0.0	-14.0	0.0	0.00	0.0	3.4	33.6	0.0	-10.3	0.0	23.3
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	9.12	-30.2	0.1	-14.2	0.0	0.00	0.0	2.3	31.0	0.0	-0.8	0.0	30.2
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	9.12	-30.2	0.1	-14.2	0.0	0.00	0.0	2.3	31.0	0.0	-10.3	0.0	20.6

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	I or A m,m²	KI dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	8.78	-29.9	0.0	-14.6	0.0	0.00	0.0	2.6	28.1	0.0	-0.8	0.0	27.3
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	8.78	-29.9	0.0	-14.6	0.0	0.00	0.0	2.6	28.1	0.0	-10.3	0.0	17.7
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	15.40	-34.7	0.3	-0.2	-0.1	0.00	0.0	0.5	32.8	0.0	12.6	0.0	45.4
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	15.40	-34.7	0.3	-0.2	-0.1	0.00	0.0	0.5	32.8	0.0	-1.1	0.0	31.7
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	29.26	-40.3	1.6	0.0	-0.8	0.00	0.0	2.4	38.9	0.0	-7.4	0.0	36.5
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	29.26	-40.3	1.6	0.0	-0.8	0.00	0.0	2.4	38.9	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	18.60	-36.4	1.0	-15.8	-0.1	0.00	0.0	0.3	24.1	0.0	-0.8	0.0	23.3
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	18.60	-36.4	1.0	-15.8	-0.1	0.00	0.0	0.3	24.1	0.0	-10.3	0.0	13.7
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	36.70	-42.3	0.9	-21.9	-0.3	0.00	0.0	4.1	22.3	0.0	-1.2	0.0	21.0
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	36.70	-42.3	0.9	-21.9	-0.3	0.00	0.0	4.1	22.3	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	35.09	-41.9	1.6	-24.5	-0.3	0.00	0.0	1.3	24.2	0.0	-1.2	0.0	22.9
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	35.09	-41.9	1.6	-24.5	-0.3	0.00	0.0	1.3	24.2	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	28.37	-40.0	1.6	-23.9	-0.3	0.00	0.0	1.5	32.3	0.0	-1.2	0.0	31.1
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	28.37	-40.0	1.6	-23.9	-0.3	0.00	0.0	1.5	32.3	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	30.51	-40.7	1.5	0.0	-0.3	0.00	0.0	0.7	30.9	0.0	-7.4	0.0	23.5
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	30.51	-40.7	1.5	0.0	-0.3	0.00	0.0	0.7	30.9	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	34.72	-41.8	1.6	0.0	-0.3	0.00	0.0	0.7	59.2	0.0	-28.2	0.0	36.0
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	34.72	-41.8	1.6	0.0	-0.3	0.00	0.0	0.7	59.2	0.0			
Receiver T68 FI F 1 Lmax 60 dB(A) LAeq - Day 48 dB(A) LAeq - Nig 36 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	17.17	-35.7	0.7	-1.1	-0.2	0.00	0.0	0.5	43.8	0.0	-1.6	0.0	42.2
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	17.17	-35.7	0.7	-1.1	-0.2	0.00	0.0	0.5	43.8	0.0	-13.5	0.0	30.3
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	9.07	-30.1	0.4	-12.2	0.0	0.00	0.0	4.4	37.3	0.0	-0.8	0.0	36.6
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	9.07	-30.1	0.4	-12.2	0.0	0.00	0.0	4.4	37.3	0.0	-10.3	0.0	27.0
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	10.08	-31.1	0.4	-12.0	0.0	0.00	0.0	4.6	36.9	0.0	-0.8	0.0	36.1
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	10.08	-31.1	0.4	-12.0	0.0	0.00	0.0	4.6	36.9	0.0	-10.3	0.0	26.6
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	9.44	-30.5	0.4	-12.3	0.0	0.00	0.0	4.6	37.1	0.0	-0.8	0.0	36.3
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	9.44	-30.5	0.4	-12.3	0.0	0.00	0.0	4.6	37.1	0.0	-10.3	0.0	26.7
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	8.72	-29.8	0.4	-12.4	0.0	0.00	0.0	2.7	33.9	0.0	-0.8	0.0	33.1
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	8.72	-29.8	0.4	-12.4	0.0	0.00	0.0	2.7	33.9	0.0	-10.3	0.0	23.6
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	8.37	-29.4	0.3	-13.3	0.0	0.00	0.0	3.3	30.8	0.0	-0.8	0.0	30.0
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	8.37	-29.4	0.3	-13.3	0.0	0.00	0.0	3.3	30.8	0.0	-10.3	0.0	20.4
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	16.37	-35.3	0.5	-0.8	-0.1	0.00	0.0	0.4	31.8	0.0	12.6	0.0	44.5
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	16.37	-35.3	0.5	-0.8	-0.1	0.00	0.0	0.4	31.8	0.0	-1.1	0.0	30.7

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	I or A m,m ²	KI dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	29.36	-40.3	1.7	-7.8	-0.5	0.00	0.0	2.4	31.6	0.0	-7.4	0.0	29.2
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	29.36	-40.3	1.7	-7.8	-0.5	0.00	0.0	2.4	31.6	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	17.87	-36.0	1.3	-12.1	-0.1	0.00	0.0	0.1	28.2	0.0	-0.8	0.0	27.4
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	17.87	-36.0	1.3	-12.1	-0.1	0.00	0.0	0.1	28.2	0.0	-10.3	0.0	17.8
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	36.86	-42.3	1.1	-20.4	-0.3	0.00	0.0	5.0	24.9	0.0	-1.2	0.0	23.7
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	36.86	-42.3	1.1	-20.4	-0.3	0.00	0.0	5.0	24.9	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	34.97	-41.9	1.8	-23.3	-0.3	0.00	0.0	1.5	25.8	0.0	-1.2	0.0	24.6
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	34.97	-41.9	1.8	-23.3	-0.3	0.00	0.0	1.5	25.8	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	28.21	-40.0	1.8	-22.9	-0.2	0.00	0.0	1.4	33.5	0.0	-1.2	0.0	32.2
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	28.21	-40.0	1.8	-22.9	-0.2	0.00	0.0	1.4	33.5	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	30.57	-40.7	1.8	-7.4	-0.1	0.00	0.0	0.6	23.8	0.0	-7.4	0.0	16.4
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	30.57	-40.7	1.8	-7.4	-0.1	0.00	0.0	0.6	23.8	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	34.77	-41.8	1.8	-7.6	-0.2	0.00	0.0	0.5	51.8	0.0	-28.2	0.0	28.6
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	34.77	-41.8	1.8	-7.6	-0.2	0.00	0.0	0.5	51.8	0.0			
Receiver T69 FI GF Lmax 60 dB(A) LAeq - Day 47 dB(A) LAeq - Nig 34 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	18.15	-36.2	0.7	0.0	-0.2	0.00	0.0	0.3	44.2	0.0	-1.6	0.0	42.6
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	18.15	-36.2	0.7	0.0	-0.2	0.00	0.0	0.3	44.2	0.0	-13.5	0.0	30.7
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	13.55	-33.6	-0.1	-17.6	0.0	0.00	0.0	1.6	25.3	0.0	-0.8	0.0	24.5
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	13.55	-33.6	-0.1	-17.6	0.0	0.00	0.0	1.6	25.3	0.0	-10.3	0.0	15.0
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	15.13	-34.6	-0.1	-12.6	0.0	0.00	0.0	2.7	30.3	0.0	-0.8	0.0	29.5
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	15.13	-34.6	-0.1	-12.6	0.0	0.00	0.0	2.7	30.3	0.0	-10.3	0.0	20.0
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	14.28	-34.1	-0.1	-12.9	0.0	0.00	0.0	0.8	28.6	0.0	-0.8	0.0	27.8
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	14.28	-34.1	-0.1	-12.9	0.0	0.00	0.0	0.8	28.6	0.0	-10.3	0.0	18.3
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	12.88	-33.2	-0.1	-20.2	0.0	0.00	0.0	2.1	21.7	0.0	-0.8	0.0	20.9
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	12.88	-33.2	-0.1	-20.2	0.0	0.00	0.0	2.1	21.7	0.0	-10.3	0.0	11.3
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	12.83	-33.2	-0.2	-13.5	0.0	0.00	0.0	0.5	23.5	0.0	-0.8	0.0	22.7
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	12.83	-33.2	-0.2	-13.5	0.0	0.00	0.0	0.5	23.5	0.0	-10.3	0.0	13.2
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	18.18	-36.2	0.3	-0.1	-0.2	0.00	0.0	0.4	31.4	0.0	12.6	0.0	44.1
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	18.18	-36.2	0.3	-0.1	-0.2	0.00	0.0	0.4	31.4	0.0	-1.1	0.0	30.4
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	28.46	-40.1	1.6	0.0	-0.8	0.00	0.0	0.0	36.7	0.0	-7.4	0.0	34.3
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	28.46	-40.1	1.6	0.0	-0.8	0.00	0.0	0.0	36.7	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	17.05	-35.6	1.0	-16.1	-0.1	0.00	0.0	0.4	24.6	0.0	-0.8	0.0	23.8
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	17.05	-35.6	1.0	-16.1	-0.1	0.00	0.0	0.4	24.6	0.0	-10.3	0.0	14.2

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	I or A m,m²	KI dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)	
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	31.74	-41.0	0.7	-21.3	-0.2	0.00	0.0	5.0	25.0	0.0	-1.2	0.0	23.7	
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	31.74	-41.0	0.7	-21.3	-0.2	0.00	0.0	5.0	25.0	0.0				
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	32.41	-41.2	1.6	-24.5	-0.3	0.00	0.0	1.1	24.7	0.0	-1.2	0.0	23.4	
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	32.41	-41.2	1.6	-24.5	-0.3	0.00	0.0	1.1	24.7	0.0				
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	28.96	-40.2	1.6	-24.2	-0.3	0.00	0.0	1.5	31.8	0.0	-1.2	0.0	30.6	
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	28.96	-40.2	1.6	-24.2	-0.3	0.00	0.0	1.5	31.8	0.0				
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	31.76	-41.0	1.5	0.0	-0.3	0.00	0.0	1.9	31.8	0.0	-7.4	0.0	24.4	
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	31.76	-41.0	1.5	0.0	-0.3	0.00	0.0	1.9	31.8	0.0				
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	36.53	-42.2	1.5	0.0	-0.3	0.00	0.0	2.1	60.0	0.0	-28.2	0.0	36.8	
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	36.53	-42.2	1.5	0.0	-0.3	0.00	0.0	2.1	60.0	0.0				
Receiver T69 FI F 1 Lmax 59 dB(A) LAeq - Day 46 dB(A) LAeq - Nig 33 dB(A)																								
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	18.71	-36.4	0.7	-0.9	-0.2	0.00	0.0	0.3	43.1	0.0	-1.6	0.0	41.5	
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	18.71	-36.4	0.7	-0.9	-0.2	0.00	0.0	0.3	43.1	0.0	-13.5	0.0	29.6	
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	13.25	-33.4	0.3	-18.2	0.0	0.00	0.0	2.1	25.8	0.0	-0.8	0.0	25.0	
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	13.25	-33.4	0.3	-18.2	0.0	0.00	0.0	2.1	25.8	0.0	-10.3	0.0	15.5	
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	14.86	-34.4	0.3	-11.2	0.0	0.00	0.0	3.2	32.9	0.0	-0.8	0.0	32.1	
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	14.86	-34.4	0.3	-11.2	0.0	0.00	0.0	3.2	32.9	0.0	-10.3	0.0	22.5	
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	14.00	-33.9	0.3	-11.5	0.0	0.00	0.0	0.7	30.5	0.0	-0.8	0.0	29.7	
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	14.00	-33.9	0.3	-11.5	0.0	0.00	0.0	0.7	30.5	0.0	-10.3	0.0	20.2	
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	12.56	-33.0	0.3	-19.6	0.0	0.00	0.0	2.1	22.8	0.0	-0.8	0.0	22.0	
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	12.56	-33.0	0.3	-19.6	0.0	0.00	0.0	2.1	22.8	0.0	-10.3	0.0	12.5	
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	12.51	-32.9	0.2	-12.5	0.0	0.00	0.0	0.4	25.1	0.0	-0.8	0.0	24.3	
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	12.51	-32.9	0.2	-12.5	0.0	0.00	0.0	0.4	25.1	0.0	-10.3	0.0	14.8	
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	18.79	-36.5	0.6	-0.7	-0.2	0.00	0.0	0.2	30.6	0.0	12.6	0.0	43.2	
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	18.79	-36.5	0.6	-0.7	-0.2	0.00	0.0	0.2	30.6	0.0	-1.1	0.0	29.5	
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	28.55	-40.1	1.7	-6.3	-0.6	0.00	0.0	0.0	30.7	0.0	-7.4	0.0	28.3	
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	28.55	-40.1	1.7	-6.3	-0.6	0.00	0.0	0.0	30.7	0.0				
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	16.22	-35.2	1.2	-12.6	-0.1	0.00	0.0	0.2	28.6	0.0	-0.8	0.0	27.8	
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	16.22	-35.2	1.2	-12.6	-0.1	0.00	0.0	0.2	28.6	0.0	-10.3	0.0	18.2	
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	31.89	-41.1	0.9	-19.1	-0.2	0.00	0.0	5.5	27.8	0.0	-1.2	0.0	26.5	
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	31.89	-41.1	0.9	-19.1	-0.2	0.00	0.0	5.5	27.8	0.0				
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	32.26	-41.2	1.8	-23.7	-0.3	0.00	0.0	1.3	26.0	0.0	-1.2	0.0	24.7	
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	32.26	-41.2	1.8	-23.7	-0.3	0.00	0.0	1.3	26.0	0.0				

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	I or A m,m²	KI dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	28.79	-40.2	1.7	-23.4	-0.2	0.00	0.0	1.5	32.9	0.0	-1.2	0.0	31.6
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	28.79	-40.2	1.7	-23.4	-0.2	0.00	0.0	1.5	32.9	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	31.80	-41.0	1.7	-6.3	-0.2	0.00	0.0	1.9	25.8	0.0	-7.4	0.0	18.4
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	31.80	-41.0	1.7	-6.3	-0.2	0.00	0.0	1.9	25.8	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	36.56	-42.3	1.8	-6.5	-0.2	0.00	0.0	2.0	53.9	0.0	-28.2	0.0	30.7
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	36.56	-42.3	1.8	-6.5	-0.2	0.00	0.0	2.0	53.9	0.0			
Receiver T70 FI GF Lmax 59 dB(A) LAeq - Day 45 dB(A) LAeq - Nig 32 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	21.25	-37.5	0.8	-0.1	-0.2	0.00	0.0	0.0	42.5	0.0	-1.6	0.0	40.9
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	21.25	-37.5	0.8	-0.1	-0.2	0.00	0.0	0.0	42.5	0.0	-13.5	0.0	29.0
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	18.40	-36.3	-0.2	-19.1	-0.1	0.00	0.0	1.8	21.1	0.0	-0.8	0.0	20.3
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	18.40	-36.3	-0.2	-19.1	-0.1	0.00	0.0	1.8	21.1	0.0	-10.3	0.0	10.7
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	20.20	-37.1	-0.3	-11.7	-0.1	0.00	0.0	0.9	26.7	0.0	-0.8	0.0	25.9
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	20.20	-37.1	-0.3	-11.7	-0.1	0.00	0.0	0.9	26.7	0.0	-10.3	0.0	16.4
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	19.28	-36.7	-0.3	-11.9	-0.1	0.00	0.0	0.5	26.6	0.0	-0.8	0.0	25.8
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	19.28	-36.7	-0.3	-11.9	-0.1	0.00	0.0	0.5	26.6	0.0	-10.3	0.0	16.2
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	17.60	-35.9	-0.2	-20.1	-0.1	0.00	0.0	0.0	16.8	0.0	-0.8	0.0	16.0
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	17.60	-35.9	-0.2	-20.1	-0.1	0.00	0.0	0.0	16.8	0.0	-10.3	0.0	6.4
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	17.70	-36.0	-0.4	-19.2	-0.1	0.00	0.0	0.1	14.5	0.0	-0.8	0.0	13.7
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	17.70	-36.0	-0.4	-19.2	-0.1	0.00	0.0	0.1	14.5	0.0	-10.3	0.0	4.2
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	22.43	-38.0	0.5	-0.2	-0.2	0.00	0.0	0.0	29.2	0.0	12.6	0.0	41.8
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	22.43	-38.0	0.5	-0.2	-0.2	0.00	0.0	0.0	29.2	0.0	-1.1	0.0	28.1
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	28.58	-40.1	1.6	-12.2	-0.3	0.00	0.0	0.0	24.9	0.0	-7.4	0.0	22.5
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	28.58	-40.1	1.6	-12.2	-0.3	0.00	0.0	0.0	24.9	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	17.30	-35.8	1.0	-16.1	-0.1	0.00	0.0	0.0	24.0	0.0	-0.8	0.0	23.2
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	17.30	-35.8	1.0	-16.1	-0.1	0.00	0.0	0.0	24.0	0.0	-10.3	0.0	13.7
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	27.07	-39.6	0.6	-20.3	-0.2	0.00	0.0	5.2	27.4	0.0	-1.2	0.0	26.2
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	27.07	-39.6	0.6	-20.3	-0.2	0.00	0.0	5.2	27.4	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	30.48	-40.7	1.6	-24.5	-0.3	0.00	0.0	1.0	25.1	0.0	-1.2	0.0	23.9
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	30.48	-40.7	1.6	-24.5	-0.3	0.00	0.0	1.0	25.1	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	30.21	-40.6	1.6	-24.3	-0.3	0.00	0.0	1.0	30.8	0.0	-1.2	0.0	29.6
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	30.21	-40.6	1.6	-24.3	-0.3	0.00	0.0	1.0	30.8	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	33.65	-41.5	1.5	0.0	-0.3	0.00	0.0	0.0	29.4	0.0	-7.4	0.0	22.0
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	33.65	-41.5	1.5	0.0	-0.3	0.00	0.0	0.0	29.4	0.0			

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	I or A m,m²	KI dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)	
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	38.73	-42.8	1.5	0.0	-0.3	0.00	0.0	0.0	57.4	0.0	-28.2	0.0	34.2	
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	38.73	-42.8	1.5	0.0	-0.3	0.00	0.0	0.0	57.4	0.0				
Receiver T70 FI F 1 Lmax 58 dB(A) LAeq - Day 45 dB(A) LAeq - Nig 32 dB(A)																								
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	21.66	-37.7	0.8	-0.9	-0.2	0.00	0.0	0.0	41.6	0.0	-1.6	0.0	40.0	
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	21.66	-37.7	0.8	-0.9	-0.2	0.00	0.0	0.0	41.6	0.0	-13.5	0.0	28.1	
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	18.15	-36.2	0.3	-18.8	-0.1	0.00	0.0	1.8	22.1	0.0	-0.8	0.0	21.3	
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	18.15	-36.2	0.3	-18.8	-0.1	0.00	0.0	1.8	22.1	0.0	-10.3	0.0	11.8	
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	19.98	-37.0	0.3	-10.5	-0.1	0.00	0.0	1.4	29.1	0.0	-0.8	0.0	28.3	
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	19.98	-37.0	0.3	-10.5	-0.1	0.00	0.0	1.4	29.1	0.0	-10.3	0.0	18.8	
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	19.04	-36.6	0.3	-10.8	-0.1	0.00	0.0	0.6	28.4	0.0	-0.8	0.0	27.6	
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	19.04	-36.6	0.3	-10.8	-0.1	0.00	0.0	0.6	28.4	0.0	-10.3	0.0	18.1	
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	17.34	-35.8	0.3	-19.9	-0.1	0.00	0.0	0.0	17.6	0.0	-0.8	0.0	16.8	
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	17.34	-35.8	0.3	-19.9	-0.1	0.00	0.0	0.0	17.6	0.0	-10.3	0.0	7.3	
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	17.44	-35.8	0.2	-19.0	-0.1	0.00	0.0	0.2	15.5	0.0	-0.8	0.0	14.7	
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	17.44	-35.8	0.2	-19.0	-0.1	0.00	0.0	0.2	15.5	0.0	-10.3	0.0	5.1	
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	22.80	-38.1	0.7	-0.6	-0.2	0.00	0.0	0.0	28.9	0.0	12.6	0.0	41.5	
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	22.80	-38.1	0.7	-0.6	-0.2	0.00	0.0	0.0	28.9	0.0	-1.1	0.0	27.8	
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	28.65	-40.1	1.7	-24.2	-0.7	0.00	0.0	0.0	12.7	0.0	-7.4	0.0	10.3	
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	28.65	-40.1	1.7	-24.2	-0.7	0.00	0.0	0.0	12.7	0.0				
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	16.45	-35.3	1.2	-12.8	-0.1	0.00	0.0	0.0	28.0	0.0	-0.8	0.0	27.3	
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	16.45	-35.3	1.2	-12.8	-0.1	0.00	0.0	0.0	28.0	0.0	-10.3	0.0	17.7	
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	27.27	-39.7	0.8	-17.1	-0.2	0.00	0.0	5.3	30.9	0.0	-1.2	0.0	29.6	
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	27.27	-39.7	0.8	-17.1	-0.2	0.00	0.0	5.3	30.9	0.0				
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	30.30	-40.6	1.8	-23.9	-0.3	0.00	0.0	1.1	26.1	0.0	-1.2	0.0	24.9	
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	30.30	-40.6	1.8	-23.9	-0.3	0.00	0.0	1.1	26.1	0.0				
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	30.03	-40.5	1.7	-23.6	-0.2	0.00	0.0	1.1	31.9	0.0	-1.2	0.0	30.7	
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	30.03	-40.5	1.7	-23.6	-0.2	0.00	0.0	1.1	31.9	0.0				
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	33.67	-41.5	1.7	-5.5	-0.2	0.00	0.0	0.0	24.2	0.0	-7.4	0.0	16.8	
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	33.67	-41.5	1.7	-5.5	-0.2	0.00	0.0	0.0	24.2	0.0				
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	38.75	-42.8	1.8	-5.6	-0.2	0.00	0.0	0.0	52.2	0.0	-28.2	0.0	29.0	
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	38.75	-42.8	1.8	-5.6	-0.2	0.00	0.0	0.0	52.2	0.0				
Receiver T71 FI GF Lmax 55 dB(A) LAeq - Day 41 dB(A) LAeq - Nig 27 dB(A)																								

MWA Environmental

38

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	l or A m,m²	Kl dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	25.39	-39.1	1.0	-3.3	-0.2	0.00	0.0	0.0	38.0	0.0	-1.6	0.0	36.4
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	25.39	-39.1	1.0	-3.3	-0.2	0.00	0.0	0.0	38.0	0.0	-13.5	0.0	24.5
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	23.89	-38.6	-0.3	-19.3	-0.1	0.00	0.0	1.0	17.7	0.0	-0.8	0.0	17.0
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	23.89	-38.6	-0.3	-19.3	-0.1	0.00	0.0	1.0	17.7	0.0	-10.3	0.0	7.4
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	25.82	-39.2	-0.4	-17.5	-0.1	0.00	0.0	1.3	19.2	0.0	-0.8	0.0	18.4
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	25.82	-39.2	-0.4	-17.5	-0.1	0.00	0.0	1.3	19.2	0.0	-10.3	0.0	8.9
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	24.86	-38.9	-0.4	-18.1	-0.1	0.00	0.0	1.1	18.6	0.0	-0.8	0.0	17.8
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	24.86	-38.9	-0.4	-18.1	-0.1	0.00	0.0	1.1	18.6	0.0	-10.3	0.0	8.3
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	23.03	-38.2	-0.3	-20.1	-0.1	0.00	0.0	0.0	14.2	0.0	-0.8	0.0	13.4
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	23.03	-38.2	-0.3	-20.1	-0.1	0.00	0.0	0.0	14.2	0.0	-10.3	0.0	3.9
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	23.23	-38.3	-0.5	-19.2	-0.1	0.00	0.0	0.0	11.9	0.0	-0.8	0.0	11.1
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	23.23	-38.3	-0.5	-19.2	-0.1	0.00	0.0	0.0	11.9	0.0	-10.3	0.0	1.6
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	27.04	-39.6	0.7	-3.4	-0.2	0.00	0.0	0.0	24.6	0.0	12.6	0.0	37.2
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	27.04	-39.6	0.7	-3.4	-0.2	0.00	0.0	0.0	24.6	0.0	-1.1	0.0	23.5
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	29.31	-40.3	1.6	-22.5	-0.5	0.00	0.0	0.0	14.3	0.0	-7.4	0.0	11.8
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	29.31	-40.3	1.6	-22.5	-0.5	0.00	0.0	0.0	14.3	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	19.07	-36.6	1.0	-16.3	-0.1	0.00	0.0	0.0	23.1	0.0	-0.8	0.0	22.3
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	19.07	-36.6	1.0	-16.3	-0.1	0.00	0.0	0.0	23.1	0.0	-10.3	0.0	12.7
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	21.72	-37.7	0.5	-18.5	-0.1	0.00	0.0	4.5	30.5	0.0	-1.2	0.0	29.3
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	21.72	-37.7	0.5	-18.5	-0.1	0.00	0.0	4.5	30.5	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	28.82	-40.2	1.7	-24.5	-0.3	0.00	0.0	0.9	25.6	0.0	-1.2	0.0	24.3
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	28.82	-40.2	1.7	-24.5	-0.3	0.00	0.0	0.9	25.6	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	31.96	-41.1	1.6	-24.4	-0.3	0.00	0.0	1.1	30.4	0.0	-1.2	0.0	29.1
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	31.96	-41.1	1.6	-24.4	-0.3	0.00	0.0	1.1	30.4	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	36.01	-42.1	1.5	-14.9	-0.1	0.00	0.0	0.0	14.1	0.0	-7.4	0.0	6.7
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	36.01	-42.1	1.5	-14.9	-0.1	0.00	0.0	0.0	14.1	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	41.27	-43.3	1.6	-14.3	-0.2	0.00	0.0	0.3	43.1	0.0	-28.2	0.0	19.9
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	41.27	-43.3	1.6	-14.3	-0.2	0.00	0.0	0.3	43.1	0.0			
Receiver T71 FI F 1 Lmax 55 dB(A) LAeq - Day 41 dB(A) LAeq - Nig 28 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	25.66	-39.2	1.0	-3.6	-0.2	0.00	0.0	0.0	37.6	0.0	-1.6	0.0	36.0
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	25.66	-39.2	1.0	-3.6	-0.2	0.00	0.0	0.0	37.6	0.0	-13.5	0.0	24.1
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	23.68	-38.5	0.3	-19.2	-0.1	0.00	0.0	1.5	19.0	0.0	-0.8	0.0	18.2
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	23.68	-38.5	0.3	-19.2	-0.1	0.00	0.0	1.5	19.0	0.0	-10.3	0.0	8.7

MWA Environmental

39

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	l or A m,m²	Kl dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	25.63	-39.2	0.3	-17.1	-0.1	0.00	0.0	1.4	20.4	0.0	-0.8	0.0	19.6
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	25.63	-39.2	0.3	-17.1	-0.1	0.00	0.0	1.4	20.4	0.0	-10.3	0.0	10.0
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	24.66	-38.8	0.3	-17.9	-0.1	0.00	0.0	1.2	19.6	0.0	-0.8	0.0	18.9
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	24.66	-38.8	0.3	-17.9	-0.1	0.00	0.0	1.2	19.6	0.0	-10.3	0.0	9.3
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	22.81	-38.2	0.3	-20.2	-0.1	0.00	0.0	0.0	14.9	0.0	-0.8	0.0	14.1
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	22.81	-38.2	0.3	-20.2	-0.1	0.00	0.0	0.0	14.9	0.0	-10.3	0.0	4.5
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	23.02	-38.2	0.2	-19.3	-0.1	0.00	0.0	0.0	12.6	0.0	-0.8	0.0	11.8
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	23.02	-38.2	0.2	-19.3	-0.1	0.00	0.0	0.0	12.6	0.0	-10.3	0.0	2.3
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	27.27	-39.7	1.0	-3.4	-0.2	0.00	0.0	0.0	24.8	0.0	12.6	0.0	37.4
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	27.27	-39.7	1.0	-3.4	-0.2	0.00	0.0	0.0	24.8	0.0	-1.1	0.0	23.7
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	29.36	-40.3	1.7	-22.4	-0.5	0.00	0.0	0.0	14.5	0.0	-7.4	0.0	12.1
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	29.36	-40.3	1.7	-22.4	-0.5	0.00	0.0	0.0	14.5	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	18.28	-36.2	1.3	-13.1	-0.1	0.00	0.0	0.0	26.9	0.0	-0.8	0.0	26.1
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	18.28	-36.2	1.3	-13.1	-0.1	0.00	0.0	0.0	26.9	0.0	-10.3	0.0	16.5
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	22.00	-37.8	0.7	-12.9	-0.1	0.00	0.0	3.7	35.3	0.0	-1.2	0.0	34.0
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	22.00	-37.8	0.7	-12.9	-0.1	0.00	0.0	3.7	35.3	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	28.62	-40.1	1.8	-24.2	-0.3	0.00	0.0	1.0	26.3	0.0	-1.2	0.0	25.0
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	28.62	-40.1	1.8	-24.2	-0.3	0.00	0.0	1.0	26.3	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	31.77	-41.0	1.8	-23.7	-0.3	0.00	0.0	1.2	31.4	0.0	-1.2	0.0	30.1
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	31.77	-41.0	1.8	-23.7	-0.3	0.00	0.0	1.2	31.4	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	36.02	-42.1	1.8	-20.9	-0.2	0.00	0.0	0.0	8.3	0.0	-7.4	0.0	0.9
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	36.02	-42.1	1.8	-20.9	-0.2	0.00	0.0	0.0	8.3	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	41.28	-43.3	1.8	-21.9	-0.2	0.00	0.0	1.5	36.9	0.0	-28.2	0.0	13.7
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	41.28	-43.3	1.8	-21.9	-0.2	0.00	0.0	1.5	36.9	0.0			
Receiver T72 FI GF Lmax 52 dB(A) LAeq - Day 38 dB(A) LAeq - Nig 23 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	30.75	-40.7	1.1	-6.1	-0.2	0.00	0.0	0.0	33.6	0.0	-1.6	0.0	32.0
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	30.75	-40.7	1.1	-6.1	-0.2	0.00	0.0	0.0	33.6	0.0	-13.5	0.0	20.0
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	30.07	-40.6	-0.5	-19.3	-0.1	0.00	0.0	0.0	14.6	0.0	-0.8	0.0	13.8
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	30.07	-40.6	-0.5	-19.3	-0.1	0.00	0.0	0.0	14.6	0.0	-10.3	0.0	4.2
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	32.05	-41.1	-0.5	-17.6	-0.1	0.00	0.0	0.6	16.3	0.0	-0.8	0.0	15.5
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	32.05	-41.1	-0.5	-17.6	-0.1	0.00	0.0	0.6	16.3	0.0	-10.3	0.0	5.9
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	31.07	-40.8	-0.5	-18.2	-0.1	0.00	0.0	0.4	15.8	0.0	-0.8	0.0	15.0
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	31.07	-40.8	-0.5	-18.2	-0.1	0.00	0.0	0.4	15.8	0.0	-10.3	0.0	5.4

MWA Environmental

40

26062 Carina

Mean propagation Leq - Single Point Calculation

10

Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	I or A m,m²	KI dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	29.18	-40.3	-0.4	-20.2	-0.1	0.00	0.0	0.0	12.0	0.0	-0.8	0.0	11.2
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	29.18	-40.3	-0.4	-20.2	-0.1	0.00	0.0	0.0	12.0	0.0	-10.3	0.0	1.7
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	29.44	-40.4	-0.6	-19.2	-0.1	0.00	0.0	0.0	9.7	0.0	-0.8	0.0	8.9
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	29.44	-40.4	-0.6	-19.2	-0.1	0.00	0.0	0.0	9.7	0.0	-10.3	0.0	-0.6
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	32.46	-41.2	0.8	-6.4	-0.2	0.00	0.0	0.0	20.0	0.0	12.6	0.0	32.7
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	32.46	-41.2	0.8	-6.4	-0.2	0.00	0.0	0.0	20.0	0.0	-1.1	0.0	18.9
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	31.87	-41.1	1.6	-23.7	-0.7	0.00	0.0	0.0	12.2	0.0	-7.4	0.0	9.8
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	31.87	-41.1	1.6	-23.7	-0.7	0.00	0.0	0.0	12.2	0.0			
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	23.03	-38.2	1.0	-15.9	-0.1	0.00	0.0	0.0	21.7	0.0	-0.8	0.0	20.9
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	23.03	-38.2	1.0	-15.9	-0.1	0.00	0.0	0.0	21.7	0.0	-10.3	0.0	11.4
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	17.45	-35.8	0.2	-12.6	-0.1	0.00	0.0	1.6	35.0	0.0	-1.2	0.0	33.8
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	17.45	-35.8	0.2	-12.6	-0.1	0.00	0.0	1.6	35.0	0.0			
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	29.05	-40.3	1.7	-24.5	-0.3	0.00	0.0	0.9	25.6	0.0	-1.2	0.0	24.3
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	29.05	-40.3	1.7	-24.5	-0.3	0.00	0.0	0.9	25.6	0.0			
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	35.29	-41.9	1.6	-24.4	-0.3	0.00	0.0	1.2	29.6	0.0	-1.2	0.0	28.3
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	35.29	-41.9	1.6	-24.4	-0.3	0.00	0.0	1.2	29.6	0.0			
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	39.75	-43.0	1.5	-19.2	-0.2	0.00	0.0	0.1	9.0	0.0	-7.4	0.0	1.6
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	39.75	-43.0	1.5	-19.2	-0.2	0.00	0.0	0.1	9.0	0.0			
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	45.08	-44.1	1.6	-18.9	-0.2	0.00	0.0	0.8	38.2	0.0	-28.2	0.0	15.0
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	45.08	-44.1	1.6	-18.9	-0.2	0.00	0.0	0.8	38.2	0.0			
Receiver T72 FI F 1 Lmax 52 dB(A) LAeq - Day 43 dB(A) LAeq - Nig 24 dB(A)																							
Parking	PLot	LAeq - Day			53.3	79.6	418.8	0.0	0.0	0	30.93	-40.8	1.1	-6.3	-0.2	0.00	0.0	0.0	33.4	0.0	-1.6	0.0	31.8
Parking	PLot	LAeq - Nig			53.3	79.6	418.8	0.0	0.0	0	30.93	-40.8	1.1	-6.3	-0.2	0.00	0.0	0.0	33.4	0.0	-13.5	0.0	19.8
AC1	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	29.88	-40.5	0.3	-19.5	-0.1	0.00	0.0	0.0	15.2	0.0	-0.8	0.0	14.4
AC1	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	29.88	-40.5	0.3	-19.5	-0.1	0.00	0.0	0.0	15.2	0.0	-10.3	0.0	4.9
AC2	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	31.88	-41.1	0.3	-17.5	-0.1	0.00	0.0	0.5	17.1	0.0	-0.8	0.0	16.4
AC2	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	31.88	-41.1	0.3	-17.5	-0.1	0.00	0.0	0.5	17.1	0.0	-10.3	0.0	6.8
AC3	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	30.90	-40.8	0.3	-18.2	-0.1	0.00	0.0	0.4	16.5	0.0	-0.8	0.0	15.7
AC3	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	30.90	-40.8	0.3	-18.2	-0.1	0.00	0.0	0.4	16.5	0.0	-10.3	0.0	6.2
AC4	Point	LAeq - Day			73.0	73.0		0.0	0.0	0	28.99	-40.2	0.3	-20.4	-0.1	0.00	0.0	0.0	12.6	0.0	-0.8	0.0	11.8
AC4	Point	LAeq - Nig			73.0	73.0		0.0	0.0	0	28.99	-40.2	0.3	-20.4	-0.1	0.00	0.0	0.0	12.6	0.0	-10.3	0.0	2.2
AC5	Point	LAeq - Day			70.0	70.0		0.0	0.0	0	29.25	-40.3	0.2	-19.5	-0.1	0.00	0.0	0.0	10.3	0.0	-0.8	0.0	9.5
AC5	Point	LAeq - Nig			70.0	70.0		0.0	0.0	0	29.25	-40.3	0.2	-19.5	-0.1	0.00	0.0	0.0	10.3	0.0	-10.3	0.0	0.0

26062 Carina

Mean propagation Leq - Single Point Calculation

10


Source	Source type	Time slice	Li dB(A)	Rw dB	L'w dB(A)	Lw dB(A)	l or A m,m²	Kl dB	KT dB	DO dB	S m	Adiv dB	Agr dB	Abar dB	Aatm dB	Amisc dB	ADI dB	dLrefl dB(A)	Ls dB(A)	Cmet dB	dLw dB	ZR dB	Lr dB(A)	
Car Trips	Line	LAeq - Day			52.0	67.1	32.3	0.0	0.0	0	32.62	-41.3	1.1	-6.3	-0.2	0.00	0.0	0.0	20.4	0.0	12.6	0.0	33.0	
Car Trips	Line	LAeq - Nig			52.0	67.1	32.3	0.0	0.0	0	32.62	-41.3	1.1	-6.3	-0.2	0.00	0.0	0.0	20.4	0.0	-1.1	0.0	19.3	
Deliveries	Point	LAeq - Day			76.0	76.0		0.0	5.0	0	31.90	-41.1	1.8	-23.6	-0.7	0.00	0.0	0.0	12.4	0.0	-7.4	0.0	10.0	
Deliveries	Point	LAeq - Nig			76.0	76.0		0.0	5.0	0	31.90	-41.1	1.8	-23.6	-0.7	0.00	0.0	0.0	12.4	0.0				
Kitchen Exhaust	Point	LAeq - Day			75.0	75.0		0.0	0.0	0	22.36	-38.0	1.3	-12.8	-0.1	0.00	0.0	0.0	25.4	0.0	-0.8	0.0	24.6	
Kitchen Exhaust	Point	LAeq - Nig			75.0	75.0		0.0	0.0	0	22.36	-38.0	1.3	-12.8	-0.1	0.00	0.0	0.0	25.4	0.0	-10.3	0.0	15.1	
Outdoor Play 1	Area	LAeq - Day			60.5	81.8	133.8	0.0	0.0	0	17.88	-36.0	0.3	-3.9	-0.2	0.00	0.0	0.5	42.4	0.0	-1.2	0.0	41.2	
Outdoor Play 1	Area	LAeq - Nig			60.5	81.8	133.8	0.0	0.0	0	17.88	-36.0	0.3	-3.9	-0.2	0.00	0.0	0.5	42.4	0.0				
Outdoor Play 3	Area	LAeq - Day			66.5	88.0	140.2	0.0	0.0	0	28.83	-40.2	1.8	-24.3	-0.3	0.00	0.0	1.1	26.2	0.0	-1.2	0.0	24.9	
Outdoor Play 3	Area	LAeq - Nig			66.5	88.0	140.2	0.0	0.0	0	28.83	-40.2	1.8	-24.3	-0.3	0.00	0.0	1.1	26.2	0.0				
Outdoor Play 4	Area	LAeq - Day			68.7	93.4	292.3	0.0	0.0	0	35.12	-41.9	1.8	-23.8	-0.3	0.00	0.0	1.4	30.6	0.0	-1.2	0.0	29.4	
Outdoor Play 4	Area	LAeq - Nig			68.7	93.4	292.3	0.0	0.0	0	35.12	-41.9	1.8	-23.8	-0.3	0.00	0.0	1.4	30.6	0.0				
RCV	Line	LAeq - Day			59.0	69.7	11.9	0.0	0.0	0	39.74	-43.0	1.8	-19.0	-0.2	0.00	0.0	0.1	9.4	0.0	-7.4	0.0	2.0	
RCV	Line	LAeq - Nig			59.0	69.7	11.9	0.0	0.0	0	39.74	-43.0	1.8	-19.0	-0.2	0.00	0.0	0.1	9.4	0.0				
Refuse (Loading)	Point	LAeq - Day			99.0	99.0		5.0	0.0	0	45.07	-44.1	1.8	-18.8	-0.2	0.00	0.0	0.8	38.6	0.0	-28.2	0.0	15.4	
Refuse (Loading)	Point	LAeq - Nig			99.0	99.0		5.0	0.0	0	45.07	-44.1	1.8	-18.8	-0.2	0.00	0.0	0.8	38.6	0.0				

MWA Environmental

42

Attachment 4

SoundPLAN Noise Contour Plots



Noise level
LAeq(11hr)
in dB(A)

<= 38	<= 38
38 < <= 41	<= 41
41 < <= 44	<= 44
44 < <= 47	<= 47
47 < <= 50	<= 50
50 < <= 53	<= 53
53 < <= 56	<= 56
56 < <= 59	<= 59

Legend

- Cadastral
- Line source
- * Point receiver
- Parking lot
- Point source
- Area source
- ▨ Main building
- Barrier/Balustrade
- Auxiliary building

Carina 26062

**Childcare Centre
Noise Impact**

**Day Period
Ground Level**

June 2026


Length scale 1:1500

0 10 20 40 60





Noise level
LAeq(9hr)
in dB(A)



Legend

- Cadastral
- Line source
- * Point receiver
- Parking lot
- Point source
- Area source
- Main building
- Barrier/Balustrade
- Auxiliary building

Carina 26062

**Childcare Centre
Noise Impact**


**Night Period
Ground Level**

June 2026

Length scale 1:1500

0 10 20 40 60





Noise level
L_Amax
in dB(A)

<= 40	<= 40
40 <	<= 43
43 <	<= 46
46 <	<= 49
49 <	<= 52
52 <	<= 55
55 <	<= 58
58 <	<= 61
61 <	

Legend

- Cadastral
- Line source
- * Point receiver
- ▨ Parking lot
- Point source
- ▭ Area source
- ▨ Main building
- Barrier/Balustrade
- ▭ Auxiliary building


Carina 26062

Childcare Centre
Noise Impact

L_{max} Night Period
Ground Level

June 2026





Noise level
LAeq(11hr)
in dB(A)

<= 38	<= 38
38 <	<= 41
41 <	<= 44
44 <	<= 47
47 <	<= 50
50 <	<= 53
53 <	<= 56
56 <	<= 59
59 <	<= 59

Legend

- Cadastral
- Line source
- * Point receiver
- ▨ Parking lot
- Point source
- ▨ Area source
- ▨ Main building
- Barrier/Balustrade
- ▨ Auxiliary building

Carina 26062

Childcare Centre
Noise Impact

Day Period
Upper Level

June 2026


Length scale 1:1500

0 10 20 40 60





Noise level
LAeq(9hr)
in dB(A)



Legend

- Cadastral
- Line source
- * Point receiver
- Parking lot
- Point source
- Area source
- Main building
- Barrier/Balustrade
- Auxiliary building

Carina 26062

**Childcare Centre
Noise Impact**


**Night Period
Upper Level**

June 2026

Length scale 1:1500

0 10 20 40 60





Noise level
L_Amax
in dB(A)

	<= 40
40 <	<= 43
43 <	<= 46
46 <	<= 49
49 <	<= 52
52 <	<= 55
55 <	<= 58
58 <	<= 61

Legend

- Cadastral
- Line source
- * Point receiver
- Parking lot
- Point source
- Area source
- Main building
- Barrier/Balustrade
- Auxiliary building

Carina 26062

**Childcare Centre
Noise Impact**

**L_{max} Night Period
Upper Level**

June 2026

Length scale 1:1500

0 10 20 40 60

